

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 2 of 2

Sample ID: **BD09621**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Prep Room Sink CWT



Collect Date: 10/04/2022
Collect Time: 07:27
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - <1.8 except for analyte 6:2 Fluorotelomersulfonic acid. Result of 33 ng/L due to suspected contamination.
Sample test result not affected.
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 11/9/2022 Page 1 of 2
Sample ID: BD09621
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Prep Room Sink CWT

-4TH QTR

Collect Date: 10/04/2022
Collect Time: 07:27
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	4.1	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	3.3	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxahexanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	2.5			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	2.4			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 2 of 2
Sample ID: **BD09622**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Room 814 Sink CWT

4 TH QTR

Collect Date: 10/04/2022
Collect Time: 07:30
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - <1.8 except for analyte 6:2 Fluorotelomersulfonic acid. Result of 12 ng/L due to suspected contamination.
Sample test result not affected.
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 1 of 2
Sample ID: **BD09622**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **Room 814 Sink CWT**

4th QTR

Collect Date: 10/04/2022
Collect Time: 07:30
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluorooctanoic acid (PFOA)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropetanesulfonic acid (PFPeS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HFPO-DA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (PF2EE)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	3.1			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	3.1			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.8			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 11/9/2022 Page 2 of 2

Sample ID: **BD09623**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **PE7 Concession Stand Sink CWT**

HTE QTR

Collect Date: 10/04/2022
Collect Time: 07:37
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.

Surrogates: All surrogate recoveries within acceptable limits.

PFAS FIELD BLANK:

All analytes - <1.9

Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 1 of 2
Sample ID: **BD09623**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **PE7 Concession Stand Sink CWT**

4TH QTR

Collect Date: 10/04/2022
Collect Time: 07:37
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Hexafluoropropylene oxide dimer acid (HF)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropetanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	2.6			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	2.5			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 2 of 2
Sample ID: **BD09624**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **Kitchen Right Sink CWT**

HZ *ATP*

Collect Date: 10/04/2022
Collect Time: 07:42
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - <1.9
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School
Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 1 of 2
Sample ID: **BD09624**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Kitchen Right Sink CWT

4TH QTR

Collect Date: 10/04/2022
Collect Time: 07:42
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling
Potable: Yes
Grab/Comp: Grab

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluoropetanesulfonic acid (PFPeS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.8			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	2.4			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	2.3			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.8			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 2 of 2
Sample ID: **BD09625**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **After GAC Tap**

474 Q72

Collect Date: 10/04/2022
Collect Time: 07:48
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.

Surrogates: All surrogate recoveries within acceptable limits.

PFAS FIELD BLANK:

All analytes - <1.8

Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022

Page 1 of 2

Sample ID: **BD09625**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **After GAC Tap**

4TH QTR

Collect Date: **10/04/2022**
Collect Time: 07:48
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluorooctanesulfonic acid (PFOS)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF	<1.8			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanesulfonic acid (PFPeS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<1.8	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.8			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.8			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park, NY 12018

Printed On : 11/9/2022 Page 2 of 2
Sample ID: **BD09626**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Water Softener Tank A Tap

Collect Date: 10/04/2022
Collect Time: 07:52
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

Handwritten: 4TH QTR

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - <1.8
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Handwritten Signature: Brian P. Collins

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 11/9/2022

Page 1 of 2

Sample ID: BD09626
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Water Softener Tank A Tap

474 QTR

Collect Date: 10/04/2022
Collect Time: 07:52
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluorononanoic acid (PFNA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	7.2			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<2.0	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<2.0	10		ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropetanesulfonic acid (PFPeS)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<2.0			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<2.0			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022 Page 2 of 2

Sample ID: **BD09627**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: **Water Softener Tank B Tap**

4TH QTR

Collect Date: 10/04/2022
Collect Time: 07:55
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|---|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-)Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 11/9/2022

Page 1 of 2

Sample ID: **BD09627**
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Water Softener Tank B Tap

Collect Date: 10/04/2022
Collect Time: 07:55
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

47# QTR

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
11CI-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
9CI-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	10/31/2022

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Sample ID: BD09628
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Tap Closest Storage Tank

4TH QTR

Collect Date: 10/04/2022
Collect Time: 08:00
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)

- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits

- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10899. Samples were prepared on 10/24/22.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - <1.8 except for analyte 6:2 Fluorotelomersulfonic acid. Result of 5.8 ng/L due to suspected contamination.
Sample test result may be biased high.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 11/9/2022 Page 1 of 2
Sample ID: BD09628
Date Received: 10/04/2022
Time Received: 09:00
Date Finalized: 11/9/2022
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Tap Closest Storage Tank

4th QTR

Collect Date: 10/04/2022
Collect Time: 08:00
Collected by: BILL SANSONE
Receipt Temp: 9.0 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanoic acid (PFOA)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropetanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
6:2 Fluorotelomersulfonic acid (6:2FTSA)	3.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorooctanesulfonic acid (PFOS)	<1.9	10		ng/L	EPA 533	SUB*	10/31/2022
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Hexafluoropropylene oxide dimer acid (HF	<1.9			ng/L	EPA 533	SUB*	10/31/2022
4,8-dioxa-3H-perfluorononanoic acid (ADO	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Nonafluoro-3,6-dioxaheptanoic acid (NFDH	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanoic acid (PFBA)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
Perfluoropentanoic acid (PFPeA)	2.4			ng/L	EPA 533	SUB*	10/31/2022
Perfluorohexanoic acid (PFHxA)	2.4			ng/L	EPA 533	SUB*	10/31/2022
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	10/31/2022
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	10/31/2022