

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 5/9/2023

Page 1 of 2

Sample ID: BE03061

Date Received: 04/18/2023

Time Received: 08:00

Date Finalized: 5/9/2023

PO Number:

Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Between GAC 1 & 2

Collect Date: 04/18/2023
Collect Time: 07:05
Collected by: BILL SANSONE
Receipt Temp: 9.7 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoroheptanoic acid (PFHpA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluorooctanoic acid (PFOA)	<0.463	10		ng/L	EPA 533	SUB*	4/29/2023
Perfluorooctanesulfonic acid (PFOS)	<0.463	10		ng/L	EPA 533	SUB*	4/29/2023
Perfluorononanoic acid (PFNA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<0.926			ng/L	EPA 533	SUB*	4/29/2023
Perfluoroundecanoic acid (PFUnA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoro-5-oxahexanoic acid (PFMBA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Hexafluoropropylene oxide dimer acid (HF)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<0.926			ng/L	EPA 533	SUB*	4/29/2023
Perfluorodecanoic acid (PFDA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluorododecanoic acid (PFDoA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoro(2-ethoxyethane)sulfonic acid (<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoroheptanesulfonic acid (PFHpS)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluorohexanesulfonic acid (PFHxS)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoro-4-oxapentanoic acid (PFMPA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoropentanesulfonic acid (PFPeS)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluorobutanoic acid (PFBA)	2.62			ng/L	EPA 533	SUB*	4/29/2023
Perfluorobutanesulfonic acid (PFBS)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
Perfluoropentanoic acid (PFPeA)	0.841			ng/L	EPA 533	SUB*	4/29/2023
Perfluorohexanoic acid (PFHxA)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
11CI-PF3OUds (F53B Minor)	<0.463			ng/L	EPA 533	SUB*	4/29/2023
9CI-PF3ONS (F53B Major)	<0.463			ng/L	EPA 533	SUB*	4/29/2023

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 5/9/2023 Page 2 of 2

Sample ID: BE03061
Date Received: 04/18/2023
Time Received: 08:00
Date Finalized: 5/9/2023
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Between GAC 1 & 2

Collect Date: 04/18/2023
Collect Time: 07:05
Collected by: BILL SANSONE
Receipt Temp: 9.7 C On Ice Chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- blank
- C(+/-) CCV outside acceptance limits received
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- H Hold time exceeded
- B Analyte detected in
- G Incorrect bottle received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported


MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #12058. Samples were prepared on 04/28/23.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
8:2FTS and 6:2FTS - <0.926
All other analytes - <0.463
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted . If you have any questions, please call the laboratory.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.

Reviewed by Brian Collins
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.