

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
AMS-01-BF-P-01	Main Office Restroom	Bathroom Faucet	4/30/2021 06:09	5/12/2021 22:59	70171418001	Lead	<1.0	15	ug/L	
AMS-01-SF-P-02	Main Office	Sink Faucet	4/30/2021 06:09	5/12/2021 23:00	70171418002	Lead	<1.0	15	ug/L	
AMS-01-BF-P-04	Main Corridor Men's - L	Bathroom Faucet	4/30/2021 06:08	5/12/2021 23:01	70171418003	Lead	11.0	15	ug/L	
AMS-01-BF-P-05	Main Corridor Men's - R	Bathroom Faucet	4/30/2021 06:08	5/12/2021 23:02	70171418004	Lead	<1.0	15	ug/L	
AMS-01-BF-P-06	Main Corridor Women's - L	Bathroom Faucet	4/30/2021 06:07	5/12/2021 23:03	70171418005	Lead	<1.0	15	ug/L	
AMS-01-BF-P-07	Main Corridor Women's - R	Bathroom Faucet	4/30/2021 06:07	5/12/2021 23:04	70171418006	Lead	<1.0	15	ug/L	
AMS-01-SF-P-08	Library Office Area - 411	Sink Faucet	4/30/2021 06:06	5/12/2021 23:09	70171418007	Lead	<1.0	15	ug/L	
AMS-01-BF-P-09	Nurse's Bathroom	Bathroom Faucet	4/30/2021 06:05	5/12/2021 23:10	70171418008	Lead	<1.0	15	ug/L	
AMS-01-SF-P-10	Nurse's Office - Main Room	Sink Faucet	4/30/2021 06:05	5/12/2021 23:11	70171418009	Lead	<1.0	15	ug/L	
AMS-01-SF-P-11	Nurse's Office - Exam Room	Sink Faucet	4/30/2021 06:05	5/12/2021 23:12	70171418010	Lead	1.7	15	ug/L	
AMS-01-IM-P-12	Nurse's Office	Ice Machine	4/30/2021 06:00	5/12/2021 23:13	70171418011	Lead	<1.0	15	ug/L	
AMS-01-CF-P-17	PFA2 - Center - L	Classroom Faucet	4/30/2021 06:00	5/12/2021 23:14	70171418012	Lead	13.1	15	ug/L	
AMS-01-CF-P-18	PFA2 - Center - R	Classroom Faucet	4/30/2021 06:00	5/12/2021 23:15	70171418013	Lead	25.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
AMS-01-CF-P-19	PFA2 - South Side - L	Classroom Faucet	4/30/2021 06:00	5/12/2021 23:16	70171418014	Lead	<1.0	15	ug/L	
AMS-01-CF-P-20	PFA2 - South Side - R	Classroom Faucet	4/30/2021 06:00	5/12/2021 23:18	70171418015	Lead	<1.0	15	ug/L	
AMS-01-BF-P-21	PFA Girl's Restroom - L	Bathroom Faucet	4/30/2021 05:58	5/12/2021 23:21	70171418016	Lead	<1.0	15	ug/L	
AMS-01-BF-P-22	PFA Girl's Restroom - R	Bathroom Faucet	4/30/2021 05:58	5/12/2021 23:24	70171418017	Lead	<1.0	15	ug/L	
AMS-01-BF-P-23	PFA Boy's Restroom - L	Bathroom Faucet	4/30/2021 05:58	5/12/2021 23:25	70171418018	Lead	<1.0	15	ug/L	
AMS-01-BF-P-24	PFA Boy's Restroom - R	Bathroom Faucet	4/30/2021 05:58	5/12/2021 23:26	70171418019	Lead	<1.0	15	ug/L	
AMS-01-SF-P-25	315	Sink Faucet	4/30/2021 05:57	5/12/2021 23:27	70171418020	Lead	<1.0	15	ug/L	
AMS-01-BF-P-26	Left Restroom Off 315	Bathroom Faucet	4/30/2021 05:53	5/12/2021 23:30	70171418021	Lead	1.0	15	ug/L	
AMS-01-BF-P-27	Right Restroom Off 315	Bathroom Faucet	4/30/2021 05:53	5/12/2021 23:31	70171418022	Lead	1.9	15	ug/L	
AMS-01-KF-P-28	Kitchen - Food Prep - Center	Kitchen Faucet	4/30/2021 05:54	5/12/2021 23:32	70171418023	Lead	<1.0	15	ug/L	
AMS-01-KF-P-29	Kitchen - Kettle	Kitchen Faucet	4/30/2021 05:54	5/12/2021 23:33	70171418024	Lead	34.3	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
AMS-01-SF-P-36	402	Sink Faucet	4/30/2021 06:10	5/12/2021 23:34	70171418025	Lead	<1.0	15	ug/L	
AMS-01-SF-P-39	Concession by New Gym	Sink Faucet	4/30/2021 06:12	5/12/2021 23:35	70171418026	Lead	<1.0	15	ug/L	
AMS-01-BF-P-41	Boy's Coaches Office	Bathroom Faucet	4/30/2021 06:12	5/12/2021 23:38	70171418027	Lead	4.0	15	ug/L	
AMS-01-BF-P-42	Girl's Coaches Office	Bathroom Faucet	4/30/2021 06:12	5/12/2021 23:38	70171418028	Lead	586	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
AMS-01-CF-P-43	405/TCA Office	Sink Faucet	4/30/2021 06:13	5/12/2021 23:41	70171418029	Lead	2.1	15	ug/L	
AMS-01-CF-P-45	M4 (M2A on Map) - Music/Orchestra	Classroom Faucet	4/30/2021 06:15	5/12/2021 23:42	70171418030	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
AMS-01-CF-P-46	M3 - Music/Orchestra	Classroom Faucet	4/30/2021 06:15	5/12/2021 23:43	70171418031	Lead	<1.0	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb