



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (D)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-01	Copper	EPA 200.8	795	2.00	ug/L	1300	AMS-01-BF-P-01	10/20/16 04:52	11/23/16 18:58
N042137-02	Copper	EPA 200.8	589	2.00	ug/L	1300	AMS-01-SF-P-02	10/20/16 04:52	11/23/16 19:00
N042137-03	Copper	EPA 200.8	2100	2.00	ug/L	1300	AMS-01-DW-P-03	10/20/16 04:54	11/23/16 19:11
N042137-04	Copper	EPA 200.8	620	2.00	ug/L	1300	AMS-01-BF-P-04	10/20/16 04:56	11/23/16 19:13
N042137-05	Copper	EPA 200.8	711	2.00	ug/L	1300	AMS-01-BF-P-05	10/20/16 04:56	11/23/16 19:16
N042137-06	Copper	EPA 200.8	588	2.00	ug/L	1300	AMS-01-BF-P-06	10/20/16 04:55	11/23/16 19:18
N042137-07	Copper	EPA 200.8	565	2.00	ug/L	1300	AMS-01-BF-P-07	10/20/16 04:55	11/23/16 19:20
N042137-08	Copper	EPA 200.8	798	2.00	ug/L	1300	AMS-01-SF-P-08	10/20/16 04:57	11/23/16 19:22
N042137-09	Copper	EPA 200.8	648	2.00	ug/L	1300	AMS-01-BF-P-09	10/20/16 04:59	11/23/16 19:25
N042137-10	Copper	EPA 200.8	550	2.00	ug/L	1300	AMS-01-BF-P-10	10/20/16 04:59	11/23/16 19:27
N042137-11	Copper	EPA 200.8	536	2.00	ug/L	1300	AMS-01-BF-P-11	10/20/16 04:59	11/23/16 19:29
N042137-12	Copper	EPA 200.8	952	2.00	ug/L	1300	AMS-01-BF-P-12	10/20/16 04:59	11/23/16 19:31
N042137-13	Copper	EPA 200.8	940	2.00	ug/L	1300	AMS-01-BF-P-13	10/20/16 04:59	11/23/16 19:45
N042137-14	Copper	EPA 200.8	818	2.00	ug/L	1300	AMS-01-BF-P-14	10/20/16 04:59	11/23/16 19:47
N042137-15	Copper	EPA 200.8	520	2.00	ug/L	1300	AMS-01-BF-P-15	10/20/16 05:01	11/23/16 19:49
N042137-16	Copper	EPA 200.8	758	2.00	ug/L	1300	AMS-01-NF-P-16	10/20/16 05:01	11/23/16 19:52
N042137-17	Copper	EPA 200.8	542	2.00	ug/L	1300	AMS-01-BF-P-17	10/20/16 05:01	11/23/16 19:54
N042137-18	Copper	EPA 200.8	17.9	2.00	ug/L	1300	AMS-01-IM-P-18	10/20/16 05:01	11/23/16 19:56
N042137-19	Copper	EPA 200.8	802	2.00	ug/L	1300	AMS-01-DW-P-19	10/20/16 05:05	11/23/16 19:58
N042137-20	Copper	EPA 200.8	607	2.00	ug/L	1300	AMS-01-SF-P-20	10/20/16 05:05	11/23/16 20:01
N042137-21	Copper	EPA 200.8	606	2.00	ug/L	1300	AMS-01-SF-P-21	10/20/16 04:52	11/23/16 20:03
N042137-22	Copper	EPA 200.8	582	2.00	ug/L	1300	AMS-01-SF-P-22	10/20/16 05:05	11/23/16 20:05
N042137-23	Copper	EPA 200.8	625	2.00	ug/L	1300	AMS-01-DW-P-23	10/20/16 05:05	11/23/16 20:16
N042137-24	Copper	EPA 200.8	447	2.00	ug/L	1300	AMS-01-CF-P-24	10/20/16 05:08	11/23/16 20:19
N042137-25	Copper	EPA 200.8	849	2.00	ug/L	1300	AMS-01-CF-P-25	10/20/16 05:08	11/23/16 20:21
N042137-26	Copper	EPA 200.8	892	2.00	ug/L	1300	AMS-01-CF-P-26	10/20/16 05:08	11/23/16 20:23
N042137-27	Copper	EPA 200.8	909	2.00	ug/L	1300	AMS-01-CF-P-27	10/20/16 05:08	11/23/16 20:25
N042137-28	Copper	EPA 200.8	1030	2.00	ug/L	1300	AMS-01-CF-P-28	10/20/16 05:08	11/23/16 20:28
N042137-29	Copper	EPA 200.8	945	2.00	ug/L	1300	AMS-01-CF-P-29	10/20/16 05:09	11/23/16 20:30
N042137-30	Copper	EPA 200.8	1100	2.00	ug/L	1300	AMS-01-CF-P-30	10/20/16 05:12	11/23/16 20:32
N042137-31	Copper	EPA 200.8	651	2.00	ug/L	1300	AMS-01-CF-P-31	10/20/16 05:12	11/23/16 20:37
N042137-32	Copper	EPA 200.8	485	2.00	ug/L	1300	AMS-01-CF-P-32	10/20/16 05:12	11/23/16 20:39



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (n)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-33	Copper	EPA 200.8	419	2.00	ug/L	1300	AMS-01-CF-P-33	10/20/16 05:12	11/23/16 20:50
N042137-34	Copper	EPA 200.8	456	2.00	ug/L	1300	AMS-01-CF-P-34	10/20/16 05:12	11/23/16 20:53
N042137-35	Copper	EPA 200.8	1240	2.00	ug/L	1300	AMS-01-CF-P-35	10/20/16 05:16	11/23/16 20:55
N042137-36	Copper	EPA 200.8	491	2.00	ug/L	1300	AMS-01-CF-P-36	10/20/16 05:16	11/23/16 20:57
N042137-37	Copper	EPA 200.8	609	2.00	ug/L	1300	AMS-01-CF-P-37	10/20/16 05:16	11/23/16 20:59
N042137-38	Copper	EPA 200.8	766	2.00	ug/L	1300	AMS-01-CF-P-38	10/20/16 05:16	11/23/16 21:02
N042137-39	Copper	EPA 200.8	746	2.00	ug/L	1300	AMS-01-CF-P-39	10/20/16 05:16	11/23/16 21:04
N042137-40	Copper	EPA 200.8	611	2.00	ug/L	1300	AMS-01-BF-P-40	10/20/16 05:18	11/23/16 21:06
N042137-41	Copper	EPA 200.8	399	2.00	ug/L	1300	AMS-01-BF-P-41	10/20/16 05:18	11/23/16 21:08
N042137-42	Copper	EPA 200.8	523	2.00	ug/L	1300	AMS-01-BF-P-42	10/20/16 05:19	11/23/16 21:11
N042137-43	Copper	EPA 200.8	896	2.00	ug/L	1300	AMS-01-BF-P-43	10/20/16 05:19	11/23/16 21:22
N042137-44	Copper	EPA 200.8	638	2.00	ug/L	1300	AMS-01-CF-P-44	10/20/16 05:20	11/23/16 21:24
N042137-48	Copper	EPA 200.8	653	2.00	ug/L	1300	AMS-01-CF-P-48	10/20/16 04:52	11/23/16 21:27
N042137-50	Copper	EPA 200.8	1000	2.00	ug/L	1300	AMS-01-CF-P-50	10/20/16 05:22	11/23/16 21:29
N042137-51	Copper	EPA 200.8	646	2.00	ug/L	1300	AMS-01-CF-P-51	10/20/16 05:25	11/23/16 21:33
N042137-52	Copper	EPA 200.8	282	2.00	ug/L	1300	AMS-01-BF-P-52	10/20/16 05:27	11/23/16 21:36
N042137-53	Copper	EPA 200.8	970	2.00	ug/L	1300	AMS-01-BF-P-53	10/20/16 05:27	11/23/16 21:38
N042137-54	Copper	EPA 200.8	632	2.00	ug/L	1300	AMS-01-KF-P-54	10/20/16 05:28	11/23/16 21:40
N042137-55	Copper	EPA 200.8	506	2.00	ug/L	1300	AMS-01-KF-P-55	10/20/16 05:28	11/23/16 21:42
N042137-56	Copper	EPA 200.8	488	2.00	ug/L	1300	AMS-01-KF-P-56	10/20/16 05:28	11/23/16 21:45
N042137-57	Copper	EPA 200.8	672	2.00	ug/L	1300	AMS-01-KF-P-57	10/20/16 05:28	11/23/16 21:56
N042137-58	Copper	EPA 200.8	267	2.00	ug/L	1300	AMS-01-KF-P-58	10/20/16 05:28	11/23/16 21:58
N042137-59	Copper	EPA 200.8	708	2.00	ug/L	1300	AMS-01-CF-P-59	10/20/16 05:32	11/29/16 15:40
N042137-60	Copper	EPA 200.8	272	2.00	ug/L	1300	AMS-01-DW-P-60	10/20/16 05:36	11/29/16 15:43
N042137-61	Copper	EPA 200.8	865	2.00	ug/L	1300	AMS-01-SF-P-61	10/20/16 05:36	11/29/16 15:45
N042137-62	Copper	EPA 200.8	765	2.00	ug/L	1300	AMS-01-CF-P-62	10/20/16 05:40	11/29/16 15:48
N042137-63	Copper	EPA 200.8	893	2.00	ug/L	1300	AMS-01-CF-P-63	10/20/16 05:40	11/29/16 15:50
N042137-64	Copper	EPA 200.8	1150	2.00	ug/L	1300	AMS-01-CF-P-64	10/20/16 05:40	11/29/16 15:53
N042137-65	Copper	EPA 200.8	1100	2.00	ug/L	1300	AMS-01-CF-P-65	10/20/16 05:40	11/29/16 15:56
N042137-66	Copper	EPA 200.8	877	2.00	ug/L	1300	AMS-01-CF-P-66	10/20/16 05:40	11/29/16 15:59
N042137-67	Copper	EPA 200.8	750	2.00	ug/L	1300	AMS-01-CF-P-67	10/20/16 05:40	11/29/16 16:01
N042137-68	Copper	EPA 200.8	696	2.00	ug/L	1300	AMS-01-CF-P-68	10/20/16 05:40	11/29/16 16:04

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00


Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-69	Copper	EPA 200.8	3060	4.00	ug/L	1300	AMS-01-CF-P-69	10/20/16 05:40	12/5/16 19:21
N042137-71	Copper	EPA 200.8	761	2.00	ug/L	1300	AMS-01-SF-P-71	10/20/16 05:43	11/29/16 16:19
N042137-72	Copper	EPA 200.8	1020	2.00	ug/L	1300	AMS-01-CF-P-72	10/20/16 05:45	11/29/16 16:21
N042137-73	Copper	EPA 200.8	862	2.00	ug/L	1300	AMS-01-CF-P-73	10/20/16 05:45	11/29/16 16:24
N042137-74	Copper	EPA 200.8	1210	2.00	ug/L	1300	AMS-01-CF-P-74	10/20/16 05:45	11/29/16 16:27
N042137-75	Copper	EPA 200.8	1360	4.00	ug/L	1300	AMS-01-CF-P-75	10/20/16 05:45	12/5/16 19:24
N042137-76	Copper	EPA 200.8	1050	2.00	ug/L	1300	AMS-01-CF-P-76	10/20/16 05:45	11/29/16 16:32
N042137-77	Copper	EPA 200.8	889	2.00	ug/L	1300	AMS-01-CF-P-77	10/20/16 05:45	11/29/16 16:35
N042137-78	Copper	EPA 200.8	712	2.00	ug/L	1300	AMS-01-CF-P-78	10/20/16 05:45	11/29/16 16:40
N042137-82	Copper	EPA 200.8	497	2.00	ug/L	1300	AMS-01-CF-P-82	10/20/16 05:40	11/29/16 16:43
N042137-83	Copper	EPA 200.8	1040	2.00	ug/L	1300	AMS-01-CF-P-83	10/20/16 05:40	11/29/16 18:27
N042137-84	Copper	EPA 200.8	1060	2.00	ug/L	1300	AMS-01-CF-P-84	10/20/16 05:40	11/29/16 18:30
N042137-85	Copper	EPA 200.8	1190	2.00	ug/L	1300	AMS-01-CF-P-85	10/20/16 05:40	11/29/16 18:33
N042137-86	Copper	EPA 200.8	1490	4.00	ug/L	1300	AMS-01-CF-P-86	10/20/16 05:40	12/5/16 19:26
N042137-87	Copper	EPA 200.8	1420	4.00	ug/L	1300	AMS-01-CF-P-87	10/20/16 05:40	12/5/16 19:28
N042137-88	Copper	EPA 200.8	1210	2.00	ug/L	1300	AMS-01-CF-P-88	10/20/16 05:40	11/29/16 18:41
N042137-89	Copper	EPA 200.8	1070	2.00	ug/L	1300	AMS-01-CF-P-89	10/20/16 05:40	11/29/16 18:44
N042137-90	Copper	EPA 200.8	1030	2.00	ug/L	1300	AMS-01-SF-P-90	10/20/16 05:37	11/29/16 18:46
N042137-91	Copper	EPA 200.8	9490	200	ug/L	1300	AMS-01-CF-P-91	10/20/16 05:34	12/7/16 12:47
N042137-93	Copper	EPA 200.8	7000	4.00	ug/L	1300	AMS-01-CF-P-93	10/20/16 05:34	12/5/16 19:30
N042137-94	Copper	EPA 200.8	1470	4.00	ug/L	1300	AMS-01-CF-P-94	10/20/16 05:34	12/5/16 19:32
N042137-95	Copper	EPA 200.8	1020	2.00	ug/L	1300	AMS-01-CF-P-95	10/20/16 05:34	11/29/16 19:04
N042137-96	Copper	EPA 200.8	1360	4.00	ug/L	1300	AMS-01-CF-P-96	10/20/16 05:34	12/5/16 19:35
N042137-97	Copper	EPA 200.8	1700	4.00	ug/L	1300	AMS-01-CF-P-97	10/20/16 05:34	12/5/16 19:37
N042137-98	Copper	EPA 200.8	947	2.00	ug/L	1300	AMS-01-CF-P-98	10/20/16 05:34	11/29/16 19:13
N042137-99	Copper	EPA 200.8	926	2.00	ug/L	1300	AMS-01-CF-P-99	10/20/16 05:34	11/29/16 19:15
N042137-AA	Copper	EPA 200.8	513	2.00	ug/L	1300	AMS-01-BF-P-100	10/20/16 05:31	11/29/16 19:18
N042137-AB	Copper	EPA 200.8	539	2.00	ug/L	1300	AMS-01-BF-P-101	10/20/16 05:31	11/29/16 19:21
N042137-AC	Copper	EPA 200.8	555	2.00	ug/L	1300	AMS-01-BF-P-102	10/20/16 05:31	11/29/16 19:23
N042137-AD	Copper	EPA 200.8	898	2.00	ug/L	1300	AMS-01-BF-P-103	10/20/16 05:30	11/29/16 19:28
N042137-AE	Copper	EPA 200.8	833	2.00	ug/L	1300	AMS-01-DW-P-104	10/20/16 05:30	11/29/16 19:31
N042137-AG	Copper	EPA 200.8	534	2.00	ug/L	1300	AMS-01-BF-P-106	10/20/16 05:28	11/29/16 19:43

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (P)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-AH	Copper	EPA 200.8	569	2.00	ug/L	1300	AMS-01-BF-P-107	10/20/16 05:28	11/29/16 19:45
N042137-AL	Copper	EPA 200.8	713	2.00	ug/L	1300	AMS-01-CF-P-111	10/20/16 05:24	11/29/16 19:48
N042137-AM	Copper	EPA 200.8	840	2.00	ug/L	1300	AMS-01-CF-P-112	10/20/16 05:24	11/29/16 19:50
N042137-AN	Copper	EPA 200.8	781	2.00	ug/L	1300	AMS-01-CF-P-113	10/20/16 05:24	11/29/16 19:53
N042137-AO	Copper	EPA 200.8	959	2.00	ug/L	1300	AMS-01-CF-P-114	10/20/16 05:24	11/29/16 19:56
N042137-AP	Copper	EPA 200.8	957	2.00	ug/L	1300	AMS-01-CF-P-115	10/20/16 05:24	11/29/16 19:58
N042137-AQ	Copper	EPA 200.8	817	2.00	ug/L	1300	AMS-01-CF-P-116	10/20/16 05:24	11/29/16 20:01
N042137-AR	Copper	EPA 200.8	842	2.00	ug/L	1300	AMS-01-CF-P-117	10/20/16 05:24	11/29/16 20:04
N042137-AS	Copper	EPA 200.8	923	2.00	ug/L	1300	AMS-01-CF-P-118	10/20/16 05:23	11/29/16 20:07
N042137-AT	Copper	EPA 200.8	703	2.00	ug/L	1300	AMS-01-CF-P-119	10/20/16 05:21	11/30/16 13:28
N042137-AU	Copper	EPA 200.8	53.4	2.00	ug/L	1300	AMS-01-CF-P-120	10/20/16 05:21	11/30/16 13:31
N042137-AV	Copper	EPA 200.8	868	2.00	ug/L	1300	AMS-01-CF-P-121	10/20/16 05:21	11/30/16 13:33
N042137-AW	Copper	EPA 200.8	882	2.00	ug/L	1300	AMS-01-CF-P-122	10/20/16 05:21	11/30/16 13:36
N042137-AX	Copper	EPA 200.8	898	2.00	ug/L	1300	AMS-01-CF-P-123	10/20/16 05:21	11/30/16 13:39
N042137-AY	Copper	EPA 200.8	900	2.00	ug/L	1300	AMS-01-CF-P-124	10/20/16 05:21	11/30/16 13:41
N042137-AZ	Copper	EPA 200.8	1010	2.00	ug/L	1300	AMS-01-CF-P-125	10/20/16 05:21	11/30/16 13:44
N042137-BA	Copper	EPA 200.8	888	2.00	ug/L	1300	AMS-01-CF-P-126	10/20/16 05:21	11/30/16 13:47
N042137-BB	Copper	EPA 200.8	757	2.00	ug/L	1300	AMS-01-CF-P-127	10/20/16 05:21	11/30/16 13:50
N042137-BC	Copper	EPA 200.8	560	2.00	ug/L	1300	AMS-01-DW-P-128	10/20/16 05:16	11/30/16 13:52
N042137-BD	Copper	EPA 200.8	827	2.00	ug/L	1300	AMS-01-SF-P-129	10/20/16 05:16	11/30/16 14:04
N042137-BE	Copper	EPA 200.8	1030	2.00	ug/L	1300	AMS-01-DW-P-130	10/20/16 05:14	11/30/16 14:07
N042137-BF	Copper	EPA 200.8	1050	2.00	ug/L	1300	AMS-01-DW-P-131	10/20/16 05:14	11/30/16 14:10
N042137-BG	Copper	EPA 200.8	831	2.00	ug/L	1300	AMS-01-SF-P-132	10/20/16 05:13	11/30/16 14:13
N042137-BH	Copper	EPA 200.8	21.8	2.00	ug/L	1300	AMS-01-IM-P-133	10/20/16 05:13	11/30/16 14:15
N042137-BI	Copper	EPA 200.8	1120	2.00	ug/L	1300	AMS-01-SF-P-134	10/20/16 05:10	11/30/16 14:18
N042137-BJ	Copper	EPA 200.8	1190	2.00	ug/L	1300	AMS-01-CF-P-135	10/20/16 05:10	11/30/16 14:21
N042137-BK	Copper	EPA 200.8	1160	2.00	ug/L	1300	AMS-01-SF-P-136	10/20/16 05:10	11/30/16 14:23
N042137-BL	Copper	EPA 200.8	499	2.00	ug/L	1300	AMS-01-BF-P-137	10/20/16 05:08	11/30/16 14:28
N042137-BM	Copper	EPA 200.8	1150	2.00	ug/L	1300	AMS-01-BF-P-138	10/20/16 05:08	11/30/16 14:31
N042137-BN	Copper	EPA 200.8	953	2.00	ug/L	1300	AMS-01-CF-P-139	10/20/16 05:08	11/30/16 14:43
N042137-BO	Copper	EPA 200.8	588	2.00	ug/L	1300	AMS-01-BF-P-140	10/20/16 05:06	11/30/16 14:46
N042137-BP	Copper	EPA 200.8	617	2.00	ug/L	1300	AMS-01-BF-P-141	10/20/16 05:08	11/30/16 14:48

New Jersey Analytical Laboratories

The
cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-BQ	Copper	EPA 200.8	613	2.00	ug/L	1300	AMS-01-BF-P-142	10/20/16 05:08	11/30/16 14:51
N042137-BR	Copper	EPA 200.8	710	2.00	ug/L	1300	AMS-01-BF-P-143	10/20/16 05:05	11/30/16 14:53
N042137-BS	Copper	EPA 200.8	943	2.00	ug/L	1300	AMS-01-BF-P-144	10/20/16 05:05	11/30/16 14:56
N042137-BT	Copper	EPA 200.8	966	2.00	ug/L	1300	AMS-01-BF-P-145	10/20/16 05:05	11/30/16 14:58
N042137-BU	Copper	EPA 200.8	605	2.00	ug/L	1300	AMS-01-BF-P-146	10/20/16 05:03	11/30/16 15:01
N042137-BV	Copper	EPA 200.8	999	2.00	ug/L	1300	AMS-01-BF-P-147	10/20/16 05:02	11/30/16 15:03
N042137-BW	Copper	EPA 200.8	1260	2.00	ug/L	1300	AMS-01-BF-P-148	10/20/16 05:02	11/30/16 15:06
N042137-BX	Copper	EPA 200.8	906	2.00	ug/L	1300	AMS-01-BF-P-149	10/20/16 05:02	11/30/16 15:19
N042137-BZ	Copper	EPA 200.8	635	2.00	ug/L	1300	AMS-01-BF-P-151	10/20/16 05:00	11/30/16 15:21
N042137-CA	Copper	EPA 200.8	622	2.00	ug/L	1300	AMS-01-BF-P-152	10/20/16 05:00	11/30/16 15:24
N042137-CC	Copper	EPA 200.8	718	2.00	ug/L	1300	AMS-01-DW-P-154	10/20/16 04:59	11/30/16 15:26
N042137-CE	Copper	EPA 200.8	1020	2.00	ug/L	1300	AMS-01-BF-P-156	10/20/16 04:57	11/30/16 15:31
N042137-CF	Copper	EPA 200.8	978	2.00	ug/L	1300	AMS-01-BF-P-157	10/20/16 04:57	11/30/16 15:34
N042137-CG	Copper	EPA 200.8	923	2.00	ug/L	1300	AMS-01-CF-P-158	10/20/16 04:55	11/30/16 15:36
N042137-CH	Copper	EPA 200.8	779	2.00	ug/L	1300	AMS-01-CF-P-159	10/20/16 04:54	11/30/16 15:39
N042137-CI	Copper	EPA 200.8	562	2.00	ug/L	1300	AMS-01-DW-P-160	10/20/16 04:51	11/30/16 15:42


Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-01	Lead	EPA 200.8	0.66	0.50	ug/L	15	AMS-01-BF-P-01	10/20/16 04:52	11/23/16 18:58
N042137-02	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-SF-P-02	10/20/16 04:52	11/23/16 19:00
N042137-03	Lead	EPA 200.8	0.52	0.50	ug/L	15	AMS-01-DW-P-03	10/20/16 04:54	11/23/16 19:11
N042137-04	Lead	EPA 200.8	1.07	0.50	ug/L	15	AMS-01-BF-P-04	10/20/16 04:56	11/23/16 19:13
N042137-05	Lead	EPA 200.8	1.12	0.50	ug/L	15	AMS-01-BF-P-05	10/20/16 04:56	11/23/16 19:16
N042137-06	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-BF-P-06	10/20/16 04:55	11/23/16 19:18
N042137-07	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-BF-P-07	10/20/16 04:55	11/23/16 19:20
N042137-08	Lead	EPA 200.8	1.15	0.50	ug/L	15	AMS-01-SF-P-08	10/20/16 04:57	11/23/16 19:22
N042137-09	Lead	EPA 200.8	3.05	0.50	ug/L	15	AMS-01-BF-P-09	10/20/16 04:59	11/23/16 19:25
N042137-10	Lead	EPA 200.8	1.55	0.50	ug/L	15	AMS-01-BF-P-10	10/20/16 04:59	11/23/16 19:27
N042137-11	Lead	EPA 200.8	1.41	0.50	ug/L	15	AMS-01-BF-P-11	10/20/16 04:59	11/23/16 19:29
N042137-12	Lead	EPA 200.8	0.68	0.50	ug/L	15	AMS-01-BF-P-12	10/20/16 04:59	11/23/16 19:31
N042137-13	Lead	EPA 200.8	0.51	0.50	ug/L	15	AMS-01-BF-P-13	10/20/16 04:59	11/23/16 19:45
N042137-14	Lead	EPA 200.8	0.57	0.50	ug/L	15	AMS-01-BF-P-14	10/20/16 04:59	11/23/16 19:47
N042137-15	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-BF-P-15	10/20/16 05:01	11/23/16 19:49

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (P)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00


Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-16	Lead	EPA 200.8	0.70	0.50	ug/L	15	AMS-01-NF-P-16	10/20/16 05:01	11/23/16 19:52
N042137-17	Lead	EPA 200.8	5.66	0.50	ug/L	15	AMS-01-BF-P-17	10/20/16 05:01	11/23/16 19:54
N042137-18	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-IM-P-18	10/20/16 05:01	11/23/16 19:56
N042137-19	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-19	10/20/16 05:05	11/23/16 19:58
N042137-20	Lead	EPA 200.8	1.06	0.50	ug/L	15	AMS-01-SF-P-20	10/20/16 05:05	11/23/16 20:01
N042137-21	Lead	EPA 200.8	1.13	0.50	ug/L	15	AMS-01-SF-P-21	10/20/16 04:52	11/23/16 20:03
N042137-22	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-SF-P-22	10/20/16 05:05	11/23/16 20:05
N042137-23	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-23	10/20/16 05:05	11/23/16 20:16
N042137-24	Lead	EPA 200.8	1.17	0.50	ug/L	15	AMS-01-CF-P-24	10/20/16 05:08	11/23/16 20:19
N042137-25	Lead	EPA 200.8	0.66	0.50	ug/L	15	AMS-01-CF-P-25	10/20/16 05:08	11/23/16 20:21
N042137-26	Lead	EPA 200.8	1.69	0.50	ug/L	15	AMS-01-CF-P-26	10/20/16 05:08	11/23/16 20:23
N042137-27	Lead	EPA 200.8	0.96	0.50	ug/L	15	AMS-01-CF-P-27	10/20/16 05:08	11/23/16 20:25
N042137-28	Lead	EPA 200.8	0.66	0.50	ug/L	15	AMS-01-CF-P-28	10/20/16 05:08	11/23/16 20:28
N042137-29	Lead	EPA 200.8	1.10	0.50	ug/L	15	AMS-01-CF-P-29	10/20/16 05:09	11/23/16 20:30
N042137-30	Lead	EPA 200.8	2.33	0.50	ug/L	15	AMS-01-CF-P-30	10/20/16 05:12	11/23/16 20:32
N042137-31	Lead	EPA 200.8	1.40	0.50	ug/L	15	AMS-01-CF-P-31	10/20/16 05:12	11/23/16 20:37
N042137-32	Lead	EPA 200.8	2.75	0.50	ug/L	15	AMS-01-CF-P-32	10/20/16 05:12	11/23/16 20:39
N042137-33	Lead	EPA 200.8	1.11	0.50	ug/L	15	AMS-01-CF-P-33	10/20/16 05:12	11/23/16 20:50
N042137-34	Lead	EPA 200.8	1.06	0.50	ug/L	15	AMS-01-CF-P-34	10/20/16 05:12	11/23/16 20:53
N042137-35	Lead	EPA 200.8	4.14	0.50	ug/L	15	AMS-01-CF-P-35	10/20/16 05:16	11/23/16 20:55
N042137-36	Lead	EPA 200.8	0.69	0.50	ug/L	15	AMS-01-CF-P-36	10/20/16 05:16	11/23/16 20:57
N042137-37	Lead	EPA 200.8	0.70	0.50	ug/L	15	AMS-01-CF-P-37	10/20/16 05:16	11/23/16 20:59
N042137-38	Lead	EPA 200.8	13.1	0.50	ug/L	15	AMS-01-CF-P-38	10/20/16 05:16	11/23/16 21:02
N042137-39	Lead	EPA 200.8	1.39	0.50	ug/L	15	AMS-01-CF-P-39	10/20/16 05:16	11/23/16 21:04
N042137-40	Lead	EPA 200.8	0.52	0.50	ug/L	15	AMS-01-BF-P-40	10/20/16 05:18	11/23/16 21:06
N042137-41	Lead	EPA 200.8	0.99	0.50	ug/L	15	AMS-01-BF-P-41	10/20/16 05:18	11/23/16 21:08
N042137-42	Lead	EPA 200.8	0.76	0.50	ug/L	15	AMS-01-BF-P-42	10/20/16 05:19	11/23/16 21:11
N042137-43	Lead	EPA 200.8	4.11	0.50	ug/L	15	AMS-01-BF-P-43	10/20/16 05:19	11/23/16 21:22
N042137-44	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-44	10/20/16 05:20	11/23/16 21:24
N042137-48	Lead	EPA 200.8	1.33	0.50	ug/L	15	AMS-01-CF-P-48	10/20/16 04:52	11/23/16 21:77
N042137-50	Lead	EPA 200.8	89.6	0.50	ug/L	15	AMS-01-CF-P-50	10/20/16 05:22	11/23/16 21:29
N042137-51	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-51	10/20/16 05:25	11/23/16 21:33

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-52	Lead	EPA 200.8	2.16	0.50	ug/L	15	AMS-01-BF-P-52	10/20/16 05:27	11/23/16 21:36
N042137-53	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-BF-P-53	10/20/16 05:27	11/23/16 21:38
N042137-54	Lead	EPA 200.8	13.5	0.50	ug/L	15	AMS-01-KF-P-54	10/20/16 05:28	11/23/16 21:40
N042137-55	Lead	EPA 200.8	1.72	0.50	ug/L	15	AMS-01-KF-P-55	10/20/16 05:28	11/23/16 21:42
N042137-56	Lead	EPA 200.8	2.88	0.50	ug/L	15	AMS-01-KF-P-56	10/20/16 05:28	11/23/16 21:45
N042137-57	Lead	EPA 200.8	1.36	0.50	ug/L	15	AMS-01-KF-P-57	10/20/16 05:28	11/23/16 21:56
N042137-58	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-KF-P-58	10/20/16 05:28	11/23/16 21:58
N042137-59	Lead	EPA 200.8	0.50	0.50	ug/L	15	AMS-01-CF-P-59	10/20/16 05:32	11/29/16 15:40
N042137-60	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-60	10/20/16 05:36	11/29/16 15:43
N042137-61	Lead	EPA 200.8	1.90	0.50	ug/L	15	AMS-01-SF-P-61	10/20/16 05:36	11/29/16 15:45
N042137-62	Lead	EPA 200.8	0.91	0.50	ug/L	15	AMS-01-CF-P-62	10/20/16 05:40	11/29/16 15:48
N042137-63	Lead	EPA 200.8	1.17	0.50	ug/L	15	AMS-01-CF-P-63	10/20/16 05:40	11/29/16 15:50
N042137-64	Lead	EPA 200.8	1.22	0.50	ug/L	15	AMS-01-CF-P-64	10/20/16 05:40	11/29/16 15:53
N042137-65	Lead	EPA 200.8	1.66	0.50	ug/L	15	AMS-01-CF-P-65	10/20/16 05:40	11/29/16 15:56
N042137-66	Lead	EPA 200.8	2.17	0.50	ug/L	15	AMS-01-CF-P-66	10/20/16 05:40	11/29/16 15:59
N042137-67	Lead	EPA 200.8	0.91	0.50	ug/L	15	AMS-01-CF-P-67	10/20/16 05:40	11/29/16 16:01
N042137-68	Lead	EPA 200.8	5.80	0.50	ug/L	15	AMS-01-CF-P-68	10/20/16 05:40	11/29/16 16:04
N042137-69	Lead	EPA 200.8	205	1.00	ug/L	15	AMS-01-CF-P-69	10/20/16 05:40	12/5/16 19:21
N042137-71	Lead	EPA 200.8	0.88	0.50	ug/L	15	AMS-01-SF-P-71	10/20/16 05:43	11/29/16 16:19
N042137-72	Lead	EPA 200.8	2.18	0.50	ug/L	15	AMS-01-CF-P-72	10/20/16 05:45	11/29/16 16:21
N042137-73	Lead	EPA 200.8	2.18	0.50	ug/L	15	AMS-01-CF-P-73	10/20/16 05:45	11/29/16 16:24
N042137-74	Lead	EPA 200.8	0.95	0.50	ug/L	15	AMS-01-CF-P-74	10/20/16 05:45	11/29/16 16:27
N042137-75	Lead	EPA 200.8	ND	1.00	ug/L	15	AMS-01-CF-P-75	10/20/16 05:45	12/5/16 19:24
N042137-76	Lead	EPA 200.8	0.89	0.50	ug/L	15	AMS-01-CF-P-76	10/20/16 05:45	11/29/16 16:32
N042137-77	Lead	EPA 200.8	0.85	0.50	ug/L	15	AMS-01-CF-P-77	10/20/16 05:45	11/29/16 16:35
N042137-78	Lead	EPA 200.8	1.03	0.50	ug/L	15	AMS-01-CF-P-78	10/20/16 05:45	11/29/16 16:40
N042137-82	Lead	EPA 200.8	31.2	0.50	ug/L	15	AMS-01-CF-P-82	10/20/16 05:40	11/29/16 16:43
N042137-83	Lead	EPA 200.8	2.58	0.50	ug/L	15	AMS-01-CF-P-83	10/20/16 05:40	11/29/16 18:27
N042137-84	Lead	EPA 200.8	56.3	0.50	ug/L	15	AMS-01-CF-P-84	10/20/16 05:40	11/29/16 18:30
N042137-85	Lead	EPA 200.8	2.88	0.50	ug/L	15	AMS-01-CF-P-85	10/20/16 05:40	11/29/16 18:33
N042137-86	Lead	EPA 200.8	1.26	1.00	ug/L	15	AMS-01-CF-P-86	10/20/16 05:40	12/5/16 19:26
N042137-87	Lead	EPA 200.8	3.69	1.00	ug/L	15	AMS-01-CF-P-87	10/20/16 05:40	12/5/16 19:28



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-88	Lead	EPA 200.8	0.89	0.50	ug/L	15	AMS-01-CF-P-88	10/20/16 05:40	11/29/16 18:41
N042137-89	Lead	EPA 200.8	2.78	0.50	ug/L	15	AMS-01-CF-P-89	10/20/16 05:40	11/29/16 18:44
N042137-90	Lead	EPA 200.8	0.61	0.50	ug/L	15	AMS-01-SF-P-90	10/20/16 05:37	11/29/16 18:46
N042137-91	Lead	EPA 200.8	255	0.50	ug/L	15	AMS-01-CF-P-91	10/20/16 05:34	12/6/16 12:58
N042137-93	Lead	EPA 200.8	106	1.00	ug/L	15	AMS-01-CF-P-93	10/20/16 05:34	12/5/16 19:30
N042137-94	Lead	EPA 200.8	2.10	1.00	ug/L	15	AMS-01-CF-P-94	10/20/16 05:34	12/5/16 19:32
N042137-95	Lead	EPA 200.8	0.90	0.50	ug/L	15	AMS-01-CF-P-95	10/20/16 05:34	11/29/16 19:04
N042137-96	Lead	EPA 200.8	1.63	1.00	ug/L	15	AMS-01-CF-P-96	10/20/16 05:34	12/5/16 19:35
N042137-97	Lead	EPA 200.8	1.14	1.00	ug/L	15	AMS-01-CF-P-97	10/20/16 05:34	12/5/16 19:37
N042137-98	Lead	EPA 200.8	1.56	0.50	ug/L	15	AMS-01-CF-P-98	10/20/16 05:34	11/29/16 19:13
N042137-99	Lead	EPA 200.8	1.02	0.50	ug/L	15	AMS-01-CF-P-99	10/20/16 05:34	11/29/16 19:15
N042137-AA	Lead	EPA 200.8	0.79	0.50	ug/L	15	AMS-01-BF-P-100	10/20/16 05:31	11/29/16 19:18
N042137-AB	Lead	EPA 200.8	0.91	0.50	ug/L	15	AMS-01-BF-P-101	10/20/16 05:31	11/29/16 19:21
N042137-AC	Lead	EPA 200.8	1.20	0.50	ug/L	15	AMS-01-BF-P-102	10/20/16 05:31	11/29/16 19:23
N042137-AD	Lead	EPA 200.8	2.42	0.50	ug/L	15	AMS-01-BF-P-103	10/20/16 05:30	11/29/16 19:28
N042137-AE	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-104	10/20/16 05:30	11/29/16 19:31
N042137-AG	Lead	EPA 200.8	0.82	0.50	ug/L	15	AMS-01-BF-P-106	10/20/16 05:28	11/29/16 19:43
N042137-AH	Lead	EPA 200.8	1.01	0.50	ug/L	15	AMS-01-BF-P-107	10/20/16 05:28	11/29/16 19:45
N042137-AL	Lead	EPA 200.8	1.47	0.50	ug/L	15	AMS-01-CF-P-111	10/20/16 05:24	11/29/16 19:48
N042137-AM	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-112	10/20/16 05:24	11/29/16 19:50
N042137-AN	Lead	EPA 200.8	0.50	0.50	ug/L	15	AMS-01-CF-P-113	10/20/16 05:24	11/29/16 19:53
N042137-AO	Lead	EPA 200.8	0.52	0.50	ug/L	15	AMS-01-CF-P-114	10/20/16 05:24	11/29/16 19:56
N042137-AP	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-115	10/20/16 05:24	11/29/16 19:58
N042137-AQ	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-116	10/20/16 05:24	11/29/16 20:01
N042137-AR	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-117	10/20/16 05:24	11/29/16 20:04
N042137-AS	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-118	10/20/16 05:23	11/29/16 20:07
N042137-AT	Lead	EPA 200.8	27.7	0.50	ug/L	15	AMS-01-CF-P-119	10/20/16 05:21	11/30/16 13:28
N042137-AU	Lead	EPA 200.8	30.3	0.50	ug/L	15	AMS-01-CF-P-120	10/20/16 05:21	11/30/16 13:31
N042137-AV	Lead	EPA 200.8	0.90	0.50	ug/L	15	AMS-01-CF-P-121	10/20/16 05:21	11/30/16 13:33
N042137-AW	Lead	EPA 200.8	0.72	0.50	ug/L	15	AMS-01-CF-P-122	10/20/16 05:21	11/30/16 13:36
N042137-AX	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-123	10/20/16 05:21	11/30/16 13:39
N042137-AY	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-124	10/20/16 05:21	11/30/16 13:41

New Jersey Analytical Laboratories

The
cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-AZ	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-125	10/20/16 05:21	11/30/16 13:44
N042137-BA	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-126	10/20/16 05:21	11/30/16 13:47
N042137-BB	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-127	10/20/16 05:21	11/30/16 13:50
N042137-BC	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-128	10/20/16 05:16	11/30/16 13:52
N042137-BD	Lead	EPA 200.8	1.33	0.50	ug/L	15	AMS-01-SF-P-129	10/20/16 05:16	11/30/16 14:04
N042137-BE	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-130	10/20/16 05:14	11/30/16 14:07
N042137-BF	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-131	10/20/16 05:14	11/30/16 14:10
N042137-BG	Lead	EPA 200.8	0.91	0.50	ug/L	15	AMS-01-SF-P-132	10/20/16 05:13	11/30/16 14:13
N042137-BH	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-IM-P-133	10/20/16 05:13	11/30/16 14:15
N042137-BI	Lead	EPA 200.8	2.13	0.50	ug/L	15	AMS-01-SF-P-134	10/20/16 05:10	11/30/16 14:18
N042137-BJ	Lead	EPA 200.8	1.01	0.50	ug/L	15	AMS-01-CF-P-135	10/20/16 05:10	11/30/16 14:21
N042137-BK	Lead	EPA 200.8	1.11	0.50	ug/L	15	AMS-01-SF-P-136	10/20/16 05:10	11/30/16 14:23
N042137-BL	Lead	EPA 200.8	2.70	0.50	ug/L	15	AMS-01-BF-P-137	10/20/16 05:08	11/30/16 14:28
N042137-BM	Lead	EPA 200.8	1.29	0.50	ug/L	15	AMS-01-BF-P-138	10/20/16 05:08	11/30/16 14:31
N042137-BN	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-CF-P-139	10/20/16 05:08	11/30/16 14:43
N042137-BO	Lead	EPA 200.8	0.69	0.50	ug/L	15	AMS-01-BF-P-140	10/20/16 05:06	11/30/16 14:46
N042137-BP	Lead	EPA 200.8	0.58	0.50	ug/L	15	AMS-01-BF-P-141	10/20/16 05:08	11/30/16 14:48
N042137-BQ	Lead	EPA 200.8	0.58	0.50	ug/L	15	AMS-01-BF-P-142	10/20/16 05:08	11/30/16 14:51
N042137-BR	Lead	EPA 200.8	0.60	0.50	ug/L	15	AMS-01-BF-P-143	10/20/16 05:05	11/30/16 14:53
N042137-BS	Lead	EPA 200.8	1.66	0.50	ug/L	15	AMS-01-BF-P-144	10/20/16 05:05	11/30/16 14:56
N042137-BT	Lead	EPA 200.8	1.90	0.50	ug/L	15	AMS-01-BF-P-145	10/20/16 05:05	11/30/16 14:58
N042137-BU	Lead	EPA 200.8	1.30	0.50	ug/L	15	AMS-01-BF-P-146	10/20/16 05:03	11/30/16 15:01
N042137-BV	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-BF-P-147	10/20/16 05:02	11/30/16 15:03
N042137-BW	Lead	EPA 200.8	0.85	0.50	ug/L	15	AMS-01-BF-P-148	10/20/16 05:02	11/30/16 15:06
N042137-BX	Lead	EPA 200.8	6.80	0.50	ug/L	15	AMS-01-BF-P-149	10/20/16 05:02	11/30/16 15:19
N042137-BZ	Lead	EPA 200.8	0.80	0.50	ug/L	15	AMS-01-BF-P-151	10/20/16 05:00	11/30/16 15:21
N042137-CA	Lead	EPA 200.8	0.59	0.50	ug/L	15	AMS-01-BF-P-152	10/20/16 05:00	11/30/16 15:24
N042137-CC	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-154	10/20/16 04:59	11/30/16 15:26
N042137-CE	Lead	EPA 200.8	0.84	0.50	ug/L	15	AMS-01-BF-P-156	10/20/16 04:57	11/30/16 15:31
N042137-CF	Lead	EPA 200.8	0.94	0.50	ug/L	15	AMS-01-BF-P-157	10/20/16 04:57	11/30/16 15:34
N042137-CG	Lead	EPA 200.8	1.74	0.50	ug/L	15	AMS-01-CF-P-158	10/20/16 04:55	11/30/16 15:36
N042137-CH	Lead	EPA 200.8	0.53	0.50	ug/L	15	AMS-01-CF-P-159	10/20/16 04:54	11/30/16 15:39

New Jersey Analytical Laboratories

The
 chis.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (D)
www.njal.com

Total Metals by EPA 200.8

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042137-CI	Lead	EPA 200.8	ND	0.50	ug/L	15	AMS-01-DW-P-160	10/20/16 04:51	11/30/16 15:42

ALGONQUIN - RESULTS		COPPER RESULTS	
	SAMPLE #	TEST	ROOM #
#1	NO42137 (3)	COPPER	MAIN CORR. WATER FOUNTAIN-MAIN CORRIDOR FOUNTAIN
#2	NO42137 (69)	COPPER	614 - CLASSROOM FAUCET SCIENCE
#3	NO42137 (75)	COPPER	615 - CLASSROOM FAUCET SCIENCE
#4	NO42137 (86)	COPPER	712 - CLASSROOM FAUCET SCIENCE
#5	NO42137 (87)	COPPER	712 - CLASSROOM FAUCET SCIENCE
#6	NO42137 (91)	COPPER	713 - CLASSROOM FAUCET SCIENCE
#7	NO42137 (93)	COPPER	713 - CLASSROOM FAUCET SCIENCE
#8	NO42137 (94)	COPPER	713 - CLASSROOM FAUCET SCIENCE
#9	NO42137 (96)	COPPER	713 - CLASSROOM FAUCET SCIENCE
#10	NO42137 (97)	COPPER	713 - CLASSROOM FAUCET SCIENCE
ALGONQUIN - RESULTS		LEAD RESULTS	
	SAMPLE #	TEST	ROOM #
#1	NO42137 (50)	LEAD	BACK OF PFA6-CLASSROOM FAUCET-COM.LAB/ROBOTICS
#2	NO42137 (69)	LEAD	614 - CLASSROOM FAUCET SCIENCE
#3	NO42137 (82)	LEAD	712 - CLASSROOM FAUCET SCIENCE
#4	NO42137 (84)	LEAD	712 - CLASSROOM FAUCET SCIENCE
#5	NO42137 (91)	LEAD	713 - CLASSROOM FAUCET SCIENCE
#6	NO42137 (93)	LEAD	713 - CLASSROOM FAUCET SCIENCE
#7	NO42137 (AT)	LEAD	812 SCIENCE FAUCET
#8	NO42137 (AU)	LEAD	812 SCIENCE FAUCET