



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-01	Copper	EPA 200.8	376	2.00	ug/L	1300	HS-01-CF-P-01	10/21/16 04:51	12/2/16 11:11
N042136-02	Copper	EPA 200.8	3.56	2.00	ug/L	1300	HS-01-IM-P-02	10/21/16 04:57	12/2/16 11:13
N042136-03	Copper	EPA 200.8	331	2.00	ug/L	1300	HS-01-KF-P-03	10/21/16 04:51	12/2/16 11:15
N042136-04	Copper	EPA 200.8	275	2.00	ug/L	1300	HS-01-KF-P-04	10/21/16 04:57	12/2/16 11:17
N042136-05	Copper	EPA 200.8	281	2.00	ug/L	1300	HS-01-KF-P-05	10/21/16 04:57	12/2/16 11:19
N042136-06	Copper	EPA 200.8	148	2.00	ug/L	1300	HS-01-KF-P-06	10/21/16 04:57	12/2/16 11:22
N042136-07	Copper	EPA 200.8	53.0	2.00	ug/L	1300	HS-01-KF-P-07	10/21/16 04:57	12/2/16 11:24
N042136-08	Copper	EPA 200.8	239	2.00	ug/L	1300	HS-01-KF-P-08	10/21/16 04:57	12/2/16 11:26
N042136-09	Copper	EPA 200.8	241	2.00	ug/L	1300	HS-01-KF-P-09	10/21/16 04:57	12/2/16 11:28
N042136-10	Copper	EPA 200.8	431	2.00	ug/L	1300	HS-01-KF-P-10	10/21/16 04:59	12/2/16 11:31
N042136-11	Copper	EPA 200.8	189	2.00	ug/L	1300	HS-01-BF-P-11	10/21/16 04:59	12/2/16 11:43
N042136-12	Copper	EPA 200.8	126	2.00	ug/L	1300	HS-01-BF-P-12	10/21/16 04:59	12/2/16 11:45
N042136-13	Copper	EPA 200.8	340	2.00	ug/L	1300	HS-01-DW-P-13	10/21/16 05:02	12/2/16 11:47
N042136-14	Copper	EPA 200.8	313	2.00	ug/L	1300	HS-01-DW-P-14	10/21/16 05:02	12/2/16 11:50
N042136-15	Copper	EPA 200.8	309	2.00	ug/L	1300	HS-01-SF-P-15	10/21/16 05:02	12/2/16 11:52
N042136-16	Copper	EPA 200.8	220	2.00	ug/L	1300	HS-01-CF-P-16	10/21/16 05:04	12/2/16 11:54
N042136-17	Copper	EPA 200.8	212	2.00	ug/L	1300	HS-01-CF-P-17	10/21/16 05:04	12/2/16 11:56
N042136-18	Copper	EPA 200.8	188	2.00	ug/L	1300	HS-01-DW-P-18	10/21/16 05:04	12/2/16 11:58
N042136-19	Copper	EPA 200.8	286	2.00	ug/L	1300	HS-01-CF-P-19	10/21/16 05:06	12/2/16 12:01
N042136-20	Copper	EPA 200.8	302	2.00	ug/L	1300	HS-01-CF-P-20	10/21/16 05:06	12/2/16 12:03
N042136-21	Copper	EPA 200.8	246	2.00	ug/L	1300	HS-01-CF-P-21	10/21/16 05:04	12/2/16 13:55
N042136-22	Copper	EPA 200.8	260	2.00	ug/L	1300	HS-01-CF-P-22	10/21/16 05:06	12/2/16 13:58
N042136-23	Copper	EPA 200.8	245	2.00	ug/L	1300	HS-01-CF-P-23	10/21/16 05:06	12/2/16 14:00
N042136-24	Copper	EPA 200.8	219	2.00	ug/L	1300	HS-01-CF-P-24	10/21/16 05:06	12/2/16 14:02
N042136-25	Copper	EPA 200.8	343	2.00	ug/L	1300	HS-01-CF-P-25	10/21/16 05:14	12/2/16 14:04
N042136-26	Copper	EPA 200.8	350	2.00	ug/L	1300	HS-01-CF-P-26	10/21/16 05:14	12/2/16 14:06
N042136-27	Copper	EPA 200.8	345	2.00	ug/L	1300	HS-01-CF-P-27	10/21/16 05:18	12/2/16 14:09
N042136-28	Copper	EPA 200.8	430	2.00	ug/L	1300	HS-01-CF-P-28	10/21/16 05:18	12/2/16 14:11
N042136-29	Copper	EPA 200.8	293	2.00	ug/L	1300	HS-01-CF-P-29	10/21/16 05:18	12/2/16 14:13
N042136-30	Copper	EPA 200.8	353	2.00	ug/L	1300	HS-01-SP-P-30	10/21/16 05:18	12/2/16 14:15
N042136-31	Copper	EPA 200.8	492	2.00	ug/L	1300	HS-01-SF-P-31	10/21/16 05:18	12/2/16 14:53
N042136-32	Copper	EPA 200.8	97.4	2.00	ug/L	1300	HS-01-DW-P-32	10/21/16 05:20	12/2/16 14:55

New Jersey Analytical Laboratories

The  
 cus.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved

New Jersey Analytical Laboratories  
**NJAL**

380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-33	Copper	EPA 200.8	130	2.00	ug/L	1300	HS-01-DW-P-33	10/21/16 05:20	12/2/16 14:57
N042136-34	Copper	EPA 200.8	106	2.00	ug/L	1300	HS-01-SF-P-34	10/21/16 05:22	12/2/16 14:59
N042136-35	Copper	EPA 200.8	111	2.00	ug/L	1300	HS-01-SF-P-35	10/21/16 05:22	12/2/16 15:02
N042136-36	Copper	EPA 200.8	105	2.00	ug/L	1300	HS-01-SF-P-36	10/21/16 05:23	12/2/16 15:04
N042136-37	Copper	EPA 200.8	99.7	2.00	ug/L	1300	HS-01-NF-P-37	10/21/16 05:27	12/2/16 15:06
N042136-38	Copper	EPA 200.8	356	2.00	ug/L	1300	HS-01-NF-P-38	10/21/16 05:27	12/2/16 15:08
N042136-39	Copper	EPA 200.8	42.6	2.00	ug/L	1300	HS-01-BF-P-39	10/21/16 05:27	12/2/16 15:11
N042136-40	Copper	EPA 200.8	ND	2.00	ug/L	1300	HS-01-IM-P-40	10/21/16 05:27	12/2/16 15:13
N042136-41	Copper	EPA 200.8	77.3	2.00	ug/L	1300	HS-01-DW-P-41	10/21/16 05:31	12/5/16 11:29
N042136-42	Copper	EPA 200.8	96.4	2.00	ug/L	1300	HS-01-DW-P-42	10/21/16 05:31	12/5/16 11:32
N042136-43	Copper	EPA 200.8	90.8	2.00	ug/L	1300	HS-01-BF-P-43	10/21/16 05:30	12/5/16 11:34
N042136-44	Copper	EPA 200.8	80.9	2.00	ug/L	1300	HS-01-BF-P-44	10/21/16 05:30	12/5/16 11:36
N042136-45	Copper	EPA 200.8	80.5	2.00	ug/L	1300	HS-01-BF-P-45	10/21/16 05:30	12/5/16 11:38
N042136-46	Copper	EPA 200.8	73.7	2.00	ug/L	1300	HS-01-BF-P-46	10/21/16 05:30	12/5/16 11:40
N042136-47	Copper	EPA 200.8	231	2.00	ug/L	1300	HS-01-BF-P-47	10/21/16 05:33	12/5/16 11:43
N042136-48	Copper	EPA 200.8	250	2.00	ug/L	1300	HS-01-BF-P-48	10/21/16 05:33	12/5/16 11:45
N042136-49	Copper	EPA 200.8	221	2.00	ug/L	1300	HS-01-BF-P-49	10/21/16 05:33	12/5/16 11:47
N042136-50	Copper	EPA 200.8	211	2.00	ug/L	1300	HS-01-BF-P-50	10/21/16 05:33	12/5/16 11:50
N042136-51	Copper	EPA 200.8	153	2.00	ug/L	1300	HS-01-BF-P-51	10/21/16 05:38	12/5/16 14:08
N042136-52	Copper	EPA 200.8	151	2.00	ug/L	1300	HS-01-BF-P-52	10/21/16 05:36	12/5/16 14:10
N042136-53	Copper	EPA 200.8	452	2.00	ug/L	1300	HS-01-BF-P-53	10/21/16 05:36	12/5/16 14:13
N042136-54	Copper	EPA 200.8	195	2.00	ug/L	1300	HS-01-BF-P-54	10/21/16 05:37	12/5/16 14:15
N042136-55	Copper	EPA 200.8	202	2.00	ug/L	1300	HS-01-BF-P-55	10/21/16 05:37	12/5/16 14:17
N042136-56	Copper	EPA 200.8	363	2.00	ug/L	1300	HS-01-SF-P-56	10/21/16 05:30	12/5/16 14:19
N042136-57	Copper	EPA 200.8	158	2.00	ug/L	1300	HS-01-CF-P-57	10/21/16 05:40	12/5/16 14:22
N042136-58	Copper	EPA 200.8	179	2.00	ug/L	1300	HS-01-BF-P-58	10/21/16 05:40	12/5/16 14:24
N042136-59	Copper	EPA 200.8	126	2.00	ug/L	1300	HS-01-BF-P-59	10/21/16 05:42	12/5/16 14:26
N042136-60	Copper	EPA 200.8	93.6	2.00	ug/L	1300	HS-01-SF-P-60	10/21/16 05:44	12/5/16 14:28
N042136-61	Copper	EPA 200.8	89.3	2.00	ug/L	1300	HS-01-BF-P-61	10/21/16 05:44	12/5/16 16:30
N042136-62	Copper	EPA 200.8	92.3	2.00	ug/L	1300	HS-01-BF-P-62	10/21/16 05:44	12/5/16 16:32
N042136-64	Copper	EPA 200.8	4050	2.00	ug/L	1300	HS-01-BF-P-64	10/21/16 05:47	12/6/16 10:58
N042136-65	Copper	EPA 200.8	1080	2.00	ug/L	1300	HS-01-BF-P-65	10/21/16 05:47	12/6/16 11:05

New Jersey Analytical Laboratories

The  
 cius.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)


**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-66	Copper	EPA 200.8	3620	2.00	ug/L	1300	HS-01-BF-P-66	10/21/16 05:47	12/6/16 11:07
N042136-67	Copper	EPA 200.8	264	2.00	ug/L	1300	HS-01-BF-P-67	10/21/16 05:50	12/5/16 16:35
N042136-68	Copper	EPA 200.8	195	2.00	ug/L	1300	HS-01-BF-P-68	10/21/16 05:50	12/5/16 16:37
N042136-69	Copper	EPA 200.8	193	2.00	ug/L	1300	HS-01-BF-P-69	10/21/16 05:50	12/5/16 16:39
N042136-71	Copper	EPA 200.8	181	2.00	ug/L	1300	HS-01-CF-P-71	10/21/16 04:55	12/5/16 16:41
N042136-72	Copper	EPA 200.8	229	2.00	ug/L	1300	HS-01-CF-P-72	10/21/16 04:55	12/5/16 16:44
N042136-73	Copper	EPA 200.8	174	2.00	ug/L	1300	HS-01-CF-P-73	10/21/16 04:55	12/5/16 16:46
N042136-74	Copper	EPA 200.8	103	2.00	ug/L	1300	HS-01-SF-P-74	10/21/16 04:56	12/5/16 16:48
N042136-75	Copper	EPA 200.8	443	2.00	ug/L	1300	HS-01-CF-P-75	10/21/16 04:56	12/5/16 16:50
N042136-76	Copper	EPA 200.8	143	2.00	ug/L	1300	HS-01-CF-P-76	10/21/16 04:58	12/5/16 17:02
N042136-77	Copper	EPA 200.8	159	2.00	ug/L	1300	HS-01-CF-P-77	10/21/16 04:58	12/5/16 17:04
N042136-78	Copper	EPA 200.8	153	2.00	ug/L	1300	HS-01-CF-P-78	10/21/16 04:58	12/5/16 17:06
N042136-79	Copper	EPA 200.8	451	2.00	ug/L	1300	HS-01-CF-P-79	10/21/16 05:14	12/5/16 17:08
N042136-80	Copper	EPA 200.8	1160	2.00	ug/L	1300	HS-01-CF-P-80	10/21/16 05:00	12/5/16 17:11
N042136-81	Copper	EPA 200.8	1230	2.00	ug/L	1300	HS-01-CF-P-81	10/21/16 05:00	12/5/16 17:13
N042136-82	Copper	EPA 200.8	559	2.00	ug/L	1300	HS-01-BF-P-82	10/21/16 05:00	12/5/16 17:15
N042136-83	Copper	EPA 200.8	105	2.00	ug/L	1300	HS-01-CF-P-83	10/21/16 05:05	12/5/16 17:17
N042136-84	Copper	EPA 200.8	169	2.00	ug/L	1300	HS-01-CF-P-84	10/21/16 05:05	12/5/16 17:22
N042136-85	Copper	EPA 200.8	221	2.00	ug/L	1300	HS-01-CF-P-85	10/21/16 05:05	12/5/16 17:24
N042136-86	Copper	EPA 200.8	259	2.00	ug/L	1300	HS-01-CF-P-86	10/21/16 05:06	12/5/16 17:36
N042136-87	Copper	EPA 200.8	2170	2.00	ug/L	1300	HS-01-CF-P-87	10/21/16 05:06	12/5/16 17:38
N042136-88	Copper	EPA 200.8	21300	200	ug/L	1300	HS-01-CF-P-88	10/21/16 05:06	12/6/16 15:53
N042136-89	Copper	EPA 200.8	518	2.00	ug/L	1300	HS-01-CF-P-89	10/21/16 05:06	12/5/16 17:40
N042136-90	Copper	EPA 200.8	159	2.00	ug/L	1300	HS-01-BF-P-90	10/21/16 05:11	12/5/16 17:42
N042136-91	Copper	EPA 200.8	214	2.00	ug/L	1300	HS-01-BF-P-91	10/21/16 05:12	12/5/16 17:45
N042136-92	Copper	EPA 200.8	327	2.00	ug/L	1300	HS-01-CF-P-92	10/21/16 05:12	12/5/16 17:47
N042136-94	Copper	EPA 200.8	83.7	2.00	ug/L	1300	HS-01-BF-P-94	10/21/16 05:17	12/5/16 17:49
N042136-95	Copper	EPA 200.8	82.3	2.00	ug/L	1300	HS-01-BF-P-95	10/21/16 05:17	12/5/16 17:51
N042136-96	Copper	EPA 200.8	96.6	2.00	ug/L	1300	HS-01-BF-P-96	10/21/16 05:17	12/5/16 17:54
N042136-97	Copper	EPA 200.8	130	2.00	ug/L	1300	HS-01-BF-P-97	10/21/16 05:19	12/5/16 17:56
N042136-98	Copper	EPA 200.8	98.7	2.00	ug/L	1300	HS-01-BF-P-98	10/21/16 05:20	12/5/16 18:07
N042136-99	Copper	EPA 200.8	107	2.00	ug/L	1300	HS-01-BF-P-99	10/21/16 05:20	12/5/16 18:10



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-AA	Copper	EPA 200.8	113	2.00	ug/L	1300	HS-01-BF-P-100	10/21/16 05:20	12/5/16 18:12
N042136-AB	Copper	EPA 200.8	104	2.00	ug/L	1300	HS-01-BF-P-101	10/21/16 05:20	12/5/16 18:14
N042136-AC	Copper	EPA 200.8	80.5	2.00	ug/L	1300	HS-01-SF-P-102	10/21/16 05:22	12/5/16 18:19
N042136-AD	Copper	EPA 200.8	72.6	2.00	ug/L	1300	HS-01-SF-P-103	10/21/16 05:22	12/5/16 18:21
N042136-AE	Copper	EPA 200.8	79.5	2.00	ug/L	1300	HS-01-SF-P-104	10/21/16 05:22	12/5/16 18:23
N042136-AF	Copper	EPA 200.8	91.3	2.00	ug/L	1300	HS-01-SF-P-105	10/21/16 05:22	12/5/16 18:25
N042136-AG	Copper	EPA 200.8	241	2.00	ug/L	1300	HS-01-DF-P-106	10/21/16 05:23	12/5/16 18:28
N042136-AH	Copper	EPA 200.8	182	2.00	ug/L	1300	HS-01-SF-P-107	10/21/16 05:25	12/5/16 18:30
N042136-AI	Copper	EPA 200.8	162	2.00	ug/L	1300	HS-01-SF-P-108	10/21/16 05:25	12/1/16 12:36
N042136-AJ	Copper	EPA 200.8	155	2.00	ug/L	1300	HS-01-SF-P-109	10/21/16 05:25	12/1/16 12:39
N042136-AK	Copper	EPA 200.8	150	2.00	ug/L	1300	HS-01-SF-P-110	10/21/16 05:25	12/1/16 12:41
N042136-AL	Copper	EPA 200.8	151	2.00	ug/L	1300	HS-01-BF-P-111	10/21/16 05:26	12/1/16 12:44
N042136-AM	Copper	EPA 200.8	121	2.00	ug/L	1300	HS-01-DW-P-112	10/21/16 05:28	12/1/16 12:46
N042136-AN	Copper	EPA 200.8	114	2.00	ug/L	1300	HS-01-DW-P-113	10/21/16 05:28	12/1/16 12:48
N042136-AO	Copper	EPA 200.8	210	2.00	ug/L	1300	HS-01-SF-P-114	10/21/16 05:30	12/1/16 12:51
N042136-AP	Copper	EPA 200.8	ND	2.00	ug/L	1300	HS-01-IM-P-115	10/21/16 05:35	12/1/16 12:53
N042136-AQ	Copper	EPA 200.8	230	2.00	ug/L	1300	HS-01-BF-P-116	10/21/16 05:34	12/1/16 12:55
N042136-AR	Copper	EPA 200.8	153	2.00	ug/L	1300	HS-01-SF-P-117	10/21/16 05:36	12/1/16 12:58
N042136-AS	Copper	EPA 200.8	139	2.00	ug/L	1300	HS-01-SF-P-118	10/21/16 05:36	12/1/16 13:41
N042136-AT	Copper	EPA 200.8	112	2.00	ug/L	1300	HS-01-SF-P-119	10/21/16 05:36	12/1/16 13:44
N042136-AU	Copper	EPA 200.8	127	2.00	ug/L	1300	HS-01-SF-P-120	10/21/16 05:36	12/1/16 13:46
N042136-AV	Copper	EPA 200.8	152	2.00	ug/L	1300	HS-01-SF-P-121	10/21/16 05:39	11/30/16 16:21
N042136-AW	Copper	EPA 200.8	108	2.00	ug/L	1300	HS-01-SF-P-122	10/21/16 05:39	11/30/16 16:23
N042136-AX	Copper	EPA 200.8	110	2.00	ug/L	1300	HS-01-SF-P-123	10/21/16 05:39	11/30/16 16:25
N042136-AY	Copper	EPA 200.8	140	2.00	ug/L	1300	HS-01-SF-P-124	10/21/16 05:39	11/30/16 16:27
N042136-AZ	Copper	EPA 200.8	136	2.00	ug/L	1300	HS-01-DW-P-125	10/21/16 05:39	11/30/16 16:29
N042136-BA	Copper	EPA 200.8	129	2.00	ug/L	1300	HS-01-BF-P-126	10/21/16 05:40	11/30/16 16:31
N042136-BB	Copper	EPA 200.8	145	2.00	ug/L	1300	HS-01-DW-P-127	10/21/16 05:46	11/30/16 16:34
N042136-BC	Copper	EPA 200.8	174	2.00	ug/L	1300	HS-Outside-BF-P-128	10/21/16 05:45	11/30/16 16:36
N042136-BD	Copper	EPA 200.8	134	2.00	ug/L	1300	HS-Outside-BF-P-129	10/21/16 05:45	11/30/16 16:38
N042136-BE	Copper	EPA 200.8	130	2.00	ug/L	1300	HS-Outside-BF-P-130	10/21/16 05:45	11/30/16 16:40
N042136-BF	Copper	EPA 200.8	714	2.00	ug/L	1300	HS-Concession-SF-P-131	10/21/16 05:47	11/30/16 16:51



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-BG	Copper	EPA 200.8	90.1	2.00	ug/L	1300	HS-02-BF-P-132	10/21/16 04:57	11/30/16 16:54
N042136-BH	Copper	EPA 200.8	72.6	2.00	ug/L	1300	HS-02-BF-P-133	10/21/16 04:57	11/30/16 16:56
N042136-BI	Copper	EPA 200.8	84.0	2.00	ug/L	1300	HS-02-BF-P-134	10/21/16 06:15	11/30/16 16:58
N042136-BJ	Copper	EPA 200.8	88.5	2.00	ug/L	1300	HS-02-BF-P-135	10/21/16 06:15	11/30/16 17:00
N042136-BK	Copper	EPA 200.8	87.3	2.00	ug/L	1300	HS-02-BF-P-136	10/21/16 04:58	11/30/16 17:02
N042136-BL	Copper	EPA 200.8	59.0	2.00	ug/L	1300	HS-02-BF-P-137	10/21/16 04:58	11/30/16 17:04
N042136-BM	Copper	EPA 200.8	55.9	2.00	ug/L	1300	HS-02-BF-P-138	10/21/16 04:58	11/30/16 17:07
N042136-BN	Copper	EPA 200.8	79.8	2.00	ug/L	1300	HS-02-BF-P-139	10/21/16 04:58	11/30/16 17:11
N042136-BO	Copper	EPA 200.8	188	2.00	ug/L	1300	HS-02-BF-P-140	10/21/16 05:00	11/30/16 17:13
N042136-BP	Copper	EPA 200.8	178	2.00	ug/L	1300	HS-02-CF-P-141	10/21/16 05:02	11/30/16 17:54
N042136-BQ	Copper	EPA 200.8	232	2.00	ug/L	1300	HS-02-CF-P-142	10/21/16 05:02	11/30/16 17:56
N042136-BT	Copper	EPA 200.8	192	2.00	ug/L	1300	HS-02-CF-P-145	10/21/16 05:03	11/30/16 17:59
N042136-BU	Copper	EPA 200.8	368	2.00	ug/L	1300	HS-02-CF-P-146	10/21/16 05:05	11/30/16 18:01
N042136-BV	Copper	EPA 200.8	213	2.00	ug/L	1300	HS-02-DW-P-147	10/21/16 05:06	11/30/16 18:03
N042136-BW	Copper	EPA 200.8	214	2.00	ug/L	1300	HS-02-DW-P-148	10/21/16 05:06	11/30/16 18:05
N042136-BX	Copper	EPA 200.8	141	2.00	ug/L	1300	HS-02-BF-P-149	10/21/16 05:07	11/30/16 18:07
N042136-BY	Copper	EPA 200.8	404	2.00	ug/L	1300	HS-02-CF-P-150	10/21/16 05:08	11/30/16 18:10
N042136-BZ	Copper	EPA 200.8	408	2.00	ug/L	1300	HS-02-CF-P-151	10/21/16 05:11	11/30/16 18:12
N042136-CA	Copper	EPA 200.8	395	2.00	ug/L	1300	HS-02-CF-P-152	10/21/16 05:11	11/30/16 18:14
N042136-CB	Copper	EPA 200.8	513	2.00	ug/L	1300	HS-02-CF-P-153	10/21/16 05:11	11/30/16 18:25
N042136-CC	Copper	EPA 200.8	546	2.00	ug/L	1300	HS-02-CF-P-154	10/21/16 05:11	11/30/16 18:27
N042136-CD	Copper	EPA 200.8	425	2.00	ug/L	1300	HS-02-CF-P-155	10/21/16 05:11	11/30/16 18:29
N042136-CE	Copper	EPA 200.8	359	2.00	ug/L	1300	HS-02-CF-P-156	10/21/16 05:11	11/30/16 18:32
N042136-CF	Copper	EPA 200.8	534	2.00	ug/L	1300	HS-02-CF-P-157	10/21/16 05:18	11/30/16 18:34
N042136-CG	Copper	EPA 200.8	313	2.00	ug/L	1300	HS-02-SF-P-158	10/21/16 05:14	11/30/16 18:36
N042136-CH	Copper	EPA 200.8	614	2.00	ug/L	1300	HS-02-CF-P-159	10/21/16 05:17	11/30/16 18:38
N042136-CI	Copper	EPA 200.8	1760	2.00	ug/L	1300	HS-02-CF-P-160	10/21/16 05:17	11/30/16 18:40
N042136-CJ	Copper	EPA 200.8	493	2.00	ug/L	1300	HS-02-CF-P-161	10/21/16 05:17	11/30/16 18:45
N042136-CK	Copper	EPA 200.8	515	2.00	ug/L	1300	HS-02-CF-P-162	10/21/16 05:17	11/30/16 18:47
N042136-CL	Copper	EPA 200.8	487	2.00	ug/L	1300	HS-02-CF-P-163	10/21/16 05:17	11/30/16 18:58
N042136-CM	Copper	EPA 200.8	577	2.00	ug/L	1300	HS-02-CF-P-164	10/21/16 05:17	11/30/16 19:01
N042136-CN	Copper	EPA 200.8	83.1	2.00	ug/L	1300	HS-02-BF-P-165	10/21/16 05:22	11/30/16 19:03



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-CO	Copper	EPA 200.8	78.0	2.00	ug/L	1300	HS-02-BF-P-166	10/21/16 05:22	11/30/16 19:05
N042136-CP	Copper	EPA 200.8	53.9	2.00	ug/L	1300	HS-02-BF-P-167	10/21/16 05:22	11/30/16 19:07
N042136-CQ	Copper	EPA 200.8	83.0	2.00	ug/L	1300	HS-02-BF-P-168	10/21/16 05:22	11/30/16 19:09
N042136-CR	Copper	EPA 200.8	128	2.00	ug/L	1300	HS-02-BF-P-169	10/21/16 05:24	11/30/16 19:12
N042136-CS	Copper	EPA 200.8	74.7	2.00	ug/L	1300	HS-02-BF-P-170	10/21/16 05:24	11/30/16 19:14
N042136-CT	Copper	EPA 200.8	398	2.00	ug/L	1300	HS-02-BF-P-171	10/21/16 05:24	11/30/16 19:16
N042136-CU	Copper	EPA 200.8	140	2.00	ug/L	1300	HS-02-BF-P-172	10/21/16 05:24	11/30/16 19:18
N042136-CV	Copper	EPA 200.8	160	2.00	ug/L	1300	HS-02-DW-P-173	10/21/16 05:29	11/30/16 19:29
N042136-CW	Copper	EPA 200.8	142	2.00	ug/L	1300	HS-02-DW-P-174	10/21/16 05:29	11/30/16 19:32
N042136-CX	Copper	EPA 200.8	377	2.00	ug/L	1300	HS-02-CF-P-175	10/21/16 05:32	11/30/16 19:34
N042136-CY	Copper	EPA 200.8	409	2.00	ug/L	1300	HS-02-CF-P-176	10/21/16 05:32	11/30/16 19:36
N042136-CZ	Copper	EPA 200.8	304	2.00	ug/L	1300	HS-02-CF-P-177	10/21/16 05:32	11/30/16 19:41
N042136-DA	Copper	EPA 200.8	192	2.00	ug/L	1300	HS-02-CF-P-178	10/21/16 05:32	11/30/16 19:43
N042136-DB	Copper	EPA 200.8	155	2.00	ug/L	1300	HS-02-CF-P-179	10/21/16 05:32	11/30/16 19:45
N042136-DC	Copper	EPA 200.8	376	2.00	ug/L	1300	HS-02-CF-P-180	10/21/16 05:32	12/1/16 13:49
N042136-DD	Copper	EPA 200.8	314	2.00	ug/L	1300	HS-02-CF-P-181	10/21/16 05:32	12/1/16 13:51
N042136-DE	Copper	EPA 200.8	469	2.00	ug/L	1300	HS-02-CF-P-182	10/21/16 05:32	12/1/16 13:53
N042136-DF	Copper	EPA 200.8	172	2.00	ug/L	1300	HS-02-SF-P-183	10/21/16 05:35	12/1/16 13:56
N042136-DG	Copper	EPA 200.8	353	2.00	ug/L	1300	HS-02-CF-P-184	10/21/16 05:37	12/1/16 13:58
N042136-DH	Copper	EPA 200.8	420	2.00	ug/L	1300	HS-02-CF-P-185	10/21/16 05:37	12/1/16 14:00
N042136-DI	Copper	EPA 200.8	323	2.00	ug/L	1300	HS-02-CF-P-186	10/21/16 05:37	12/1/16 14:03
N042136-DJ	Copper	EPA 200.8	370	2.00	ug/L	1300	HS-02-CF-P-187	10/21/16 05:37	12/1/16 14:15
N042136-DK	Copper	EPA 200.8	299	2.00	ug/L	1300	HS-02-CF-P-188	10/21/16 05:37	12/1/16 14:17
N042136-DL	Copper	EPA 200.8	862	2.00	ug/L	1300	HS-02-CF-P-189	10/21/16 05:37	12/1/16 14:19
N042136-DM	Copper	EPA 200.8	302	2.00	ug/L	1300	HS-02-CF-P-190	10/21/16 05:37	12/1/16 14:22
N042136-DN	Copper	EPA 200.8	274	2.00	ug/L	1300	HS-02-CF-P-191	10/21/16 05:37	12/1/16 14:25
N042136-DO	Copper	EPA 200.8	1220	2.00	ug/L	1300	HS-02-CF-P-192	10/21/16 05:37	12/1/16 14:27
N042136-DP	Copper	EPA 200.8	584	2.00	ug/L	1300	HS-02-CF-P-193	10/21/16 05:41	12/1/16 14:30
N042136-DQ	Copper	EPA 200.8	11700	200	ug/L	1300	HS-02-CF-P-194	10/21/16 05:41	12/6/16 11:12
N042136-DR	Copper	EPA 200.8	559	2.00	ug/L	1300	HS-02-CF-P-195	10/21/16 05:41	12/1/16 14:32
N042136-DS	Copper	EPA 200.8	440	2.00	ug/L	1300	HS-02-CF-P-196	10/21/16 05:41	12/1/16 14:37
N042136-DT	Copper	EPA 200.8	347	2.00	ug/L	1300	HS-02-CF-P-197	10/21/16 05:41	12/1/16 14:39



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-DU	Copper	EPA 200.8	440	2.00	ug/L	1300	HS-02-CF-P-198	10/21/16 05:41	12/1/16 14:51
N042136-DV	Copper	EPA 200.8	337	2.00	ug/L	1300	HS-02-CF-P-199	10/21/16 05:41	12/1/16 14:54
N042136-DW	Copper	EPA 200.8	324	2.00	ug/L	1300	HS-02-SF-P-200	10/21/16 05:44	12/1/16 14:56
N042136-DX	Copper	EPA 200.8	295	2.00	ug/L	1300	HS-02-CF-P-201	10/21/16 05:47	12/1/16 14:58
N042136-DY	Copper	EPA 200.8	296	2.00	ug/L	1300	HS-02-CF-P-202	10/21/16 05:47	12/1/16 15:01
N042136-DZ	Copper	EPA 200.8	228	2.00	ug/L	1300	HS-02-CF-P-203	10/21/16 05:47	12/1/16 15:03
N042136-EA	Copper	EPA 200.8	309	2.00	ug/L	1300	HS-02-CF-P-204	10/21/16 05:47	12/1/16 15:06
N042136-EB	Copper	EPA 200.8	308	2.00	ug/L	1300	HS-02-CF-P-205	10/21/16 05:47	12/1/16 15:08
N042136-EC	Copper	EPA 200.8	392	2.00	ug/L	1300	HS-02-CF-P-206	10/21/16 05:47	12/1/16 15:10
N042136-ED	Copper	EPA 200.8	213	2.00	ug/L	1300	HS-02-CF-P-207	10/21/16 05:47	12/1/16 15:13
N042136-EF	Copper	EPA 200.8	192	2.00	ug/L	1300	HS-02-CF-P-209	10/21/16 05:52	12/1/16 15:25
N042136-EG	Copper	EPA 200.8	652	2.00	ug/L	1300	HS-02-CF-P-210	10/21/16 05:52	12/1/16 15:27
N042136-EH	Copper	EPA 200.8	344	2.00	ug/L	1300	HS-02-CF-P-211	10/21/16 05:52	12/1/16 15:29
N042136-EI	Copper	EPA 200.8	500	2.00	ug/L	1300	HS-02-CF-P-212	10/21/16 05:52	12/1/16 15:32
N042136-EJ	Copper	EPA 200.8	433	2.00	ug/L	1300	HS-02-CF-P-213	10/21/16 05:52	12/1/16 15:37
N042136-EK	Copper	EPA 200.8	206	2.00	ug/L	1300	HS-02-CF-P-214	10/21/16 05:52	12/1/16 15:39
N042136-EL	Copper	EPA 200.8	51.4	2.00	ug/L	1300	HS-02-CF-P-215	10/21/16 05:52	12/1/16 15:41
N042136-EM	Copper	EPA 200.8	389	2.00	ug/L	1300	HS-02-SF-P-216	10/21/16 05:54	12/1/16 15:44
N042136-EO	Copper	EPA 200.8	230	2.00	ug/L	1300	HS-02-CF-P-218	10/21/16 05:56	12/1/16 15:46
N042136-EP	Copper	EPA 200.8	381	2.00	ug/L	1300	HS-02-CF-P-219	10/21/16 05:56	12/1/16 15:49
N042136-EQ	Copper	EPA 200.8	465	2.00	ug/L	1300	HS-02-CF-P-220	10/21/16 05:56	12/1/16 16:36
N042136-ER	Copper	EPA 200.8	837	2.00	ug/L	1300	HS-02-CF-P-221	10/21/16 05:56	12/1/16 16:39
N042136-ES	Copper	EPA 200.8	207	2.00	ug/L	1300	HS-02-CF-P-222	10/21/16 05:56	12/1/16 16:41
N042136-ET	Copper	EPA 200.8	1270	2.00	ug/L	1300	HS-02-CF-P-223	10/21/16 05:56	12/1/16 16:44
N042136-EV	Copper	EPA 200.8	2800	4.00	ug/L	1300	HS-02-CF-P-225	10/21/16 06:01	12/5/16 19:19
N042136-EW	Copper	EPA 200.8	558	2.00	ug/L	1300	HS-02-SF-P-226	10/21/16 06:01	12/1/16 16:49
N042136-EX	Copper	EPA 200.8	347	2.00	ug/L	1300	HS-02-CF-P-227	10/21/16 06:01	12/1/16 16:52
N042136-EY	Copper	EPA 200.8	176	2.00	ug/L	1300	HS-02-CF-P-228	10/21/16 06:01	12/1/16 16:54
N042136-EZ	Copper	EPA 200.8	232	2.00	ug/L	1300	HS-02-CF-P-229	10/21/16 06:01	12/1/16 16:56
N042136-FA	Copper	EPA 200.8	467	2.00	ug/L	1300	HS-02-CF-P-230	10/21/16 06:01	12/1/16 16:59
N042136-FB	Copper	EPA 200.8	600	2.00	ug/L	1300	HS-02-CF-P-231	10/21/16 06:01	12/1/16 17:11
N042136-FC	Copper	EPA 200.8	198	2.00	ug/L	1300	HS-02-CF-P-232	10/21/16 06:01	12/1/16 17:13



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-FD	Copper	EPA 200.8	329	2.00	ug/L	1300	HS-02-CF-P-233	10/21/16 06:01	12/1/16 17:16
N042136-FE	Copper	EPA 200.8	127	2.00	ug/L	1300	HS-02-BF-P-234	10/21/16 06:03	12/1/16 17:18
N042136-FF	Copper	EPA 200.8	133	2.00	ug/L	1300	HS-01-DW-P-17a	10/21/16 05:26	12/1/16 17:20
N042136-FG	Copper	EPA 200.8	169	2.00	ug/L	1300	HS-01-BF-P-36a	10/21/16 06:08	12/1/16 17:23
Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-01	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-01	10/21/16 04:51	12/2/16 11:11
N042136-02	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-IM-P-02	10/21/16 04:57	12/2/16 11:13
N042136-03	Lead	EPA 200.8	1.88	0.50	ug/L	15	HS-01-KF-P-03	10/21/16 04:51	12/2/16 11:15
N042136-04	Lead	EPA 200.8	2.09	0.50	ug/L	15	HS-01-KF-P-04	10/21/16 04:57	12/2/16 11:17
N042136-05	Lead	EPA 200.8	1.97	0.50	ug/L	15	HS-01-KF-P-05	10/21/16 04:57	12/2/16 11:19
N042136-06	Lead	EPA 200.8	2.57	0.50	ug/L	15	HS-01-KF-P-06	10/21/16 04:57	12/2/16 11:22
N042136-07	Lead	EPA 200.8	1.33	0.50	ug/L	15	HS-01-KF-P-07	10/21/16 04:57	12/2/16 11:24
N042136-08	Lead	EPA 200.8	4.81	0.50	ug/L	15	HS-01-KF-P-08	10/21/16 04:57	12/2/16 11:26
N042136-09	Lead	EPA 200.8	5.97	0.50	ug/L	15	HS-01-KF-P-09	10/21/16 04:57	12/2/16 11:28
N042136-10	Lead	EPA 200.8	22.6	0.50	ug/L	15	HS-01-KF-P-10	10/21/16 04:59	12/2/16 11:31
N042136-11	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-11	10/21/16 04:59	12/2/16 11:43
N042136-12	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-12	10/21/16 04:59	12/2/16 11:45
N042136-13	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-13	10/21/16 05:02	12/2/16 11:47
N042136-14	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-14	10/21/16 05:02	12/2/16 11:50
N042136-15	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-SF-P-15	10/21/16 05:02	12/2/16 11:52
N042136-16	Lead	EPA 200.8	7.00	0.50	ug/L	15	HS-01-CF-P-16	10/21/16 05:04	12/2/16 11:54
N042136-17	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-17	10/21/16 05:04	12/2/16 11:56
N042136-18	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-18	10/21/16 05:04	12/2/16 11:58
N042136-19	Lead	EPA 200.8	3.57	0.50	ug/L	15	HS-01-CF-P-19	10/21/16 05:06	12/2/16 12:01
N042136-20	Lead	EPA 200.8	1.72	0.50	ug/L	15	HS-01-CF-P-20	10/21/16 05:06	12/2/16 12:03
N042136-21	Lead	EPA 200.8	1.63	0.50	ug/L	15	HS-01-CF-P-21	10/21/16 05:04	12/2/16 13:55
N042136-22	Lead	EPA 200.8	2.50	0.50	ug/L	15	HS-01-CF-P-22	10/21/16 05:06	12/2/16 13:58
N042136-23	Lead	EPA 200.8	1.31	0.50	ug/L	15	HS-01-CF-P-23	10/21/16 05:06	12/2/16 14:00
N042136-24	Lead	EPA 200.8	2.30	0.50	ug/L	15	HS-01-CF-P-24	10/21/16 05:06	12/2/16 14:02
N042136-25	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-25	10/21/16 05:14	12/2/16 14:04
N042136-26	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-26	10/21/16 05:14	12/2/16 14:06
N042136-27	Lead	EPA 200.8	0.88	0.50	ug/L	15	HS-01-CF-P-27	10/21/16 05:18	12/2/16 14:09

New Jersey Analytical Laboratories

The  
 cus.





NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-28	Lead	EPA 200.8	0.54	0.50	ug/L	15	HS-01-CF-P-28	10/21/16 05:18	12/2/16 14:11
N042136-29	Lead	EPA 200.8	0.65	0.50	ug/L	15	HS-01-CF-P-29	10/21/16 05:18	12/2/16 14:13
N042136-30	Lead	EPA 200.8	0.50	0.50	ug/L	15	HS-01-SP-P-30	10/21/16 05:18	12/2/16 14:15
N042136-31	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-SF-P-31	10/21/16 05:18	12/2/16 14:53
N042136-32	Lead	EPA 200.8	0.80	0.50	ug/L	15	HS-01-DW-P-32	10/21/16 05:20	12/2/16 14:55
N042136-33	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-33	10/21/16 05:20	12/2/16 14:57
N042136-34	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-SF-P-34	10/21/16 05:22	12/2/16 14:59
N042136-35	Lead	EPA 200.8	0.80	0.50	ug/L	15	HS-01-SF-P-35	10/21/16 05:22	12/2/16 15:02
N042136-36	Lead	EPA 200.8	3.57	0.50	ug/L	15	HS-01-SF-P-36	10/21/16 05:23	12/2/16 15:04
N042136-37	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-NF-P-37	10/21/16 05:27	12/2/16 15:06
N042136-38	Lead	EPA 200.8	2.30	0.50	ug/L	15	HS-01-NF-P-38	10/21/16 05:27	12/2/16 15:08
N042136-39	Lead	EPA 200.8	2.39	0.50	ug/L	15	HS-01-BF-P-39	10/21/16 05:27	12/2/16 15:11
N042136-40	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-IM-P-40	10/21/16 05:27	12/2/16 15:13
N042136-41	Lead	EPA 200.8	0.55	0.50	ug/L	15	HS-01-DW-P-41	10/21/16 05:31	12/5/16 11:29
N042136-42	Lead	EPA 200.8	1.22	0.50	ug/L	15	HS-01-DW-P-42	10/21/16 05:31	12/5/16 11:32
N042136-43	Lead	EPA 200.8	2.89	0.50	ug/L	15	HS-01-BF-P-43	10/21/16 05:30	12/5/16 11:34
N042136-44	Lead	EPA 200.8	1.21	0.50	ug/L	15	HS-01-BF-P-44	10/21/16 05:30	12/5/16 11:36
N042136-45	Lead	EPA 200.8	1.84	0.50	ug/L	15	HS-01-BF-P-45	10/21/16 05:30	12/5/16 11:38
N042136-46	Lead	EPA 200.8	2.46	0.50	ug/L	15	HS-01-BF-P-46	10/21/16 05:30	12/5/16 11:40
N042136-47	Lead	EPA 200.8	2.82	0.50	ug/L	15	HS-01-BF-P-47	10/21/16 05:33	12/5/16 11:43
N042136-48	Lead	EPA 200.8	1.10	0.50	ug/L	15	HS-01-BF-P-48	10/21/16 05:33	12/5/16 11:45
N042136-49	Lead	EPA 200.8	1.16	0.50	ug/L	15	HS-01-BF-P-49	10/21/16 05:33	12/5/16 11:47
N042136-50	Lead	EPA 200.8	1.87	0.50	ug/L	15	HS-01-BF-P-50	10/21/16 05:33	12/5/16 11:50
N042136-51	Lead	EPA 200.8	0.61	0.50	ug/L	15	HS-01-BF-P-51	10/21/16 05:38	12/5/16 14:08
N042136-52	Lead	EPA 200.8	1.63	0.50	ug/L	15	HS-01-BF-P-52	10/21/16 05:36	12/5/16 14:10
N042136-53	Lead	EPA 200.8	38.5	0.50	ug/L	15	HS-01-BF-P-53	10/21/16 05:36	12/5/16 14:13
N042136-54	Lead	EPA 200.8	0.87	0.50	ug/L	15	HS-01-BF-P-54	10/21/16 05:37	12/5/16 14:15
N042136-55	Lead	EPA 200.8	2.02	0.50	ug/L	15	HS-01-BF-P-55	10/21/16 05:37	12/5/16 14:17
N042136-56	Lead	EPA 200.8	1.94	0.50	ug/L	15	HS-01-SF-P-56	10/21/16 05:30	12/5/16 14:19
N042136-57	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-57	10/21/16 05:40	12/5/16 14:22
N042136-58	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-58	10/21/16 05:40	12/5/16 14:24
N042136-59	Lead	EPA 200.8	0.73	0.50	ug/L	15	HS-01-BF-P-59	10/21/16 05:42	12/5/16 14:26

New Jersey Analytical Laboratories

The  
 cus.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-60	Lead	EPA 200.8	1.32	0.50	ug/L	15	HS-01-SF-P-60	10/21/16 05:44	12/5/16 14:28
N042136-61	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-61	10/21/16 05:44	12/5/16 16:30
N042136-62	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-62	10/21/16 05:44	12/5/16 16:32
N042136-64	Lead	EPA 200.8	270	0.50	ug/L	15	HS-01-BF-P-64	10/21/16 05:47	12/6/16 10:58
N042136-65	Lead	EPA 200.8	57.9	0.50	ug/L	15	HS-01-BF-P-65	10/21/16 05:47	12/6/16 11:05
N042136-66	Lead	EPA 200.8	252	0.50	ug/L	15	HS-01-BF-P-66	10/21/16 05:47	12/6/16 11:07
N042136-67	Lead	EPA 200.8	8.76	0.50	ug/L	15	HS-01-BF-P-67	10/21/16 05:50	12/5/16 16:35
N042136-68	Lead	EPA 200.8	5.07	0.50	ug/L	15	HS-01-BF-P-68	10/21/16 05:50	12/5/16 16:37
N042136-69	Lead	EPA 200.8	4.07	0.50	ug/L	15	HS-01-BF-P-69	10/21/16 05:50	12/5/16 16:39
N042136-71	Lead	EPA 200.8	0.82	0.50	ug/L	15	HS-01-CF-P-71	10/21/16 04:55	12/5/16 16:41
N042136-72	Lead	EPA 200.8	0.77	0.50	ug/L	15	HS-01-CF-P-72	10/21/16 04:55	12/5/16 16:44
N042136-73	Lead	EPA 200.8	2.75	0.50	ug/L	15	HS-01-CF-P-73	10/21/16 04:55	12/5/16 16:46
N042136-74	Lead	EPA 200.8	1.23	0.50	ug/L	15	HS-01-SF-P-74	10/21/16 04:56	12/5/16 16:48
N042136-75	Lead	EPA 200.8	1.56	0.50	ug/L	15	HS-01-CF-P-75	10/21/16 04:56	12/5/16 16:50
N042136-76	Lead	EPA 200.8	2.65	0.50	ug/L	15	HS-01-CF-P-76	10/21/16 04:58	12/5/16 17:02
N042136-77	Lead	EPA 200.8	7.42	0.50	ug/L	15	HS-01-CF-P-77	10/21/16 04:58	12/5/16 17:04
N042136-78	Lead	EPA 200.8	0.53	0.50	ug/L	15	HS-01-CF-P-78	10/21/16 04:58	12/5/16 17:06
N042136-79	Lead	EPA 200.8	4.35	0.50	ug/L	15	HS-01-CF-P-79	10/21/16 05:14	12/5/16 17:08
N042136-80	Lead	EPA 200.8	22.2	0.50	ug/L	15	HS-01-CF-P-80	10/21/16 05:00	12/5/16 17:11
N042136-81	Lead	EPA 200.8	2.87	0.50	ug/L	15	HS-01-CF-P-81	10/21/16 05:00	12/5/16 17:13
N042136-82	Lead	EPA 200.8	5.08	0.50	ug/L	15	HS-01-BF-P-82	10/21/16 05:00	12/5/16 17:15
N042136-83	Lead	EPA 200.8	1.51	0.50	ug/L	15	HS-01-CF-P-83	10/21/16 05:05	12/5/16 17:17
N042136-84	Lead	EPA 200.8	1.97	0.50	ug/L	15	HS-01-CF-P-84	10/21/16 05:05	12/5/16 17:22
N042136-85	Lead	EPA 200.8	4.29	0.50	ug/L	15	HS-01-CF-P-85	10/21/16 05:05	12/5/16 17:24
N042136-86	Lead	EPA 200.8	121	0.50	ug/L	15	HS-01-CF-P-86	10/21/16 05:06	12/5/16 17:36
N042136-87	Lead	EPA 200.8	41.0	0.50	ug/L	15	HS-01-CF-P-87	10/21/16 05:06	12/5/16 17:38
N042136-88	Lead	EPA 200.8	415	0.50	ug/L	15	HS-01-CF-P-88	10/21/16 05:06	12/6/16 11:10
N042136-89	Lead	EPA 200.8	61.2	0.50	ug/L	15	HS-01-CF-P-89	10/21/16 05:06	12/5/16 17:40
N042136-90	Lead	EPA 200.8	1.49	0.50	ug/L	15	HS-01-BF-P-90	10/21/16 05:11	12/5/16 17:42
N042136-91	Lead	EPA 200.8	6.90	0.50	ug/L	15	HS-01-BF-P-91	10/21/16 05:12	12/5/16 17:45
N042136-92	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-CF-P-92	10/21/16 05:12	12/5/16 17:47
N042136-94	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-94	10/21/16 05:17	12/5/16 17:49



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-95	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-95	10/21/16 05:17	12/5/16 17:51
N042136-96	Lead	EPA 200.8	1.62	0.50	ug/L	15	HS-01-BF-P-96	10/21/16 05:17	12/5/16 17:54
N042136-97	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-97	10/21/16 05:19	12/5/16 17:56
N042136-98	Lead	EPA 200.8	1.00	0.50	ug/L	15	HS-01-BF-P-98	10/21/16 05:20	12/5/16 18:07
N042136-99	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-99	10/21/16 05:20	12/5/16 18:10
N042136-AA	Lead	EPA 200.8	0.54	0.50	ug/L	15	HS-01-BF-P-100	10/21/16 05:20	12/5/16 18:12
N042136-AB	Lead	EPA 200.8	2.03	0.50	ug/L	15	HS-01-BF-P-101	10/21/16 05:20	12/5/16 18:14
N042136-AC	Lead	EPA 200.8	2.16	0.50	ug/L	15	HS-01-SF-P-102	10/21/16 05:22	12/5/16 18:19
N042136-AD	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-SF-P-103	10/21/16 05:22	12/5/16 18:21
N042136-AE	Lead	EPA 200.8	0.63	0.50	ug/L	15	HS-01-SF-P-104	10/21/16 05:22	12/5/16 18:23
N042136-AF	Lead	EPA 200.8	0.71	0.50	ug/L	15	HS-01-SF-P-105	10/21/16 05:22	12/5/16 18:25
N042136-AG	Lead	EPA 200.8	1.06	0.50	ug/L	15	HS-01-DF-P-106	10/21/16 05:23	12/5/16 18:28
N042136-AH	Lead	EPA 200.8	2.60	0.50	ug/L	15	HS-01-SF-P-107	10/21/16 05:25	12/5/16 18:30
N042136-AI	Lead	EPA 200.8	1.07	0.50	ug/L	15	HS-01-SF-P-108	10/21/16 05:25	12/1/16 12:36
N042136-AJ	Lead	EPA 200.8	1.68	0.50	ug/L	15	HS-01-SF-P-109	10/21/16 05:25	12/1/16 12:39
N042136-AK	Lead	EPA 200.8	3.94	0.50	ug/L	15	HS-01-SF-P-110	10/21/16 05:25	12/1/16 12:41
N042136-AL	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-111	10/21/16 05:26	12/1/16 12:44
N042136-AM	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-112	10/21/16 05:28	12/1/16 12:46
N042136-AN	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-113	10/21/16 05:28	12/1/16 12:48
N042136-AO	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-SF-P-114	10/21/16 05:30	12/1/16 12:51
N042136-AP	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-IM-P-115	10/21/16 05:35	12/1/16 12:53
N042136-AQ	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-116	10/21/16 05:34	12/1/16 12:55
N042136-AR	Lead	EPA 200.8	7.62	0.50	ug/L	15	HS-01-SF-P-117	10/21/16 05:36	12/1/16 12:58
N042136-AS	Lead	EPA 200.8	3.88	0.50	ug/L	15	HS-01-SF-P-118	10/21/16 05:36	12/1/16 13:41
N042136-AT	Lead	EPA 200.8	3.36	0.50	ug/L	15	HS-01-SF-P-119	10/21/16 05:36	12/1/16 13:44
N042136-AU	Lead	EPA 200.8	7.28	0.50	ug/L	15	HS-01-SF-P-120	10/21/16 05:36	12/1/16 13:46
N042136-AV	Lead	EPA 200.8	4.84	0.50	ug/L	15	HS-01-SF-P-121	10/21/16 05:39	11/30/16 16:21
N042136-AW	Lead	EPA 200.8	0.76	0.50	ug/L	15	HS-01-SF-P-122	10/21/16 05:39	11/30/16 16:23
N042136-AX	Lead	EPA 200.8	0.98	0.50	ug/L	15	HS-01-SF-P-123	10/21/16 05:39	11/30/16 16:25
N042136-AY	Lead	EPA 200.8	5.01	0.50	ug/L	15	HS-01-SF-P-124	10/21/16 05:39	11/30/16 16:27
N042136-AZ	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-125	10/21/16 05:39	11/30/16 16:29
N042136-BA	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-126	10/21/16 05:40	11/30/16 16:31

New Jersey Analytical Laboratories

The  
 cus.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-BB	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-DW-P-127	10/21/16 05:46	11/30/16 16:34
N042136-BC	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-Outside-BF-P-128	10/21/16 05:45	11/30/16 16:36
N042136-BD	Lead	EPA 200.8	0.97	0.50	ug/L	15	HS-Outside-BF-P-129	10/21/16 05:45	11/30/16 16:38
N042136-BE	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-Outside-BF-P-130	10/21/16 05:45	11/30/16 16:40
N042136-BF	Lead	EPA 200.8	10.2	0.50	ug/L	15	HS-Concession-SF-P-131	10/21/16 05:47	11/30/16 16:51
N042136-BG	Lead	EPA 200.8	1.44	0.50	ug/L	15	HS-02-BF-P-132	10/21/16 04:57	11/30/16 16:54
N042136-BH	Lead	EPA 200.8	1.89	0.50	ug/L	15	HS-02-BF-P-133	10/21/16 04:57	11/30/16 16:56
N042136-BI	Lead	EPA 200.8	2.04	0.50	ug/L	15	HS-02-BF-P-134	10/21/16 06:15	11/30/16 16:58
N042136-BJ	Lead	EPA 200.8	2.78	0.50	ug/L	15	HS-02-BF-P-135	10/21/16 06:15	11/30/16 17:00
N042136-BK	Lead	EPA 200.8	4.18	0.50	ug/L	15	HS-02-BF-P-136	10/21/16 04:58	11/30/16 17:02
N042136-BL	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-BF-P-137	10/21/16 04:58	11/30/16 17:04
N042136-BM	Lead	EPA 200.8	0.98	0.50	ug/L	15	HS-02-BF-P-138	10/21/16 04:58	11/30/16 17:07
N042136-BN	Lead	EPA 200.8	3.16	0.50	ug/L	15	HS-02-BF-P-139	10/21/16 04:58	11/30/16 17:11
N042136-BO	Lead	EPA 200.8	2.95	0.50	ug/L	15	HS-02-BF-P-140	10/21/16 05:00	11/30/16 17:13
N042136-BP	Lead	EPA 200.8	1.08	0.50	ug/L	15	HS-02-CF-P-141	10/21/16 05:02	11/30/16 17:54
N042136-BQ	Lead	EPA 200.8	0.91	0.50	ug/L	15	HS-02-CF-P-142	10/21/16 05:02	11/30/16 17:56
N042136-BT	Lead	EPA 200.8	2.42	0.50	ug/L	15	HS-02-CF-P-145	10/21/16 05:03	11/30/16 17:59
N042136-BU	Lead	EPA 200.8	57.8	0.50	ug/L	15	HS-02-CF-P-146	10/21/16 05:05	11/30/16 18:01
N042136-BV	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-DW-P-147	10/21/16 05:06	11/30/16 18:03
N042136-BW	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-DW-P-148	10/21/16 05:06	11/30/16 18:05
N042136-BX	Lead	EPA 200.8	2.17	0.50	ug/L	15	HS-02-BF-P-149	10/21/16 05:07	11/30/16 18:07
N042136-BY	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-CF-P-150	10/21/16 05:08	11/30/16 18:10
N042136-BZ	Lead	EPA 200.8	2.27	0.50	ug/L	15	HS-02-CF-P-151	10/21/16 05:11	11/30/16 18:12
N042136-CA	Lead	EPA 200.8	6.87	0.50	ug/L	15	HS-02-CF-P-152	10/21/16 05:11	11/30/16 18:14
N042136-CB	Lead	EPA 200.8	9.91	0.50	ug/L	15	HS-02-CF-P-153	10/21/16 05:11	11/30/16 18:25
N042136-CC	Lead	EPA 200.8	6.85	0.50	ug/L	15	HS-02-CF-P-154	10/21/16 05:11	11/30/16 18:27
N042136-CD	Lead	EPA 200.8	5.73	0.50	ug/L	15	HS-02-CF-P-155	10/21/16 05:11	11/30/16 18:29
N042136-CE	Lead	EPA 200.8	14.0	0.50	ug/L	15	HS-02-CF-P-156	10/21/16 05:11	11/30/16 18:32
N042136-CF	Lead	EPA 200.8	17.7	0.50	ug/L	15	HS-02-CF-P-157	10/21/16 05:18	11/30/16 18:34
N042136-CG	Lead	EPA 200.8	9.59	0.50	ug/L	15	HS-02-SF-P-158	10/21/16 05:14	11/30/16 18:36
N042136-CH	Lead	EPA 200.8	4.17	0.50	ug/L	15	HS-02-CF-P-159	10/21/16 05:17	11/30/16 18:38
N042136-CI	Lead	EPA 200.8	25.0	0.50	ug/L	15	HS-02-CF-P-160	10/21/16 05:17	11/30/16 18:40



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-CJ	Lead	EPA 200.8	7.18	0.50	ug/L	15	HS-02-CF-P-161	10/21/16 05:17	11/30/16 18:45
N042136-CK	Lead	EPA 200.8	12.0	0.50	ug/L	15	HS-02-CF-P-162	10/21/16 05:17	11/30/16 18:47
N042136-CL	Lead	EPA 200.8	12.5	0.50	ug/L	15	HS-02-CF-P-163	10/21/16 05:17	11/30/16 18:58
N042136-CM	Lead	EPA 200.8	43.3	0.50	ug/L	15	HS-02-CF-P-164	10/21/16 05:17	11/30/16 19:01
N042136-CN	Lead	EPA 200.8	1.40	0.50	ug/L	15	HS-02-BF-P-165	10/21/16 05:22	11/30/16 19:03
N042136-CO	Lead	EPA 200.8	1.62	0.50	ug/L	15	HS-02-BF-P-166	10/21/16 05:22	11/30/16 19:05
N042136-CP	Lead	EPA 200.8	0.52	0.50	ug/L	15	HS-02-BF-P-167	10/21/16 05:22	11/30/16 19:07
N042136-CQ	Lead	EPA 200.8	4.79	0.50	ug/L	15	HS-02-BF-P-168	10/21/16 05:22	11/30/16 19:09
N042136-CR	Lead	EPA 200.8	11.2	0.50	ug/L	15	HS-02-BF-P-169	10/21/16 05:24	11/30/16 19:12
N042136-CS	Lead	EPA 200.8	2.60	0.50	ug/L	15	HS-02-BF-P-170	10/21/16 05:24	11/30/16 19:14
N042136-CT	Lead	EPA 200.8	35.8	0.50	ug/L	15	HS-02-BF-P-171	10/21/16 05:24	11/30/16 19:16
N042136-CU	Lead	EPA 200.8	11.9	0.50	ug/L	15	HS-02-BF-P-172	10/21/16 05:24	11/30/16 19:18
N042136-CV	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-DW-P-173	10/21/16 05:29	11/30/16 19:29
N042136-CW	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-DW-P-174	10/21/16 05:29	11/30/16 19:32
N042136-CX	Lead	EPA 200.8	9.14	0.50	ug/L	15	HS-02-CF-P-175	10/21/16 05:32	11/30/16 19:34
N042136-CY	Lead	EPA 200.8	26.2	0.50	ug/L	15	HS-02-CF-P-176	10/21/16 05:32	11/30/16 19:36
N042136-CZ	Lead	EPA 200.8	12.7	0.50	ug/L	15	HS-02-CF-P-177	10/21/16 05:32	11/30/16 19:41
N042136-DA	Lead	EPA 200.8	6.10	0.50	ug/L	15	HS-02-CF-P-178	10/21/16 05:32	11/30/16 19:43
N042136-DB	Lead	EPA 200.8	17.4	0.50	ug/L	15	HS-02-CF-P-179	10/21/16 05:32	11/30/16 19:45
N042136-DC	Lead	EPA 200.8	12.6	0.50	ug/L	15	HS-02-CF-P-180	10/21/16 05:32	12/1/16 13:49
N042136-DD	Lead	EPA 200.8	10.1	0.50	ug/L	15	HS-02-CF-P-181	10/21/16 05:32	12/1/16 13:51
N042136-DE	Lead	EPA 200.8	12.3	0.50	ug/L	15	HS-02-CF-P-182	10/21/16 05:32	12/1/16 13:53
N042136-DF	Lead	EPA 200.8	6.45	0.50	ug/L	15	HS-02-SF-P-183	10/21/16 05:35	12/1/16 13:56
N042136-DG	Lead	EPA 200.8	8.71	0.50	ug/L	15	HS-02-CF-P-184	10/21/16 05:37	12/1/16 13:58
N042136-DH	Lead	EPA 200.8	8.44	0.50	ug/L	15	HS-02-CF-P-185	10/21/16 05:37	12/1/16 14:00
N042136-DI	Lead	EPA 200.8	8.41	0.50	ug/L	15	HS-02-CF-P-186	10/21/16 05:37	12/1/16 14:03
N042136-DJ	Lead	EPA 200.8	10.9	0.50	ug/L	15	HS-02-CF-P-187	10/21/16 05:37	12/1/16 14:15
N042136-DK	Lead	EPA 200.8	5.51	0.50	ug/L	15	HS-02-CF-P-188	10/21/16 05:37	12/1/16 14:17
N042136-DL	Lead	EPA 200.8	13.9	0.50	ug/L	15	HS-02-CF-P-189	10/21/16 05:37	12/1/16 14:19
N042136-DM	Lead	EPA 200.8	13.7	0.50	ug/L	15	HS-02-CF-P-190	10/21/16 05:37	12/1/16 14:22
N042136-DN	Lead	EPA 200.8	30.3	0.50	ug/L	15	HS-02-CF-P-191	10/21/16 05:37	12/1/16 14:25
N042136-DO	Lead	EPA 200.8	18.9	0.50	ug/L	15	HS-02-CF-P-192	10/21/16 05:37	12/1/16 14:27

New Jersey Analytical Laboratories

The  
 cus.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)


**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-DP	Lead	EPA 200.8	20.4	0.50	ug/L	15	HS-02-CF-P-193	10/21/16 05:41	12/1/16 14:30
N042136-DQ	Lead	EPA 200.8	97.7	0.50	ug/L	15	HS-02-CF-P-194	10/21/16 05:41	12/6/16 11:12
N042136-DR	Lead	EPA 200.8	20.0	0.50	ug/L	15	HS-02-CF-P-195	10/21/16 05:41	12/1/16 14:32
N042136-DS	Lead	EPA 200.8	15.2	0.50	ug/L	15	HS-02-CF-P-196	10/21/16 05:41	12/1/16 14:37
N042136-DT	Lead	EPA 200.8	14.3	0.50	ug/L	15	HS-02-CF-P-197	10/21/16 05:41	12/1/16 14:39
N042136-DU	Lead	EPA 200.8	18.0	0.50	ug/L	15	HS-02-CF-P-198	10/21/16 05:41	12/1/16 14:51
N042136-DV	Lead	EPA 200.8	12.9	0.50	ug/L	15	HS-02-CF-P-199	10/21/16 05:41	12/1/16 14:54
N042136-DW	Lead	EPA 200.8	9.27	0.50	ug/L	15	HS-02-SF-P-200	10/21/16 05:44	12/1/16 14:56
N042136-DX	Lead	EPA 200.8	16.9	0.50	ug/L	15	HS-02-CF-P-201	10/21/16 05:47	12/1/16 14:58
N042136-DY	Lead	EPA 200.8	16.7	0.50	ug/L	15	HS-02-CF-P-202	10/21/16 05:47	12/1/16 15:01
N042136-DZ	Lead	EPA 200.8	19.7	0.50	ug/L	15	HS-02-CF-P-203	10/21/16 05:47	12/1/16 15:03
N042136-EA	Lead	EPA 200.8	11.2	0.50	ug/L	15	HS-02-CF-P-204	10/21/16 05:47	12/1/16 15:06
N042136-EB	Lead	EPA 200.8	8.82	0.50	ug/L	15	HS-02-CF-P-205	10/21/16 05:47	12/1/16 15:08
N042136-EC	Lead	EPA 200.8	12.2	0.50	ug/L	15	HS-02-CF-P-206	10/21/16 05:47	12/1/16 15:10
N042136-ED	Lead	EPA 200.8	28.8	0.50	ug/L	15	HS-02-CF-P-207	10/21/16 05:47	12/1/16 15:13
N042136-EF	Lead	EPA 200.8	10.1	0.50	ug/L	15	HS-02-CF-P-209	10/21/16 05:52	12/1/16 15:25
N042136-EG	Lead	EPA 200.8	34.5	0.50	ug/L	15	HS-02-CF-P-210	10/21/16 05:52	12/1/16 15:27
N042136-EH	Lead	EPA 200.8	11.6	0.50	ug/L	15	HS-02-CF-P-211	10/21/16 05:52	12/1/16 15:29
N042136-EI	Lead	EPA 200.8	12.7	0.50	ug/L	15	HS-02-CF-P-212	10/21/16 05:52	12/1/16 15:32
N042136-EJ	Lead	EPA 200.8	11.1	0.50	ug/L	15	HS-02-CF-P-213	10/21/16 05:52	12/1/16 15:37
N042136-EK	Lead	EPA 200.8	67.0	0.50	ug/L	15	HS-02-CF-P-214	10/21/16 05:52	12/1/16 15:39
N042136-EL	Lead	EPA 200.8	4.09	0.50	ug/L	15	HS-02-CF-P-215	10/21/16 05:52	12/1/16 15:41
N042136-EM	Lead	EPA 200.8	12.3	0.50	ug/L	15	HS-02-SF-P-216	10/21/16 05:54	12/1/16 15:44
N042136-EO	Lead	EPA 200.8	3.50	0.50	ug/L	15	HS-02-CF-P-218	10/21/16 05:56	12/1/16 15:46
N042136-EP	Lead	EPA 200.8	3.93	0.50	ug/L	15	HS-02-CF-P-219	10/21/16 05:56	12/1/16 15:49
N042136-EQ	Lead	EPA 200.8	4.17	0.50	ug/L	15	HS-02-CF-P-220	10/21/16 05:56	12/1/16 16:36
N042136-ER	Lead	EPA 200.8	4.47	0.50	ug/L	15	HS-02-CF-P-221	10/21/16 05:56	12/1/16 16:39
N042136-ES	Lead	EPA 200.8	86.8	0.50	ug/L	15	HS-02-CF-P-222	10/21/16 05:56	12/1/16 16:41
N042136-ET	Lead	EPA 200.8	62.9	0.50	ug/L	15	HS-02-CF-P-223	10/21/16 05:56	12/1/16 16:44
N042136-EV	Lead	EPA 200.8	215	0.50	ug/L	15	HS-02-CF-P-225	10/21/16 06:01	12/1/16 16:46
N042136-EW	Lead	EPA 200.8	18.0	0.50	ug/L	15	HS-02-SF-P-226	10/21/16 06:01	12/1/16 16:49
N042136-EX	Lead	EPA 200.8	3.53	0.50	ug/L	15	HS-02-CF-P-227	10/21/16 06:01	12/1/16 16:52



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/28/16 16:00

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N042136-EY	Lead	EPA 200.8	4.97	0.50	ug/L	15	HS-02-CF-P-228	10/21/16 06:01	12/1/16 16:54
N042136-EZ	Lead	EPA 200.8	4.68	0.50	ug/L	15	HS-02-CF-P-229	10/21/16 06:01	12/1/16 16:56
N042136-FA	Lead	EPA 200.8	2.88	0.50	ug/L	15	HS-02-CF-P-230	10/21/16 06:01	12/1/16 16:59
N042136-FB	Lead	EPA 200.8	6.06	0.50	ug/L	15	HS-02-CF-P-231	10/21/16 06:01	12/1/16 17:11
N042136-FC	Lead	EPA 200.8	4.23	0.50	ug/L	15	HS-02-CF-P-232	10/21/16 06:01	12/1/16 17:13
N042136-FD	Lead	EPA 200.8	39.1	0.50	ug/L	15	HS-02-CF-P-233	10/21/16 06:01	12/1/16 17:16
N042136-FE	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-02-BF-P-234	10/21/16 06:03	12/1/16 17:18
N042136-FF	Lead	EPA 200.8	4.02	0.50	ug/L	15	HS-01-DW-P-17a	10/21/16 05:26	12/1/16 17:20
N042136-FG	Lead	EPA 200.8	ND	0.50	ug/L	15	HS-01-BF-P-36a	10/21/16 06:08	12/1/16 17:23

<b>HIGH SCHOOL - RESULTS</b>		<b>TEST</b>	<b>COPPER RESULTS</b>
<b>SAMPLE #</b>	<b>ROOM #</b>		
#1	NO42136 (64)	COPPER	BOYS GANG BATHROOM FAUCET BY RECEIVING DOOR
#2	NO42136 (66)	COPPER	BOYS GANG BATHROOM FAUCET BY RECEIVING DOOR
#3	NO42136 (87)	COPPER	206 - CLASSROOM FAUCET
#4	NO42136 (88)	COPPER	206 - CLASSROOM FAUCET - FUME HOOD
#5	NO42136 (CI)	COPPER	621 - CLASSROOM FAUCET
#6	NO42136 (DQ)	COPPER	627 - CLASSROOM FAUCET
#7	NO42136 (EV)	COPPER	626 - CLASSROOM FAUCET
<b>HIGH SCHOOL - RESULTS</b>		<b>TEST</b>	<b>LEAD RESULTS</b>
<b>SAMPLE #</b>	<b>ROOM #</b>		
#1	NO42136 (10)	LEAD	[REDACTED]
#2	NO42136 (53)	LEAD	D.O. MENS BATHROOM FAUCET
#3	NO42136 (64)	LEAD	BOYS GANG BATHROOM FAUCET BY RECEIVING DOOR
#4	NO42136 (65)	LEAD	BOYS GANG BATHROOM FAUCET BY RECEIVING DOOR
#5	NO42136 (66)	LEAD	BOYS GANG BATHROOM FAUCET BY RECEIVING DOOR
#6	NO42136 (80)	LEAD	204 CLASSROOM FAUCET - SCIENCE
#7	NO42136 (86)	LEAD	206 CLASSROOM FAUCET - SCIENCE
#8	NO42136 (87)	LEAD	206 CLASSROOM FAUCET - SCIENCE
#9	NO42136 (88)	LEAD	206 CLASSROOM FAUCET - SCIENCE - FUME HOOD
#10	NO42136 (89)	LEAD	206 CLASSROOM FAUCET - SCIENCE - LAB
#11	NO42136 (BU)	LEAD	604 CLASSROOM FAUCET
#12	NO42136 (CF)	LEAD	621 CLASSROOM FAUCET - SCIENCE
#13	NO42136 (CI)	LEAD	621 CLASSROOM FAUCET - SCIENCE
#14	NO42136 (CM)	LEAD	621 CLASSROOM FAUCET - SCIENCE
#15	NO42136 (CT)	LEAD	GIRLS BATHROOM FAUCET BY ROOM 623
#16	NO42136 (CV)	LEAD	623 - CLASSROOM FAUCET - SCIENCE



#17	NO42136 (DB)	LEAD	623 - CLASSROOM FAUCET - SCIENCE
#18	NO42136 (DN)	LEAD	625 - CLASSROOM FAUCET - SCIENCE
#19	NO42136 (DO)	LEAD	625 - CLASSROOM FAUCET - SCIENCE
#20	NO42136 (DP)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#21	NO42136 (DQ)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#22	NO42136 (DR)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#23	NO42136 (DS)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#24	NO42136 (DT)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#25	NO42136 (DU)	LEAD	627 - CLASSROOM FAUCET - SCIENCE
#26	NO42136 (DX)	LEAD	629 - CLASSROOM FAUCET - SCIENCE
#27	NO42136 (DY)	LEAD	629 - CLASSROOM FAUCET - SCIENCE
#28	NO42136 (DZ)	LEAD	629 - CLASSROOM FAUCET - SCIENCE
#29	NO42136 (ED)	LEAD	629 - CLASSROOM FAUCET - SCIENCE
#30	NO42136 (EG)	LEAD	628 - CLASSROOM FAUCET - SCIENCE
#31	NO42136 (EK)	LEAD	628 - CLASSROOM FAUCET - SCIENCE
#32	NO42136 (ES)	LEAD	626 - CLASSROOM FAUCET - SCIENCE
#33	NO42136 (ET)	LEAD	626 - CLASSROOM FAUCET - SCIENCE
#34	NO42136 (EV)	LEAD	626 - CLASSROOM FAUCET - SCIENCE
#35	NO42136 (EW)	LEAD	PREP ROOM FOR ROOMS 624-626 SINK FAUCETS - SCIENCE
#36	NO42136 (FD)	LEAD	624 - CLASSROOM FAUCET - SCIENCE