

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
HS-01-IM-P-02	Kitchen	Ice Machine	4/30/2021 04:47	5/7/2021 16:28	70171419001	Lead	<1.0	15	ug/L	
HS-01-KF-P-03	Kitchen - Food Prep Center	Kitchen Faucet	4/30/2021 04:47	5/7/2021 16:28	70171419002	Lead	1.1	15	ug/L	
HS-01-KF-P-04	Kitchen - Kettle	Kitchen Faucet	4/30/2021 04:48	5/7/2021 16:28	70171419003	Lead	10.6	15	ug/L	
HS-01-BF-P-05	Kitchen Locker Room - L	Bathroom Faucet	4/30/2021 04:48	5/7/2021 16:28	70171419004	Lead	<1.0	15	ug/L	
HS-01-BF-P-06	Kitchen Locker Room - R	Bathroom Faucet	4/30/2021 04:49	5/7/2021 16:25	70171419005	Lead	<1.0	15	ug/L	
HS-01-SF-P-09	Café Snack Bar	Sink Faucet	4/30/2021 04:51	5/7/2021 16:25	70171419006	Lead	1.4	15	ug/L	
HS-01-DW-P-11	102 Corridor Bottle Filler	Bottle Filler	4/30/2021 04:52	5/7/2021 16:26	70171419007	Lead	<1.0	15	ug/L	
HS-01-CF-P-12	107	Classroom Faucet	4/30/2021 04:53	5/7/2021 16:27	70171419008	Lead	<1.0	15	ug/L	
HS-01-CF-P-13	108	Classroom Faucet	4/30/2021 04:53	5/7/2021 16:28	70171419009	Lead	<1.0	15	ug/L	
HS-01-SF-P-14	101C	Sink Faucet	4/30/2021 04:54	5/7/2021 16:28	70171419010	Lead	1.4	15	ug/L	
HS-01-SF-P-15	101D	Sink Faucet	4/30/2021 04:54	5/7/2021 16:23	70171419011	Lead	<1.0	15	ug/L	
HS-01-DW-P-17	Bottle Filler by Counseling	Bottle Filler	4/30/2021 04:55	5/7/2021 16:23	70171419012	Lead	<1.0	15	ug/L	
HS-01-SF-P-18	Counseling	Sink Faucet	4/30/2021 04:55	5/7/2021 16:26	70171419013	Lead	<1.0	15	ug/L	
HS-01-SF-P-19	Library Office	Sink Faucet	4/30/2021 04:57	5/7/2021 16:27	70171419014	Lead	<1.0	15	ug/L	
HS-01-BF-P-20	Main Office Bathroom	Bathroom Faucet	4/30/2021 04:59	5/7/2021 16:28	70171419015	Lead	2.3	15	ug/L	
HS-01-BF-P-22	Copy Room Bathroom	Bathroom Faucet	4/30/2021 05:00	5/7/2021 16:28	70171419016	Lead	4.6	15	ug/L	
HS-01-NF-P-23	Health Office - Main Area	Sink Faucet	4/30/2021 05:01	5/7/2021 16:28	70171419017	Lead	<1.0	15	ug/L	
HS-01-NF-P-24	Health Office - Office	Sink Faucet	4/30/2021 05:01	5/7/2021 16:23	70171419018	Lead	2.2	15	ug/L	
HS-01-BF-P-25	Health Office	Bathroom Faucet	4/30/2021 05:01	5/7/2021 16:28	70171419019	Lead	14.9	15	ug/L	
HS-01-IM-P-26	Health Office	Ice Machine	4/30/2021 05:01	5/7/2021 16:25	70171419020	Lead	<1.0	15	ug/L	
HS-01-BF-P-29	Business Office Bathroom	Bathroom Faucet	4/30/2021 05:07	5/7/2021 16:25	70171419021	Lead	<1.0	15	ug/L	
HS-01-BF-P-30	DO Men's Room - L	Bathroom Faucet	4/30/2021 05:10	5/7/2021 16:28	70171419022	Lead	7.6	15	ug/L	
HS-01-BF-P-32	DO Women's Room - L	Bathroom Faucet	4/30/2021 05:12	5/7/2021 16:23	70171419023	Lead	2.0	15	ug/L	
HS-01-BF-P-33	DO Women's Room - R	Bathroom Faucet	4/30/2021 05:12	5/7/2021 16:23	70171419024	Lead	1.1	15	ug/L	
HS-01-SF-P-34	District Office Break Room	Sink Faucet	4/30/2021 05:12	5/7/2021 16:25	70171419025	Lead	2.1	15	ug/L	
HS-01-CF-P-35	227	Classroom Faucet	4/30/2021 05:16	5/7/2021 16:26	70171419026	Lead	<1.0	15	ug/L	
HS-01-BF-P-36	227	Bathroom Faucet	4/30/2021 05:16	5/7/2021 16:27	70171419027	Lead	<1.0	15	ug/L	
HS-01-BF-P-37	1st FL Faculty Restroom by Elevator	Bathroom Faucet	4/30/2021 05:18	5/7/2021 16:28	70171419028	Lead	<1.0	15	ug/L	
HS-01-SF-P-38	Faculty Lounge	Sink Faucet	4/30/2021 05:18	5/7/2021 16:28	70171419029	Lead	<1.0	15	ug/L	
HS-01-BF-P-39	Faculty Lounge L Bathroom	Bathroom Faucet	4/30/2021 05:18	5/7/2021 17:20	70171419030	Lead	<1.0	15	ug/L	
HS-01-BF-P-40	Faculty Lounge R Bathroom	Bathroom Faucet	4/30/2021 05:18	5/7/2021 17:21	70171419031	Lead	<1.0	15	ug/L	
HS-01-SF-P-41	Custodial Office	Sink Faucet	4/30/2021 05:20	5/7/2021 17:23	70171419032	Lead	<1.0	15	ug/L	
HS-01-CF-P-42	202 Utility Sink	Sink Faucet	4/30/2021 05:20	5/7/2021 17:26	70171419033	Lead	<1.0	15	ug/L	
HS-01-BF-P-43	206/207 Faculty Restroom	Bathroom Faucet	4/30/2021 05:21	5/7/2021 17:27	70171419034	Lead	2.8	15	ug/L	
HS-01-BF-P-44	Faculty Restroom by Gym	Bathroom Faucet	4/30/2021 05:22	5/7/2021 17:28	70171419035	Lead	<1.0	15	ug/L	
HS-01-BF-P-45	Girl's Coaches Restroom	Bathroom Faucet	4/30/2021 05:25	5/7/2021 17:28	70171419036	Lead	<1.0	15	ug/L	
HS-01-DW-P-48	Bottle Filler by Concession	Bottle Filler	4/30/2021 05:25	5/7/2021 17:41	70171419037	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
HS-01-SF-P-49	Concession by Gym	Sink Faucet	4/30/2021 05:26	5/7/2021 17:12	70171419038	Lead	17.1	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
HS-01-BF-P-51	Trainer's Office	Bathroom Faucet	4/30/2021 05:27	5/7/2021 17:12	70171419039	Lead	2.2	15	ug/L	
HS-01-BF-P-53	Boy's Coaches Office	Bathroom Faucet	4/30/2021 05:28	5/7/2021 17:12	70171419040	Lead	<1.0	15	ug/L	
HS-02-BF-P-59	Faculty Restroom by 601	Bathroom Faucet	4/30/2021 05:32	5/7/2021 17:12	70171419041	Lead	2.2	15	ug/L	
HS-02-CF-P-60	600 - L	Classroom Faucet	4/30/2021 05:32	5/7/2021 17:12	70171419042	Lead	7.7	15	ug/L	
HS-02-CF-P-61	600 - R	Classroom Faucet	4/30/2021 05:37	5/7/2021 17:22	70171419043	Lead	3.1	15	ug/L	
HS-02-CF-P-62	602	Classroom Faucet	4/30/2021 05:37	5/7/2021 17:22	70171419044	Lead	3.8	15	ug/L	
HS-02-DW-P-64	Bottle Filler by 605	Water Fountain	4/30/2021 05:37	5/7/2021 17:22	70171419045	Lead	<1.0	15	ug/L	
HS-02-BF-P-65	Faculty Restroom by 612	Bathroom Faucet	4/30/2021 05:38	5/7/2021 17:24	70171419046	Lead	1.7	15	ug/L	
HS-02-DW-P-67	Bottle Filler by 623	Bottle Filler	4/30/2021 05:38	5/7/2021 17:25	70171419047	Lead	<1.0	15	ug/L	
HS-02-BF-P-68	Faculty Restroom by Elevator	Bathroom Faucet	4/30/2021 05:33	5/7/2021 17:26	70171419048	Lead	<1.0	15	ug/L	
HS-01-KF-P-69	Kitchen - Sink - Corridor Wall - L	Kitchen Faucet	4/30/2021 04:49	5/7/2021 17:28	70171419049	Lead	2.7	15	ug/L	
HS-01-KF-P-70	Kitchen - Sink - Corridor Wall - R	Kitchen Faucet	4/30/2021 04:49	5/7/2021 17:28	70171419050	Lead	<1.0	15	ug/L	
HS-01-SF-P-71	Main Office Kitchen Sink	Sink Faucet	4/30/2021 05:03	5/7/2021 17:21	70171419051	Lead	<1.0	15	ug/L	
HS-01-DW-P-72	Bottle Filler by 305	Bottle Filler	4/30/2021 05:14	5/7/2021 17:25	70171419052	Lead	<1.0	15	ug/L	
HS-01-BF-P-31	DO Men's Room - R	Bathroom Faucet	4/30/2021 05:10	5/7/2021 17:36	70171419053	Lead	487	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)

NYSDOH Action Level for Lead of 15