




NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-01	Copper	EPA 200.8	1200	2.00	ug/L	1300	Miller Hill Elementary School-01	10/1/16 07:00	12/7/16 17:33
N041221-02	Copper	EPA 200.8	608	2.00	ug/L	1300	Miller Hill Elementary School-02	10/1/16 07:00	12/7/16 17:34
N041221-04	Copper	EPA 200.8	914	2.00	ug/L	1300	Miller Hill Elementary School-04	10/1/16 07:00	12/7/16 17:36
N041221-05	Copper	EPA 200.8	308	2.00	ug/L	1300	Miller Hill Elementary School-05	10/1/16 07:01	12/7/16 17:38
N041221-06	Copper	EPA 200.8	331	2.00	ug/L	1300	Miller Hill Elementary School-06	10/1/16 07:01	12/7/16 17:40
N041221-07	Copper	EPA 200.8	435	2.00	ug/L	1300	Miller Hill Elementary School-07	10/1/16 07:00	12/7/16 17:42
N041221-08	Copper	EPA 200.8	331	2.00	ug/L	1300	Miller Hill Elementary School-08	10/1/16 07:00	12/7/16 17:44
N041221-09	Copper	EPA 200.8	344	2.00	ug/L	1300	Miller Hill Elementary School-09	10/1/16 07:02	12/7/16 17:46
N041221-10	Copper	EPA 200.8	317	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:02	12/7/16 17:48
N041221-11	Copper	EPA 200.8	589	2.00	ug/L	1300	Miller Hill Elementary School-11	10/1/16 07:03	12/7/16 17:50
N041221-12	Copper	EPA 200.8	508	2.00	ug/L	1300	Miller Hill Elementary School-12	10/1/16 07:03	12/7/16 18:00
N041221-13	Copper	EPA 200.8	637	2.00	ug/L	1300	Miller Hill Elementary School-13	10/1/16 07:02	12/7/16 18:02
N041221-14	Copper	EPA 200.8	676	2.00	ug/L	1300	Miller Hill Elementary School-14	10/1/16 07:02	12/7/16 18:04
N041221-15	Copper	EPA 200.8	648	2.00	ug/L	1300	Miller Hill Elementary School-15	10/1/16 07:02	12/7/16 18:06
N041221-16	Copper	EPA 200.8	511	2.00	ug/L	1300	Miller Hill Elementary School-16	10/1/16 07:05	12/7/16 18:08
N041221-17	Copper	EPA 200.8	9280	20.0	ug/L	1300	Miller Hill Elementary School-17	10/1/16 07:05	12/8/16 16:10
N041221-18	Copper	EPA 200.8	434	2.00	ug/L	1300	Miller Hill Elementary School-18	10/1/16 07:05	12/7/16 18:12
N041221-19	Copper	EPA 200.8	890	2.00	ug/L	1300	Miller Hill Elementary School-19	10/1/16 07:05	12/7/16 18:14
N041221-20	Copper	EPA 200.8	224	2.00	ug/L	1300	Miller Hill Elementary School-20	10/1/16 07:06	12/7/16 18:18
N041221-21	Copper	EPA 200.8	211	2.00	ug/L	1300	Miller Hill Elementary School-21	10/1/16 07:06	12/7/16 18:20
N041221-22	Copper	EPA 200.8	1100	2.00	ug/L	1300	Miller Hill Elementary School-22	10/1/16 07:06	12/7/16 18:30
N041221-23	Copper	EPA 200.8	845	2.00	ug/L	1300	Miller Hill Elementary School-23	10/1/16 07:06	12/7/16 18:32
N041221-24	Copper	EPA 200.8	964	2.00	ug/L	1300	Miller Hill Elementary School-24	10/1/16 07:08	12/7/16 18:34
N041221-25	Copper	EPA 200.8	469	2.00	ug/L	1300	Miller Hill Elementary School-25	10/1/16 07:06	12/7/16 18:36
N041221-26	Copper	EPA 200.8	681	2.00	ug/L	1300	Miller Hill Elementary School-26	10/1/16 07:09	12/7/16 18:38
N041221-27	Copper	EPA 200.8	779	2.00	ug/L	1300	Miller Hill Elementary School-27	10/1/16 07:09	12/7/16 18:40
N041221-28	Copper	EPA 200.8	1280	2.00	ug/L	1300	Miller Hill Elementary School-28	10/1/16 07:09	12/7/16 18:42
N041221-29	Copper	EPA 200.8	482	2.00	ug/L	1300	Miller Hill Elementary School-29	10/1/16 07:09	12/7/16 18:44
N041221-30	Copper	EPA 200.8	336	2.00	ug/L	1300	Miller Hill Elementary School-30	10/1/16 07:11	12/7/16 18:46
N041221-32	Copper	EPA 200.8	576	2.00	ug/L	1300	Miller Hill Elementary School-32	10/1/16 07:11	12/7/16 18:48
N041221-34	Copper	EPA 200.8	548	2.00	ug/L	1300	Miller Hill Elementary School-34	10/1/16 07:12	12/7/16 18:58
N041221-35	Copper	EPA 200.8	450	2.00	ug/L	1300	Miller Hill Elementary School-35	10/1/16 07:12	12/7/16 19:00



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-36	Copper	EPA 200.8	259	2.00	ug/L	1300	Miller Hill Elementary School-36	10/1/16 07:13	12/7/16 19:02
N041221-37	Copper	EPA 200.8	242	2.00	ug/L	1300	Miller Hill Elementary School-37	10/1/16 07:13	12/7/16 19:04
N041221-38	Copper	EPA 200.8	628	2.00	ug/L	1300	Miller Hill Elementary School-38	10/1/16 07:15	12/7/16 19:08
N041221-39	Copper	EPA 200.8	416	2.00	ug/L	1300	Miller Hill Elementary School-39	10/1/16 07:15	12/7/16 19:10
N041221-40	Copper	EPA 200.8	515	2.00	ug/L	1300	Miller Hill Elementary School-40	10/1/16 07:16	12/7/16 19:12
N041221-41	Copper	EPA 200.8	594	2.00	ug/L	1300	Miller Hill Elementary School-41	10/1/16 07:17	12/7/16 19:14
N041221-42	Copper	EPA 200.8	325	2.00	ug/L	1300	Miller Hill Elementary School-42	10/1/16 07:17	12/7/16 19:16
N041221-43	Copper	EPA 200.8	446	2.00	ug/L	1300	Miller Hill Elementary School-43	10/1/16 07:18	12/7/16 19:18
N041221-44	Copper	EPA 200.8	312	2.00	ug/L	1300	Miller Hill Elementary School-44	10/1/16 07:18	12/7/16 19:29
N041221-45	Copper	EPA 200.8	821	2.00	ug/L	1300	Miller Hill Elementary School-45	10/1/16 07:07	12/7/16 19:31
N041221-46	Copper	EPA 200.8	512	2.00	ug/L	1300	Miller Hill Elementary School-46	10/1/16 07:18	12/7/16 19:32
N041221-47	Copper	EPA 200.8	332	2.00	ug/L	1300	Miller Hill Elementary School-47	10/1/16 07:19	12/7/16 19:34
N041221-48	Copper	EPA 200.8	357	2.00	ug/L	1300	Miller Hill Elementary School-48	10/1/16 07:19	12/7/16 19:36
N041221-49	Copper	EPA 200.8	758	2.00	ug/L	1300	Miller Hill Elementary School-49	10/1/16 07:19	12/7/16 19:38
N041221-50	Copper	EPA 200.8	450	2.00	ug/L	1300	Miller Hill Elementary School-50	10/1/16 07:19	12/7/16 19:41
N041221-51	Copper	EPA 200.8	940	2.00	ug/L	1300	Miller Hill Elementary School-51	10/1/16 07:19	12/7/16 19:43
N041221-52	Copper	EPA 200.8	580	2.00	ug/L	1300	Miller Hill Elementary School-52	10/1/16 07:20	12/7/16 19:45
N041221-53	Copper	EPA 200.8	370	2.00	ug/L	1300	Miller Hill Elementary School-53	10/1/16 07:20	12/7/16 19:47
N041221-54	Copper	EPA 200.8	247	2.00	ug/L	1300	Miller Hill Elementary School-54	10/1/16 07:41	12/7/16 19:59
N041221-55	Copper	EPA 200.8	505	2.00	ug/L	1300	Miller Hill Elementary School-55	10/1/16 07:21	12/7/16 20:01
N041221-56	Copper	EPA 200.8	387	2.00	ug/L	1300	Miller Hill Elementary School-56	10/1/16 07:00	12/7/16 20:03
N041221-57	Copper	EPA 200.8	273	2.00	ug/L	1300	Miller Hill Elementary School-57	10/1/16 07:41	12/7/16 20:05
N041221-58	Copper	EPA 200.8	694	2.00	ug/L	1300	Miller Hill Elementary School-58	10/1/16 07:22	12/7/16 20:07
N041221-59	Copper	EPA 200.8	675	2.00	ug/L	1300	Miller Hill Elementary School-59	10/1/16 07:22	12/7/16 20:09
N041221-60	Copper	EPA 200.8	730	2.00	ug/L	1300	Miller Hill Elementary School-60	10/1/16 07:22	12/7/16 20:11
N041221-61	Copper	EPA 200.8	689	2.00	ug/L	1300	Miller Hill Elementary School-61	10/1/16 07:24	12/7/16 20:13
N041221-62	Copper	EPA 200.8	748	2.00	ug/L	1300	Miller Hill Elementary School-62	10/1/16 07:24	12/7/16 20:15
N041221-63	Copper	EPA 200.8	467	2.00	ug/L	1300	Miller Hill Elementary School-63	10/1/16 07:24	12/7/16 20:17
N041221-64	Copper	EPA 200.8	462	2.00	ug/L	1300	Miller Hill Elementary School-64	10/1/16 07:24	12/7/16 20:27
N041221-65	Copper	EPA 200.8	575	2.00	ug/L	1300	Miller Hill Elementary School-65	10/1/16 07:26	12/7/16 20:29
N041221-66	Copper	EPA 200.8	525	2.00	ug/L	1300	Miller Hill Elementary School-66	10/1/16 07:26	12/7/16 20:31
N041221-67	Copper	EPA 200.8	395	2.00	ug/L	1300	Miller Hill Elementary School-67	10/1/16 07:26	12/7/16 20:33

New Jersey Analytical Laboratories

The  
 cus.



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-68	Copper	EPA 200.8	501	2.00	ug/L	1300	Miller Hill Elementary School-68	10/1/16 07:26	12/7/16 20:35
N041221-69	Copper	EPA 200.8	507	2.00	ug/L	1300	Miller Hill Elementary School-69	10/1/16 07:32	12/7/16 20:37
N041221-70	Copper	EPA 200.8	619	2.00	ug/L	1300	Miller Hill Elementary School-70	10/1/16 07:32	12/7/16 20:39
N041221-71	Copper	EPA 200.8	417	2.00	ug/L	1300	Miller Hill Elementary School-71	10/1/16 07:32	12/7/16 20:42
N041221-72	Copper	EPA 200.8	471	2.00	ug/L	1300	Miller Hill Elementary School-72	10/1/16 07:32	12/7/16 20:46
N041221-73	Copper	EPA 200.8	607	2.00	ug/L	1300	Miller Hill Elementary School-73	10/1/16 07:32	12/7/16 20:48
N041221-74	Copper	EPA 200.8	542	2.00	ug/L	1300	Miller Hill Elementary School-74	10/1/16 07:32	12/7/16 20:58
N041221-75	Copper	EPA 200.8	606	2.00	ug/L	1300	Miller Hill Elementary School-75	10/1/16 07:33	12/7/16 21:00
N041221-76	Copper	EPA 200.8	439	2.00	ug/L	1300	Miller Hill Elementary School-76	10/1/16 07:33	12/7/16 21:02
N041221-77	Copper	EPA 200.8	675	2.00	ug/L	1300	Miller Hill Elementary School-77	10/1/16 07:35	12/7/16 21:04
N041221-78	Copper	EPA 200.8	518	2.00	ug/L	1300	Miller Hill Elementary School-78	10/1/16 07:35	12/7/16 21:06
N041221-79	Copper	EPA 200.8	491	2.00	ug/L	1300	Miller Hill Elementary School-79	10/1/16 07:36	12/7/16 21:08
N041221-80	Copper	EPA 200.8	450	2.00	ug/L	1300	Miller Hill Elementary School-80	10/1/16 07:36	12/7/16 21:10
N041221-81	Copper	EPA 200.8	408	2.00	ug/L	1300	Miller Hill Elementary School-81	10/1/16 07:37	12/7/16 21:12
N041221-82	Copper	EPA 200.8	961	2.00	ug/L	1300	Miller Hill Elementary School-82	10/1/16 07:37	12/7/16 21:14
N041221-83	Copper	EPA 200.8	560	2.00	ug/L	1300	Miller Hill Elementary School-83	10/1/16 07:37	12/7/16 21:16
N041221-84	Copper	EPA 200.8	609	2.00	ug/L	1300	Miller Hill Elementary School-84	10/1/16 07:37	12/7/16 21:27
N041221-85	Copper	EPA 200.8	435	2.00	ug/L	1300	Miller Hill Elementary School-85	10/1/16 07:37	12/7/16 21:29
N041221-86	Copper	EPA 200.8	511	2.00	ug/L	1300	Miller Hill Elementary School-86	10/1/16 07:38	12/7/16 21:31
N041221-87	Copper	EPA 200.8	306	2.00	ug/L	1300	Miller Hill Elementary School-87	10/1/16 07:38	12/7/16 21:33
N041221-88	Copper	EPA 200.8	750	2.00	ug/L	1300	Miller Hill Elementary School-88	10/1/16 07:39	12/7/16 21:37
N041221-89	Copper	EPA 200.8	418	2.00	ug/L	1300	Miller Hill Elementary School-89	10/1/16 07:39	12/7/16 21:39
N041221-90	Copper	EPA 200.8	253	2.00	ug/L	1300	Miller Hill Elementary School-90	10/1/16 07:39	12/7/16 21:41
N041221-91	Copper	EPA 200.8	407	2.00	ug/L	1300	Miller Hill Elementary School-91	10/1/16 07:41	12/7/16 21:43
N041221-92	Copper	EPA 200.8	348	2.00	ug/L	1300	Miller Hill Elementary School-92	10/1/16 07:41	12/7/16 21:45
N041221-93	Copper	EPA 200.8	349	2.00	ug/L	1300	Miller Hill Elementary School-93	10/1/16 07:41	12/7/16 21:47
N041221-94	Copper	EPA 200.8	525	2.00	ug/L	1300	Miller Hill Elementary School-94	10/1/16 07:44	12/7/16 21:58
N041221-96	Copper	EPA 200.8	463	2.00	ug/L	1300	Miller Hill Elementary School-96	10/1/16 07:46	12/7/16 22:00
N041221-98	Copper	EPA 200.8	578	2.00	ug/L	1300	Miller Hill Elementary School-98	10/1/16 07:48	12/7/16 22:02
N041221-99	Copper	EPA 200.8	565	2.00	ug/L	1300	Miller Hill Elementary School-99	10/1/16 07:48	12/7/16 22:04
N041221-AA	Copper	EPA 200.8	473	2.00	ug/L	1300	Miller Hill Elementary School-100	10/1/16 07:49	12/7/16 22:06
N041221-AB	Copper	EPA 200.8	569	2.00	ug/L	1300	Miller Hill Elementary School-101	10/1/16 07:49	12/7/16 22:08



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**


Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-AC	Copper	EPA 200.8	2380	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:50	12/7/16 22:10
N041221-AD	Copper	EPA 200.8	445	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:50	12/7/16 22:12
N041221-AE	Copper	EPA 200.8	277	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:50	12/7/16 22:14
N041221-AF	Copper	EPA 200.8	555	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:50	12/7/16 22:16
N041221-AG	Copper	EPA 200.8	486	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:51	12/7/16 22:29
N041221-AH	Copper	EPA 200.8	368	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:51	12/7/16 22:31
N041221-AI	Copper	EPA 200.8	485	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:52	12/7/16 22:33
N041221-AJ	Copper	EPA 200.8	387	2.00	ug/L	1300	Miller Hill Elementary School-10	10/1/16 07:52	12/7/16 22:35
N041221-AK	Copper	EPA 200.8	654	2.00	ug/L	1300	Miller Hill Elementary School-11	10/1/16 07:53	12/7/16 22:37
N041221-AL	Copper	EPA 200.8	535	2.00	ug/L	1300	Miller Hill Elementary School-11	10/1/16 07:53	12/7/16 22:39
N041221-AM	Copper	EPA 200.8	699	2.00	ug/L	1300	Miller Hill Elementary School-11	10/1/16 07:54	12/7/16 22:41
N041221-AN	Copper	EPA 200.8	728	2.00	ug/L	1300	Miller Hill Elementary School-11	10/1/16 07:54	12/7/16 22:43
N041221-AO	Copper	EPA 200.8	443	2.00	ug/L	1300	lementary School-114 Not lister	10/1/16 07:00	12/7/16 22:45

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-01	Lead	EPA 200.8	1.54	0.50	ug/L	15	Miller Hill Elementary School-01	10/1/16 07:00	10/19/16 17:45
N041221-02	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-02	10/1/16 07:00	10/19/16 17:48
N041221-04	Lead	EPA 200.8	0.95	0.50	ug/L	15	Miller Hill Elementary School-04	10/1/16 07:00	10/19/16 17:50
N041221-05	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-05	10/1/16 07:01	10/19/16 17:52
N041221-06	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-06	10/1/16 07:01	10/19/16 17:54
N041221-07	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-07	10/1/16 07:00	10/19/16 17:56
N041221-08	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-08	10/1/16 07:00	10/19/16 17:58
N041221-09	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-09	10/1/16 07:02	10/19/16 18:00
N041221-10	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-10	10/1/16 07:02	10/19/16 18:02
N041221-11	Lead	EPA 200.8	4.76	0.50	ug/L	15	Miller Hill Elementary School-11	10/1/16 07:03	10/19/16 18:04
N041221-12	Lead	EPA 200.8	1.41	0.50	ug/L	15	Miller Hill Elementary School-12	10/1/16 07:03	10/19/16 18:15
N041221-13	Lead	EPA 200.8	108	0.50	ug/L	15	Miller Hill Elementary School-13	10/1/16 07:02	10/19/16 18:17
N041221-14	Lead	EPA 200.8	6.79	0.50	ug/L	15	Miller Hill Elementary School-14	10/1/16 07:02	10/19/16 18:19
N041221-15	Lead	EPA 200.8	3.01	0.50	ug/L	15	Miller Hill Elementary School-15	10/1/16 07:02	10/19/16 18:21
N041221-16	Lead	EPA 200.8	3.32	0.50	ug/L	15	Miller Hill Elementary School-16	10/1/16 07:05	10/19/16 18:23
N041221-17	Lead	EPA 200.8	11.6	0.50	ug/L	15	Miller Hill Elementary School-17	10/1/16 07:05	10/19/16 18:25
N041221-18	Lead	EPA 200.8	2.55	0.50	ug/L	15	Miller Hill Elementary School-18	10/1/16 07:05	10/19/16 18:27
N041221-19	Lead	EPA 200.8	3.32	0.50	ug/L	15	Miller Hill Elementary School-19	10/1/16 07:05	10/19/16 18:29



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-20	Lead	EPA 200.8	0.62	0.50	ug/L	15	Miller Hill Elementary School-20	10/1/16 07:06	10/19/16 18:34
N041221-21	Lead	EPA 200.8	2.05	0.50	ug/L	15	Miller Hill Elementary School-21	10/1/16 07:06	10/19/16 18:36
N041221-22	Lead	EPA 200.8	1.77	0.50	ug/L	15	Miller Hill Elementary School-22	10/1/16 07:06	10/19/16 18:46
N041221-23	Lead	EPA 200.8	1.68	0.50	ug/L	15	Miller Hill Elementary School-23	10/1/16 07:06	10/19/16 18:48
N041221-24	Lead	EPA 200.8	6.48	0.50	ug/L	15	Miller Hill Elementary School-24	10/1/16 07:08	10/19/16 18:50
N041221-25	Lead	EPA 200.8	9.60	0.50	ug/L	15	Miller Hill Elementary School-25	10/1/16 07:06	10/19/16 18:52
N041221-26	Lead	EPA 200.8	17.7	0.50	ug/L	15	Miller Hill Elementary School-26	10/1/16 07:09	10/19/16 18:55
N041221-27	Lead	EPA 200.8	0.94	0.50	ug/L	15	Miller Hill Elementary School-27	10/1/16 07:09	10/19/16 18:57
N041221-28	Lead	EPA 200.8	3.32	0.50	ug/L	15	Miller Hill Elementary School-28	10/1/16 07:09	10/19/16 18:59
N041221-29	Lead	EPA 200.8	3.08	0.50	ug/L	15	Miller Hill Elementary School-29	10/1/16 07:09	10/19/16 19:01
N041221-30	Lead	EPA 200.8	1.87	0.50	ug/L	15	Miller Hill Elementary School-30	10/1/16 07:11	10/19/16 19:03
N041221-32	Lead	EPA 200.8	10.7	0.50	ug/L	15	Miller Hill Elementary School-32	10/1/16 07:11	10/19/16 19:05
N041221-34	Lead	EPA 200.8	7.73	0.50	ug/L	15	Miller Hill Elementary School-34	10/1/16 07:12	10/19/16 19:16
N041221-35	Lead	EPA 200.8	6.69	0.50	ug/L	15	Miller Hill Elementary School-35	10/1/16 07:12	10/19/16 19:18
N041221-36	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-36	10/1/16 07:13	10/19/16 19:20
N041221-37	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-37	10/1/16 07:13	10/19/16 19:22
N041221-38	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-38	10/1/16 07:15	10/19/16 19:26
N041221-39	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-39	10/1/16 07:15	10/19/16 19:28
N041221-40	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-40	10/1/16 07:16	10/19/16 19:30
N041221-41	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-41	10/1/16 07:17	10/19/16 19:32
N041221-42	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-42	10/1/16 07:17	10/19/16 19:35
N041221-43	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-43	10/1/16 07:18	10/19/16 19:37
N041221-44	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-44	10/1/16 07:18	10/19/16 19:47
N041221-45	Lead	EPA 200.8	76.1	0.50	ug/L	15	Miller Hill Elementary School-45	10/1/16 07:07	10/19/16 19:49
N041221-46	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-46	10/1/16 07:18	10/19/16 19:52
N041221-47	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-47	10/1/16 07:19	10/19/16 19:54
N041221-48	Lead	EPA 200.8	6.18	0.50	ug/L	15	Miller Hill Elementary School-48	10/1/16 07:19	10/19/16 19:56
N041221-49	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-49	10/1/16 07:19	10/19/16 19:58
N041221-50	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-50	10/1/16 07:19	10/19/16 20:00
N041221-51	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-51	10/1/16 07:19	10/19/16 20:02
N041221-52	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-52	10/1/16 07:20	10/19/16 20:04
N041221-53	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-53	10/1/16 07:20	10/19/16 20:06



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-54	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-54	10/1/16 07:41	10/19/16 20:19
N041221-55	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-55	10/1/16 07:21	10/19/16 20:21
N041221-56	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-56	10/1/16 07:00	10/19/16 20:23
N041221-57	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-57	10/1/16 07:41	10/19/16 20:25
N041221-58	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-58	10/1/16 07:22	10/19/16 20:27
N041221-59	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-59	10/1/16 07:22	10/19/16 20:30
N041221-60	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-60	10/1/16 07:22	10/19/16 20:32
N041221-61	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-61	10/1/16 07:24	10/19/16 20:34
N041221-62	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-62	10/1/16 07:24	10/19/16 20:36
N041221-63	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-63	10/1/16 07:24	10/19/16 20:38
N041221-64	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-64	10/1/16 07:24	10/19/16 20:49
N041221-65	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-65	10/1/16 07:26	10/19/16 20:51
N041221-66	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-66	10/1/16 07:26	10/19/16 20:53
N041221-67	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-67	10/1/16 07:26	10/19/16 20:55
N041221-68	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-68	10/1/16 07:26	10/19/16 20:57
N041221-69	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-69	10/1/16 07:32	10/19/16 20:59
N041221-70	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-70	10/1/16 07:32	10/19/16 21:01
N041221-71	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-71	10/1/16 07:32	10/19/16 21:04
N041221-72	Lead	EPA 200.8	0.70	0.50	ug/L	15	Miller Hill Elementary School-72	10/1/16 07:32	10/19/16 21:08
N041221-73	Lead	EPA 200.8	3.78	0.50	ug/L	15	Miller Hill Elementary School-73	10/1/16 07:32	10/19/16 21:10
N041221-74	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-74	10/1/16 07:32	10/19/16 21:21
N041221-75	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-75	10/1/16 07:33	10/19/16 21:23
N041221-76	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-76	10/1/16 07:33	10/19/16 21:25
N041221-77	Lead	EPA 200.8	3.02	0.50	ug/L	15	Miller Hill Elementary School-77	10/1/16 07:35	10/19/16 21:27
N041221-78	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-78	10/1/16 07:35	10/19/16 21:29
N041221-79	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-79	10/1/16 07:36	10/19/16 21:31
N041221-80	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-80	10/1/16 07:36	10/19/16 21:33
N041221-81	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-81	10/1/16 07:37	10/19/16 21:36
N041221-82	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-82	10/1/16 07:37	10/19/16 21:38
N041221-83	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-83	10/1/16 07:37	10/19/16 21:40
N041221-84	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-84	10/1/16 07:37	10/19/16 21:51
N041221-85	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-85	10/1/16 07:37	10/19/16 21:53



NELAC NJ11005  
 EPA NJ01186  
 PADEP 68-05417  
 NYDOH NY12046  
 BWON Approved



380 Scotch Road  
 Ewing, NJ 08628  
 609-737-3477 (p)  
[www.njal.com](http://www.njal.com)

**Total Metals by EPA 200.8**

Date Received: 10/10/16 10:51

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N041221-86	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-86	10/1/16 07:38	10/19/16 21:55
N041221-87	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-87	10/1/16 07:38	10/19/16 21:57
N041221-88	Lead	EPA 200.8	4.89	0.50	ug/L	15	Miller Hill Elementary School-88	10/1/16 07:39	10/19/16 22:01
N041221-89	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-89	10/1/16 07:39	10/19/16 22:03
N041221-90	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-90	10/1/16 07:39	10/19/16 22:05
N041221-91	Lead	EPA 200.8	9.47	0.50	ug/L	15	Miller Hill Elementary School-91	10/1/16 07:41	10/19/16 22:08
N041221-92	Lead	EPA 200.8	1.49	0.50	ug/L	15	Miller Hill Elementary School-92	10/1/16 07:41	10/19/16 22:10
N041221-93	Lead	EPA 200.8	1.22	0.50	ug/L	15	Miller Hill Elementary School-93	10/1/16 07:41	10/19/16 22:12
N041221-94	Lead	EPA 200.8	ND	0.50	ug/L	15	Miller Hill Elementary School-94	10/1/16 07:44	10/20/16 15:59
N041221-96	Lead	EPA 200.8	3.95	0.50	ug/L	15	Miller Hill Elementary School-96	10/1/16 07:46	10/20/16 16:02
N041221-98	Lead	EPA 200.8	12.1	0.50	ug/L	15	Miller Hill Elementary School-98	10/1/16 07:48	10/20/16 16:04
N041221-99	Lead	EPA 200.8	41.7	0.50	ug/L	15	Miller Hill Elementary School-99	10/1/16 07:48	10/20/16 16:15
N041221-AA	Lead	EPA 200.8	2.82	0.50	ug/L	15	Miller Hill Elementary School-100	10/1/16 07:49	10/20/16 16:18
N041221-AB	Lead	EPA 200.8	20.2	0.50	ug/L	15	Miller Hill Elementary School-101	10/1/16 07:49	10/20/16 16:20
N041221-AC	Lead	EPA 200.8	3.15	0.50	ug/L	15	Miller Hill Elementary School-102	10/1/16 07:50	10/20/16 16:22
N041221-AD	Lead	EPA 200.8	1.64	0.50	ug/L	15	Miller Hill Elementary School-103	10/1/16 07:50	10/20/16 16:24
N041221-AE	Lead	EPA 200.8	5.75	0.50	ug/L	15	Miller Hill Elementary School-104	10/1/16 07:50	10/20/16 16:27
N041221-AF	Lead	EPA 200.8	2.53	0.50	ug/L	15	Miller Hill Elementary School-105	10/1/16 07:50	10/20/16 16:29
N041221-AG	Lead	EPA 200.8	1.78	0.50	ug/L	15	Miller Hill Elementary School-106	10/1/16 07:51	10/20/16 16:31
N041221-AH	Lead	EPA 200.8	4.67	0.50	ug/L	15	Miller Hill Elementary School-107	10/1/16 07:51	10/20/16 16:34
N041221-AI	Lead	EPA 200.8	1.46	0.50	ug/L	15	Miller Hill Elementary School-108	10/1/16 07:52	10/20/16 16:36
N041221-AJ	Lead	EPA 200.8	3.78	0.50	ug/L	15	Miller Hill Elementary School-109	10/1/16 07:52	10/20/16 16:50
N041221-AK	Lead	EPA 200.8	2.28	0.50	ug/L	15	Miller Hill Elementary School-110	10/1/16 07:53	10/20/16 16:52
N041221-AL	Lead	EPA 200.8	11.4	0.50	ug/L	15	Miller Hill Elementary School-111	10/1/16 07:53	10/20/16 16:54
N041221-AM	Lead	EPA 200.8	0.97	0.50	ug/L	15	Miller Hill Elementary School-112	10/1/16 07:54	10/20/16 16:56
N041221-AN	Lead	EPA 200.8	3.25	0.50	ug/L	15	Miller Hill Elementary School-113	10/1/16 07:54	10/20/16 16:59
N041221-AO	Lead	EPA 200.8	3.91	0.50	ug/L	15	Elementary School-114 Not listed	10/1/16 07:00	10/20/16 17:01

<b>MILLER HILL - RESULTS</b>			<b>COPPER RESULTS</b>
	<b>SAMPLE #</b>	<b>TEST</b>	<b>ROOM #</b>
#1	NO41221 ( 17 )	COPPER	NURSES BATHROOM FAUCET
#2	NO41221 ( AC )	COPPER	211 CORRIDOR RIGHT RESTROOM BATHROOM FAUCET
<b>MILLER HILL - RESULTS</b>			<b>LEAD RESULTS</b>
	<b>SAMPLE #</b>	<b>TEST</b>	<b>ROOM #</b>
#1	NO41221 (13)	LEAD	106 - BATHROOM FAUCET
#2	NO41221 (26)	LEAD	KITCHEN BATHROOM FAUCET
#3	NO41221 (45)	LEAD	LIBRARY OFFICE SINK FAUCET
#4	NO41221 (99)	LEAD	201 - WATER FOUNTAIN
#5	NO41221 (AB)	LEAD	211 - CORRIDOR RIGHT REST ROOMS - BOYS BATHROOM - FAUCET