

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
MH-01-SF-P-01	Main Office	Sink Faucet	4/27/2021 05:47	5/7/2021 20:07	70171465001	Lead	1.1	15	ug/L	
MH-01-BF-P-02	Main Office	Bathroom Faucet	4/27/2021 05:47	5/7/2021 20:08	70171465002	Lead	<1.0	15	ug/L	
MH-01-SF-P-03	102	Classroom Sink Faucet	4/27/2021 05:48	5/7/2021 20:10	70171465003	Lead	<1.0	15	ug/L	
MH-01-CF-P-04	103	Classroom Sink Faucet	4/27/2021 05:48	5/7/2021 20:11	70171465004	Lead	<1.0	15	ug/L	
MH-01-CF-P-06	104	Classroom Sink Faucet	4/27/2021 05:50	5/7/2021 20:12	70171465005	Lead	<1.0	15	ug/L	
MH-01-CF-P-08	105	Classroom Sink Faucet	4/27/2021 05:50	5/7/2021 20:13	70171465006	Lead	<1.0	15	ug/L	
MH-01-CF-P-10	106	Classroom Sink Faucet	4/27/2021 05:51	5/7/2021 20:14	70171465007	Lead	32.8	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
MH-01-BF-P-12	106	Bathroom Faucet	4/27/2021 05:51	5/7/2021 20:15	70171465008	Lead	9.2	15	ug/L	
MH-01-SF-P-16	109 Health Office	Sink Faucet	4/27/2021 05:53	5/7/2021 20:16	70171465009	Lead	<1.0	15	ug/L	
MH-01-SF-P-17	109 Health Office	Bathroom Faucet	4/27/2021 05:53	5/7/2021 20:19	70171465010	Lead	<1.0	15	ug/L	
MH-01-BF-P-19	Girl's Restroom 110 - R	Bathroom Faucet	4/27/2021 05:54	5/7/2021 20:22	70171465011	Lead	3.5	15	ug/L	
MH-01-BF-P-21	Boy's Restroom 113 - R	Bathroom Faucet	4/27/2021 05:55	5/7/2021 20:23	70171465012	Lead	1.8	15	ug/L	
MH-01-SF-P-22	Library Office	Sink Faucet	4/27/2021 05:56	5/7/2021 20:24	70171465013	Lead	1.0	15	ug/L	
MH-01-CF-P-24	113	Classroom Sink Faucet	4/27/2021 05:57	5/7/2021 20:25	70171465014	Lead	3.9	15	ug/L	
MH-01-BF-P-25	113	Bathroom Faucet	4/27/2021 05:57	5/7/2021 20:26	70171465015	Lead	7.3	15	ug/L	
MH-01-BF-P-26	Kitchen	Bathroom Faucet	4/27/2021 05:59	5/7/2021 20:27	70171465016	Lead	6.2	15	ug/L	
MH-01-SF-P-27	Kitchen - Food Prep	Sink Faucet	4/27/2021 05:59	5/7/2021 20:28	70171465017	Lead	4.3	15	ug/L	
MH-01-DW-P-29	Gym Corridor Bottle Filler	Bottle Filler	4/27/2021 06:01	5/7/2021 20:29	70171465018	Lead	<1.0	15	ug/L	
MH-01-CF-P-30	116	Classroom Sink Faucet	4/27/2021 06:02	5/8/2021 09:18	70171465019	Lead	<1.0	15	ug/L	
MH-01-BF-P-32	Corridor Restroom 116/118	Bathroom Faucet	4/27/2021 06:02	5/8/2021 09:21	70171465020	Lead	<1.0	15	ug/L	
MH-01-CF-P-33	118	Classroom Sink Faucet	4/27/2021 06:02	5/8/2021 09:22	70171465021	Lead	<1.0	15	ug/L	
MH-01-CF-P-35	120	Classroom Sink Faucet	4/27/2021 06:03	5/8/2021 09:22	70171465022	Lead	<1.0	15	ug/L	
MH-01-CF-P-37	122	Classroom Sink Faucet	4/27/2021 06:03	5/8/2021 09:23	70171465023	Lead	<1.0	15	ug/L	
MH-01-CF-P-39	123	Classroom Sink Faucet	4/27/2021 06:04	5/8/2021 09:24	70171465024	Lead	<1.0	15	ug/L	
MH-01-BF-P-41	Faculty Restroom by 123	Bathroom Faucet	4/27/2021 06:05	5/8/2021 09:27	70171465025	Lead	13.1	15	ug/L	
MH-01-CF-P-42	126	Classroom Sink Faucet	4/27/2021 06:05	5/8/2021 09:28	70171465026	Lead	<1.0	15	ug/L	
MH-01-CF-P-44	128	Classroom Sink Faucet	4/27/2021 06:05	5/8/2021 09:29	70171465027	Lead	<1.0	15	ug/L	
MH-01-CF-P-46	130	Classroom Sink Faucet	4/27/2021 06:06	5/8/2021 09:30	70171465028	Lead	<1.0	15	ug/L	
MH-01-BW-P-48	Corridor Restroom 130/132	Bathroom Faucet	4/27/2021 06:06	5/8/2021 09:31	70171465029	Lead	<1.0	15	ug/L	
MH-01-CF-P-49	132	Classroom Sink Faucet	4/27/2021 06:06	5/8/2021 09:34	70171465030	Lead	<1.0	15	ug/L	
MH-02-CF-P-55	232	Classroom Sink Faucet	4/27/2021 06:08	5/8/2021 09:35	70171465031	Lead	<1.0	15	ug/L	
MH-02-BF-P-57	Corridor Restroom 230/232	Bathroom Faucet	4/27/2021 06:09	5/8/2021 09:36	70171465032	Lead	<1.0	15	ug/L	
MH-02-CF-P-58	230	Classroom Sink Faucet	4/27/2021 06:10	5/8/2021 09:39	70171465033	Lead	<1.0	15	ug/L	
MH-02-CF-P-60	228	Classroom Sink Faucet	4/27/2021 06:10	5/8/2021 09:40	70171465034	Lead	1.3	15	ug/L	
MH-02-BF-P-62	Corridor Restroom 226/228	Bathroom Faucet	4/27/2021 06:11	5/8/2021 09:41	70171465035	Lead	<1.0	15	ug/L	
MH-02-CF-P-63	226	Classroom Sink Faucet	4/27/2021 06:11	5/8/2021 09:41	70171465036	Lead	<1.0	15	ug/L	
MH-02-BF-P-65	223 Corridor Right Restroom - Faculty	Bathroom Faucet	4/27/2021 06:11	5/8/2021 09:42	70171465037	Lead	<1.0	15	ug/L	
MH-02-BF-P-66	223 Corridor Left Restroom - Student	Bathroom Faucet	4/27/2021 06:11	5/8/2021 09:43	70171465038	Lead	<1.0	15	ug/L	
MH-02-CF-P-67	223	Classroom Sink Faucet	4/27/2021 06:12	5/8/2021 09:46	70171465039	Lead	<1.0	15	ug/L	
MH-02-CF-P-69	222	Classroom Sink Faucet	4/27/2021 06:12	5/8/2021 09:51	70171465040	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
MH-02-BF-P-71	Corridor 220/222 Restroom	Bathroom Faucet	4/27/2021 06:13	5/8/2021 09:52	70171465041	Lead	<1.0	15	ug/L	
MH-02-BF-P-72	220	Classroom Sink Faucet	4/27/2021 06:14	5/8/2021 09:53	70171465042	Lead	<1.0	15	ug/L	
MH-02-CF-P-74	218	Classroom Sink Faucet	4/27/2021 06:14	5/8/2021 09:54	70171465043	Lead	<1.0	15	ug/L	
MH-02-CF-P-76	Corridor 216/218 Restroom	Bathroom Faucet	4/27/2021 06:15	5/8/2021 09:55	70171465044	Lead	<1.0	15	ug/L	
MH-02-CF-P-77	216	Classroom Sink Faucet	4/27/2021 06:15	5/8/2021 09:56	70171465045	Lead	<1.0	15	ug/L	
MH-02-DW-P-80	Bottle Filler by 215	Water Fountain	4/27/2021 06:16	5/8/2021 09:57	70171465046	Lead	<1.0	15	ug/L	
MH-02-SF-P-81	234 Faculty Room	Sink Faucet	4/27/2021 06:17	5/8/2021 09:58	70171465047	Lead	<1.0	15	ug/L	
MH-02-CF-P-83	201	Classroom Sink Faucet	4/27/2021 06:18	5/8/2021 09:59	70171465048	Lead	<1.0	15	ug/L	
MH-02-BF-P-85	207 Corridor Boy's Room- L	Bathroom Faucet	4/27/2021 06:19	5/8/2021 10:01	70171465049	Lead	5.8	15	ug/L	
MH-02-BF-P-87	207 Corridor Boy's Room- R	Bathroom Faucet	4/27/2021 06:19	5/8/2021 10:04	70171465050	Lead	2.2	15	ug/L	
MH-02-BF-P-88	207 Faculty Restroom	Bathroom Faucet	4/27/2021 06:20	5/8/2021 10:05	70171465051	Lead	3.9	15	ug/L	
MH-02-BF-P-89	207 Corridor Girl's Room - L	Bathroom Faucet	4/27/2021 06:20	5/8/2021 10:06	70171465052	Lead	73.5	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
MH-02-BF-P-91	207 Corridor Girl's Room - R	Bathroom Faucet	4/27/2021 06:21	5/8/2021 10:07	70171465053	Lead	27.9	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
MH-02-CF-P-92	205	Classroom Sink Faucet	4/27/2021 06:21	5/8/2021 10:08	70171465054	Lead	<1.0	15	ug/L	
MH-02-CF-P-94	202	Classroom Sink Faucet	4/27/2021 06:24	5/8/2021 10:09	70171465055	Lead	<1.0	15	ug/L	
MH-02-CF-P-96	204	Classroom Sink Faucet	4/27/2021 06:21	5/8/2021 10:10	70171465056	Lead	152	15	ug/L	Remediation actions are currently under way. (i.e. inspection, replacement, flushing, and posting of non potable water labels. Retesting will be conducted in the future.)
MH-02-CF-P-99	203	Classroom Sink Faucet	4/27/2021 06:24	5/8/2021 10:13	70171465057	Lead	<1.0	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb