



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-01	Copper	EPA 200.8	132	2.0	ug/L	1300	PK-01-BF-P-01	9/23/16 05:00	10/8/16 11:47
N040582-02	Copper	EPA 200.8	121	2.0	ug/L	1300	PK-01-BF-P-02	9/23/16 05:00	10/8/16 11:50
N040582-03	Copper	EPA 200.8	106	2.0	ug/L	1300	PK-01-DW-P-03	9/23/16 05:00	10/8/16 11:52
N040582-04	Copper	EPA 200.8	111	2.0	ug/L	1300	PK-01-DW-P-04	9/23/16 05:00	10/8/16 11:54
N040582-05	Copper	EPA 200.8	106	2.0	ug/L	1300	PK-01-BF-P-05	9/23/16 05:01	10/8/16 11:57
N040582-06	Copper	EPA 200.8	69.6	2.0	ug/L	1300	PK-01-SF-P-06	9/23/16 05:01	10/8/16 11:59
N040582-07	Copper	EPA 200.8	72.2	2.0	ug/L	1300	PK-01-SF-P-07	9/23/16 05:03	10/8/16 12:01
N040582-08	Copper	EPA 200.8	92.6	2.0	ug/L	1300	PK-01-SF-P-08	9/23/16 05:03	10/8/16 12:04
N040582-09	Copper	EPA 200.8	88.5	2.0	ug/L	1300	PK-01-SF-P-09	9/23/16 05:03	10/8/16 12:06
N040582-10	Copper	EPA 200.8	49.1	2.0	ug/L	1300	PK-01-SF-P-10	9/23/16 05:03	10/8/16 12:09
N040582-11	Copper	EPA 200.8	129	2.0	ug/L	1300	PK-01-BF-P-11	9/23/16 05:03	10/8/16 12:20
N040582-12	Copper	EPA 200.8	85.6	2.0	ug/L	1300	PK-01-CF-P-12	9/23/16 05:10	10/8/16 12:23
N040582-13	Copper	EPA 200.8	88.1	2.0	ug/L	1300	PK-01-DW-P-13	9/23/16 05:10	10/8/16 12:25
N040582-14	Copper	EPA 200.8	83.9	2.0	ug/L	1300	PK-01-CF-P-14	9/23/16 05:11	10/8/16 12:28
N040582-15	Copper	EPA 200.8	128	2.0	ug/L	1300	PK-01-DW-P-15	9/23/16 05:11	10/8/16 12:30
N040582-16	Copper	EPA 200.8	137	2.0	ug/L	1300	PK-01-CF-P-16	9/23/16 05:20	10/8/16 12:32
N040582-17	Copper	EPA 200.8	157	2.0	ug/L	1300	PK-01-DW-P-17	9/23/16 05:20	10/8/16 12:35
N040582-18	Copper	EPA 200.8	76.6	2.0	ug/L	1300	PK-01-CF-P-18	9/23/16 05:18	10/8/16 12:37
N040582-19	Copper	EPA 200.8	85.2	2.0	ug/L	1300	PK-01-DW-P-19	9/23/16 05:18	10/8/16 12:42
N040582-20	Copper	EPA 200.8	85.4	2.0	ug/L	1300	PK-01-SF-P-20	9/23/16 05:21	10/8/16 12:44
N040582-21	Copper	EPA 200.8	91.6	2.0	ug/L	1300	PK-01-CF-P-21	9/23/16 05:22	10/8/16 12:56
N040582-22	Copper	EPA 200.8	392	2.0	ug/L	1300	PK-01-SF-P-22	9/23/16 05:22	10/8/16 12:58
N040582-23	Copper	EPA 200.8	68.0	2.0	ug/L	1300	PK-01-BF-P-23	9/23/16 05:22	10/8/16 13:01
N040582-24	Copper	EPA 200.8	71.7	2.0	ug/L	1300	PK-01-BF-P-24	9/23/16 05:26	10/8/16 13:03
N040582-25	Copper	EPA 200.8	106	2.0	ug/L	1300	PK-01-BF-P-25	9/23/16 05:27	10/8/16 13:06
N040582-26	Copper	EPA 200.8	84.6	2.0	ug/L	1300	PK-01-BF-P-26	9/23/16 05:27	10/8/16 13:08
N040582-27	Copper	EPA 200.8	75.1	2.0	ug/L	1300	PK-01-CF-P-27	9/23/16 05:29	10/8/16 13:10
N040582-28	Copper	EPA 200.8	94.3	2.0	ug/L	1300	PK-01-DW-P-28	9/23/16 05:29	10/8/16 13:13
N040582-29	Copper	EPA 200.8	90.5	2.0	ug/L	1300	PK-01-BF-P-29	9/23/16 05:29	10/8/16 13:15
N040582-30	Copper	EPA 200.8	93.4	2.0	ug/L	1300	PK-01-CF-P-30	9/23/16 05:30	10/8/16 13:18
N040582-31	Copper	EPA 200.8	107	2.0	ug/L	1300	PK-01-DW-P-31	9/23/16 05:30	10/8/16 13:29
N040582-32	Copper	EPA 200.8	67.7	2.0	ug/L	1300	PK-01-SF-P-32	9/23/16 05:30	10/8/16 13:32



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-33	Copper	EPA 200.8	147	2.0	ug/L	1300	PK-01-BF-P-33	9/23/16 05:30	10/8/16 13:34
N040582-34	Copper	EPA 200.8	156	2.0	ug/L	1300	PK-01-BF-P-34	9/23/16 05:30	10/8/16 13:37
N040582-35	Copper	EPA 200.8	71.8	2.0	ug/L	1300	PK-01-CF-P-35	9/23/16 05:35	10/8/16 13:41
N040582-36	Copper	EPA 200.8	90.3	2.0	ug/L	1300	PK-01-DW-P-36	9/23/16 05:35	10/8/16 13:44
N040582-37	Copper	EPA 200.8	84.3	2.0	ug/L	1300	PK-01-BF-P-37	9/23/16 05:35	10/8/16 13:46
N040582-38	Copper	EPA 200.8	86.9	2.0	ug/L	1300	PK-01-CF-P-38	9/23/16 05:39	10/8/16 13:49
N040582-39	Copper	EPA 200.8	104	2.0	ug/L	1300	PK-01-DW-P-39	9/23/16 05:39	10/8/16 13:51
N040582-40	Copper	EPA 200.8	97.8	2.0	ug/L	1300	PK-01-BF-P-40	9/23/16 05:39	10/8/16 13:53
N040582-41	Copper	EPA 200.8	69.9	2.0	ug/L	1300	PK-01-CF-P-41	9/23/16 05:39	10/8/16 14:05
N040582-42	Copper	EPA 200.8	86.0	2.0	ug/L	1300	PK-01-DW-P-42	9/23/16 05:39	10/8/16 14:08
N040582-43	Copper	EPA 200.8	60.2	2.0	ug/L	1300	PK-01-BF-P-43	9/23/16 05:39	10/8/16 14:10
N040582-44	Copper	EPA 200.8	68.2	2.0	ug/L	1300	PK-01-CF-P-44	9/23/16 05:40	10/8/16 14:12
N040582-45	Copper	EPA 200.8	94.6	2.0	ug/L	1300	PK-01-DW-P-45	9/23/16 05:40	10/8/16 14:15
N040582-46	Copper	EPA 200.8	62.3	2.0	ug/L	1300	PK-01-BF-P-46	9/23/16 05:40	10/8/16 14:17
N040582-47	Copper	EPA 200.8	85.6	2.0	ug/L	1300	PK-01-CF-P-47	9/23/16 05:42	10/8/16 14:20
N040582-48	Copper	EPA 200.8	96.2	2.0	ug/L	1300	PK-01-DW-P-48	9/23/16 05:42	10/8/16 14:22
N040582-49	Copper	EPA 200.8	81.4	2.0	ug/L	1300	PK-01-BF-P-49	9/23/16 05:42	10/8/16 14:24
N040582-50	Copper	EPA 200.8	74.4	2.0	ug/L	1300	PK-01-CF-P-50	9/23/16 05:40	10/8/16 14:27
N040582-51	Copper	EPA 200.8	82.2	2.0	ug/L	1300	PK-01-DW-P-51	9/23/16 05:40	10/8/16 14:41
N040582-52	Copper	EPA 200.8	65.8	2.0	ug/L	1300	PK-01-BF-P-52	9/23/16 05:40	10/8/16 14:43
N040582-53	Copper	EPA 200.8	111	2.0	ug/L	1300	PK-01-CF-P-53	9/23/16 05:55	10/8/16 14:46
N040582-54	Copper	EPA 200.8	111	2.0	ug/L	1300	PK-01-DW-P-54	9/23/16 05:55	10/8/16 14:48
N040582-55	Copper	EPA 200.8	90.3	2.0	ug/L	1300	PK-01-BF-P-55	9/23/16 05:55	10/8/16 14:51
N040582-56	Copper	EPA 200.8	73.6	2.0	ug/L	1300	PK-01-CF-P-56	9/23/16 05:46	10/8/16 14:53
N040582-57	Copper	EPA 200.8	114	2.0	ug/L	1300	PK-01-DW-P-57	9/23/16 05:46	10/8/16 14:55
N040582-58	Copper	EPA 200.8	78.8	2.0	ug/L	1300	PK-01-BF-P-58	9/23/16 05:46	10/8/16 14:58
N040582-59	Copper	EPA 200.8	81.8	2.0	ug/L	1300	PK-01-CF-P-59	9/23/16 05:47	10/8/16 15:00
N040582-60	Copper	EPA 200.8	111	2.0	ug/L	1300	PK-01-DW-P-60	9/23/16 05:47	10/8/16 15:03
N040582-61	Copper	EPA 200.8	78.2	2.0	ug/L	1300	PK-01-BF-P-61	9/23/16 05:47	10/8/16 15:15
N040582-62	Copper	EPA 200.8	90.6	2.0	ug/L	1300	PK-01-CF-P-62	9/23/16 05:48	10/8/16 15:17
N040582-63	Copper	EPA 200.8	107	2.0	ug/L	1300	PK-01-DW-P-63	9/23/16 05:48	10/8/16 15:19
N040582-64	Copper	EPA 200.8	97.0	2.0	ug/L	1300	PK-01-BF-P-64	9/23/16 05:48	10/8/16 15:22

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-65	Copper	EPA 200.8	96.4	2.0	ug/L	1300	PK-01-CF-P-65	9/23/16 05:50	10/8/16 15:24
N040582-66	Copper	EPA 200.8	99.9	2.0	ug/L	1300	PK-01-DW-P-66	9/23/16 05:50	10/8/16 15:27
N040582-67	Copper	EPA 200.8	91.0	2.0	ug/L	1300	PK-01-BF-P-67	9/23/16 05:50	10/8/16 15:29
N040582-68	Copper	EPA 200.8	98.8	2.0	ug/L	1300	PK-01-CF-P-68	9/23/16 05:51	10/8/16 15:31
N040582-69	Copper	EPA 200.8	94.7	2.0	ug/L	1300	PK-01-DW-P-69	9/23/16 05:51	10/8/16 15:36
N040582-70	Copper	EPA 200.8	73.0	2.0	ug/L	1300	PK-01-BF-P-70	9/23/16 05:51	10/8/16 15:39
N040582-71	Copper	EPA 200.8	73.0	2.0	ug/L	1300	PK-01-CF-P-71	9/23/16 05:52	10/8/16 15:51
N040582-72	Copper	EPA 200.8	94.2	2.0	ug/L	1300	PK-01-DW-P-72	9/23/16 05:52	10/8/16 15:53
N040582-73	Copper	EPA 200.8	87.6	2.0	ug/L	1300	PK-01-BF-P-73	9/23/16 05:52	10/8/16 15:55
N040582-74	Copper	EPA 200.8	168	2.0	ug/L	1300	PK-01-BF-P-74	9/23/16 05:54	10/8/16 15:58
N040582-75	Copper	EPA 200.8	201	2.0	ug/L	1300	PK-01-BF-P-75	9/23/16 05:54	10/8/16 16:00
N040582-76	Copper	EPA 200.8	85.7	2.0	ug/L	1300	PK-01-BF-P-76	9/23/16 05:54	10/8/16 16:03
N040582-77	Copper	EPA 200.8	7.2	2.0	ug/L	1300	PK-01-BF-P-77	9/23/16 05:54	10/8/16 16:05
N040582-78	Copper	EPA 200.8	167	2.0	ug/L	1300	PK-01-SF-P-78	9/23/16 05:55	10/8/16 16:08
N040582-79	Copper	EPA 200.8	103	2.0	ug/L	1300	PK-01-BF-P-79	9/23/16 05:55	10/8/16 16:10
N040582-80	Copper	EPA 200.8	121	2.0	ug/L	1300	PK-01-CF-P-80	9/23/16 05:59	10/8/16 16:12
N040582-81	Copper	EPA 200.8	100	2.0	ug/L	1300	PK-01-CF-P-81	9/23/16 06:00	10/8/16 16:24
N040582-82	Copper	EPA 200.8	85.2	2.0	ug/L	1300	PK-01-BF-P-82	9/23/16 06:01	10/8/16 16:27
N040582-83	Copper	EPA 200.8	52.7	2.0	ug/L	1300	9	9/23/16 05:14	10/8/16 16:29
N040582-84	Copper	EPA 200.8	72.1	2.0	ug/L	1300	10	9/23/16 05:15	10/8/16 16:32
N040582-85	Copper	EPA 200.8	92.1	2.0	ug/L	1300	11	9/23/16 05:17	10/8/16 16:36
N040582-86	Copper	EPA 200.8	83.6	2.0	ug/L	1300	12	9/23/16 05:18	10/8/16 16:39
N040582-87	Copper	EPA 200.8	106	2.0	ug/L	1300	7	9/23/16 05:23	10/8/16 16:41
N040582-88	Copper	EPA 200.8	101	2.0	ug/L	1300	17	9/23/16 05:27	10/8/16 16:44
N040582-89	Copper	EPA 200.8	79.7	2.0	ug/L	1300	GYM CORRIDOR	9/23/16 05:37	10/8/16 16:46
N040582-90	Copper	EPA 200.8	84.2	2.0	ug/L	1300	GYM CORRIDOR	9/23/16 05:37	10/8/16 16:49
N040582-91	Copper	EPA 200.8	286	2.0	ug/L	1300	FOUNTAIN BY 26	9/23/16 06:00	10/8/16 17:01
N040582-92	Copper	EPA 200.8	268	2.0	ug/L	1300	FOUNTAIN BY 26	9/23/16 06:00	10/8/16 17:03
N040582-93	Copper	EPA 200.8	135	2.0	ug/L	1300	NURSE	9/23/16 06:02	10/8/16 17:05
N040582-94	Copper	EPA 200.8	142	2.0	ug/L	1300	LIBRARY	9/23/16 06:06	10/8/16 17:08
N040582-95	Copper	EPA 200.8	119	2.0	ug/L	1300	4	9/23/16 06:06	10/8/16 17:10
Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed

New Jersey Analytical Laboratories

The
 cus.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-01	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-BF-P-01	9/23/16 05:00	10/8/16 11:47
N040582-02	Lead	EPA 200.8	1.2	0.5	ug/L	15	PK-01-BF-P-02	9/23/16 05:00	10/8/16 11:50
N040582-03	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-03	9/23/16 05:00	10/8/16 11:52
N040582-04	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-04	9/23/16 05:00	10/8/16 11:54
N040582-05	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-05	9/23/16 05:01	10/8/16 11:57
N040582-06	Lead	EPA 200.8	1.2	0.5	ug/L	15	PK-01-SF-P-06	9/23/16 05:01	10/8/16 11:59
N040582-07	Lead	EPA 200.8	1.9	0.5	ug/L	15	PK-01-SF-P-07	9/23/16 05:03	10/8/16 12:01
N040582-08	Lead	EPA 200.8	1.4	0.5	ug/L	15	PK-01-SF-P-08	9/23/16 05:03	10/8/16 12:04
N040582-09	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-SF-P-09	9/23/16 05:03	10/8/16 12:06
N040582-10	Lead	EPA 200.8	7.8	0.5	ug/L	15	PK-01-SF-P-10	9/23/16 05:03	10/8/16 12:09
N040582-11	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-11	9/23/16 05:03	10/8/16 12:20
N040582-12	Lead	EPA 200.8	0.7	0.5	ug/L	15	PK-01-CF-P-12	9/23/16 05:10	10/8/16 12:23
N040582-13	Lead	EPA 200.8	1.0	0.5	ug/L	15	PK-01-DW-P-13	9/23/16 05:10	10/8/16 12:25
N040582-14	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-CF-P-14	9/23/16 05:11	10/8/16 12:28
N040582-15	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-DW-P-15	9/23/16 05:11	10/8/16 12:30
N040582-16	Lead	EPA 200.8	1.0	0.5	ug/L	15	PK-01-CF-P-16	9/23/16 05:20	10/8/16 12:32
N040582-17	Lead	EPA 200.8	2.8	0.5	ug/L	15	PK-01-DW-P-17	9/23/16 05:20	10/8/16 12:35
N040582-18	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-CF-P-18	9/23/16 05:18	10/8/16 12:37
N040582-19	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-19	9/23/16 05:18	10/8/16 12:42
N040582-20	Lead	EPA 200.8	6.9	0.5	ug/L	15	PK-01-SF-P-20	9/23/16 05:21	10/8/16 12:44
N040582-21	Lead	EPA 200.8	1.3	0.5	ug/L	15	PK-01-CF-P-21	9/23/16 05:22	10/8/16 12:56
N040582-22	Lead	EPA 200.8	19.6	0.5	ug/L	15	PK-01-SF-P-22	9/23/16 05:22	10/8/16 12:58
N040582-23	Lead	EPA 200.8	2.9	0.5	ug/L	15	PK-01-BF-P-23	9/23/16 05:22	10/8/16 13:01
N040582-24	Lead	EPA 200.8	3.8	0.5	ug/L	15	PK-01-BF-P-24	9/23/16 05:26	10/8/16 13:03
N040582-25	Lead	EPA 200.8	0.7	0.5	ug/L	15	PK-01-BF-P-25	9/23/16 05:27	10/8/16 13:06
N040582-26	Lead	EPA 200.8	0.7	0.5	ug/L	15	PK-01-BF-P-26	9/23/16 05:27	10/8/16 13:08
N040582-27	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-CF-P-27	9/23/16 05:29	10/8/16 13:10
N040582-28	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-28	9/23/16 05:29	10/8/16 13:13
N040582-29	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-29	9/23/16 05:29	10/8/16 13:15
N040582-30	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-CF-P-30	9/23/16 05:30	10/8/16 13:18
N040582-31	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-31	9/23/16 05:30	10/8/16 13:29
N040582-32	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-SF-P-32	9/23/16 05:30	10/8/16 13:32

New Jersey Analytical Laboratories

The
 cis.



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-33	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-BF-P-33	9/23/16 05:30	10/8/16 13:34
N040582-34	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-34	9/23/16 05:30	10/8/16 13:37
N040582-35	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-CF-P-35	9/23/16 05:35	10/8/16 13:41
N040582-36	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-36	9/23/16 05:35	10/8/16 13:44
N040582-37	Lead	EPA 200.8	0.7	0.5	ug/L	15	PK-01-BF-P-37	9/23/16 05:35	10/8/16 13:46
N040582-38	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-CF-P-38	9/23/16 05:39	10/8/16 13:49
N040582-39	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-39	9/23/16 05:39	10/8/16 13:51
N040582-40	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-40	9/23/16 05:39	10/8/16 13:53
N040582-41	Lead	EPA 200.8	3.6	0.5	ug/L	15	PK-01-CF-P-41	9/23/16 05:39	10/8/16 14:05
N040582-42	Lead	EPA 200.8	1.1	0.5	ug/L	15	PK-01-DW-P-42	9/23/16 05:39	10/8/16 14:08
N040582-43	Lead	EPA 200.8	1.0	0.5	ug/L	15	PK-01-BF-P-43	9/23/16 05:39	10/8/16 14:10
N040582-44	Lead	EPA 200.8	3.1	0.5	ug/L	15	PK-01-CF-P-44	9/23/16 05:40	10/8/16 14:12
N040582-45	Lead	EPA 200.8	0.9	0.5	ug/L	15	PK-01-DW-P-45	9/23/16 05:40	10/8/16 14:15
N040582-46	Lead	EPA 200.8	1.2	0.5	ug/L	15	PK-01-BF-P-46	9/23/16 05:40	10/8/16 14:17
N040582-47	Lead	EPA 200.8	4.2	0.5	ug/L	15	PK-01-CF-P-47	9/23/16 05:42	10/8/16 14:20
N040582-48	Lead	EPA 200.8	1.2	0.5	ug/L	15	PK-01-DW-P-48	9/23/16 05:42	10/8/16 14:22
N040582-49	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-49	9/23/16 05:42	10/8/16 14:24
N040582-50	Lead	EPA 200.8	0.6	0.5	ug/L	15	PK-01-CF-P-50	9/23/16 05:40	10/8/16 14:27
N040582-51	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-51	9/23/16 05:40	10/8/16 14:41
N040582-52	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-BF-P-52	9/23/16 05:40	10/8/16 14:43
N040582-53	Lead	EPA 200.8	4.1	0.5	ug/L	15	PK-01-CF-P-53	9/23/16 05:55	10/8/16 14:46
N040582-54	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-54	9/23/16 05:55	10/8/16 14:48
N040582-55	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-55	9/23/16 05:55	10/8/16 14:51
N040582-56	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-CF-P-56	9/23/16 05:46	10/8/16 14:53
N040582-57	Lead	EPA 200.8	0.7	0.5	ug/L	15	PK-01-DW-P-57	9/23/16 05:46	10/8/16 14:55
N040582-58	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-58	9/23/16 05:46	10/8/16 14:58
N040582-59	Lead	EPA 200.8	2.2	0.5	ug/L	15	PK-01-CF-P-59	9/23/16 05:47	10/8/16 15:00
N040582-60	Lead	EPA 200.8	1.0	0.5	ug/L	15	PK-01-DW-P-60	9/23/16 05:47	10/8/16 15:03
N040582-61	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-61	9/23/16 05:47	10/8/16 15:15
N040582-62	Lead	EPA 200.8	0.6	0.5	ug/L	15	PK-01-CF-P-62	9/23/16 05:48	10/8/16 15:17
N040582-63	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-DW-P-63	9/23/16 05:48	10/8/16 15:19
N040582-64	Lead	EPA 200.8	0.5	0.5	ug/L	15	PK-01-BF-P-64	9/23/16 05:48	10/8/16 15:22



NELAC NJ11005
 EPA NJ01186
 PADEP 68-05417
 NYDOH NY12046
 BWON Approved



380 Scotch Road
 Ewing, NJ 08628
 609-737-3477 (p)
www.njal.com

Total Metals by EPA 200.8

Date Received: 09/26/16 17:50

Sample ID#	Analysis	Method	Results	RL	Units	MCL	Sample Point	Sampled	Analyzed
N040582-65	Lead	EPA 200.8	6.0	0.5	ug/L	15	PK-01-CF-P-65	9/23/16 05:50	10/8/16 15:24
N040582-66	Lead	EPA 200.8	4.0	0.5	ug/L	15	PK-01-DW-P-66	9/23/16 05:50	10/8/16 15:27
N040582-67	Lead	EPA 200.8	0.6	0.5	ug/L	15	PK-01-BF-P-67	9/23/16 05:50	10/8/16 15:29
N040582-68	Lead	EPA 200.8	0.9	0.5	ug/L	15	PK-01-CF-P-68	9/23/16 05:51	10/8/16 15:31
N040582-69	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-DW-P-69	9/23/16 05:51	10/8/16 15:36
N040582-70	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-70	9/23/16 05:51	10/8/16 15:39
N040582-71	Lead	EPA 200.8	5.6	0.5	ug/L	15	PK-01-CF-P-71	9/23/16 05:52	10/8/16 15:51
N040582-72	Lead	EPA 200.8	4.4	0.5	ug/L	15	PK-01-DW-P-72	9/23/16 05:52	10/8/16 15:53
N040582-73	Lead	EPA 200.8	0.6	0.5	ug/L	15	PK-01-BF-P-73	9/23/16 05:52	10/8/16 15:55
N040582-74	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-74	9/23/16 05:54	10/8/16 15:58
N040582-75	Lead	EPA 200.8	ND	0.5	ug/L	15	PK-01-BF-P-75	9/23/16 05:54	10/8/16 16:00
N040582-76	Lead	EPA 200.8	1.2	0.5	ug/L	15	PK-01-BF-P-76	9/23/16 05:54	10/8/16 16:03
N040582-77	Lead	EPA 200.8	26.7	0.5	ug/L	15	PK-01-BF-P-77	9/23/16 05:54	10/8/16 16:05
N040582-78	Lead	EPA 200.8	2.9	0.5	ug/L	15	PK-01-SF-P-78	9/23/16 05:55	10/8/16 16:08
N040582-79	Lead	EPA 200.8	4.1	0.5	ug/L	15	PK-01-BF-P-79	9/23/16 05:55	10/8/16 16:10
N040582-80	Lead	EPA 200.8	3.2	0.5	ug/L	15	PK-01-CF-P-80	9/23/16 05:59	10/8/16 16:12
N040582-81	Lead	EPA 200.8	3.3	0.5	ug/L	15	PK-01-CF-P-81	9/23/16 06:00	10/8/16 16:24
N040582-82	Lead	EPA 200.8	3.3	0.5	ug/L	15	PK-01-BF-P-82	9/23/16 06:01	10/8/16 16:27
N040582-83	Lead	EPA 200.8	ND	0.5	ug/L	15	9	9/23/16 05:14	10/8/16 16:29
N040582-84	Lead	EPA 200.8	ND	0.5	ug/L	15	10	9/23/16 05:15	10/8/16 16:32
N040582-85	Lead	EPA 200.8	1.4	0.5	ug/L	15	11	9/23/16 05:17	10/8/16 16:36
N040582-86	Lead	EPA 200.8	0.6	0.5	ug/L	15	12	9/23/16 05:18	10/8/16 16:39
N040582-87	Lead	EPA 200.8	15.1	0.5	ug/L	15	7	9/23/16 05:23	10/8/16 16:41
N040582-88	Lead	EPA 200.8	15.7	0.5	ug/L	15	17	9/23/16 05:27	10/8/16 16:44
N040582-89	Lead	EPA 200.8	ND	0.5	ug/L	15	GYM CORRIDOR	9/23/16 05:37	10/8/16 16:46
N040582-90	Lead	EPA 200.8	ND	0.5	ug/L	15	GYM CORRIDOR	9/23/16 05:37	10/8/16 16:49
N040582-91	Lead	EPA 200.8	ND	0.5	ug/L	15	FOUNTAIN BY 26	9/23/16 06:00	10/8/16 17:01
N040582-92	Lead	EPA 200.8	ND	0.5	ug/L	15	FOUNTAIN BY 26	9/23/16 06:00	10/8/16 17:03
N040582-93	Lead	EPA 200.8	4.5	0.5	ug/L	15	NURSE	9/23/16 06:02	10/8/16 17:05
N040582-94	Lead	EPA 200.8	4.7	0.5	ug/L	15	LIBRARY	9/23/16 06:06	10/8/16 17:08
N040582-95	Lead	EPA 200.8	5.2	0.5	ug/L	15	4	9/23/16 06:06	10/8/16 17:10