

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
PK-01-DW-P-03	Bottle Filler by Boy's Restroom	Bottle Filler	4/28/2021 05:25	5/7/2021 18:31	70171458001	Lead	<1.0	15	ug/L	
PK-01-BF-P-05	Restroom Across from 17	Bathroom Faucet	4/28/2021 05:25	5/7/2021 18:35	70171458002	Lead	<1.0	15	ug/L	
PK-01-KF-P-07	Kitchen - Main Sink - L	Kitchen Faucet	4/28/2021 05:28	5/7/2021 18:37	70171458003	Lead	<1.0	15	ug/L	
PK-01-KF-P-08	Kitchen - Main Sink - R	Kitchen Faucet	4/28/2021 05:28	5/7/2021 18:38	70171458004	Lead	1.1	15	ug/L	
PK-01-KF-P-10	Kitchen - Handwashing Sink	Kitchen Faucet	4/28/2021 05:28	5/7/2021 18:39	70171458005	Lead	1.3	15	ug/L	
PK-01-BF-P-11	Kitchen Restroom	Bathroom Faucet	4/28/2021 05:28	5/7/2021 18:40	70171458006	Lead	1.1	15	ug/L	
PK-01-CF-P-12	9 - Outside Bathroom	Classroom Faucet	4/28/2021 05:35	5/7/2021 18:41	70171458007	Lead	<1.0	15	ug/L	
PK-01-CF-P-14	9	Classroom Faucet	4/28/2021 05:35	5/7/2021 18:42	70171458008	Lead	<1.0	15	ug/L	
PK-01-DW-P-15	10 - Ouside Bathroom	Classroom Faucet	4/28/2021 05:35	5/7/2021 18:43	70171458009	Lead	1.1	15	ug/L	
PK-01-DW-P-17	10	Classroom Faucet	4/28/2021 05:35	5/7/2021 18:44	70171458010	Lead	<1.0	15	ug/L	
PK-01-CF-P-18	11 - Outside Bathroom	Classroom Faucet	4/28/2021 05:36	5/7/2021 18:45	70171458011	Lead	<1.0	15	ug/L	
PK-01-SF-P-20	11	Classroom Faucet	4/28/2021 05:36	5/7/2021 18:50	70171458012	Lead	<1.0	15	ug/L	
PK-01-CF-P-21	12 - Outside Bathroom	Classroom Faucet	4/28/2021 05:37	5/7/2021 18:51	70171458013	Lead	<1.0	15	ug/L	
PK-01-BF-P-23	12	Classroom Faucet	4/28/2021 05:37	5/7/2021 18:52	70171458014	Lead	<1.0	15	ug/L	
PK-01-BF-P-24	7 - Bathroom	Bathroom Faucet	4/28/2021 05:37	5/7/2021 18:53	70171458015	Lead	3.4	15	ug/L	
PK-01-CF-P-26	7	Classroom Faucet	4/28/2021 05:37	5/7/2021 18:54	70171458016	Lead	11.1	15	ug/L	
PK-01-BF-P-27	17	Bathroom Faucet	4/28/2021 05:39	5/7/2021 18:55	70171458017	Lead	2.1	15	ug/L	
PK-01-BF-P-28	18	Bathroom Faucet	4/28/2021 05:40	5/7/2021 18:56	70171458018	Lead	2.7	15	ug/L	
PK-01-DW-P-30	Bottle Filler by 38/Gym	Bottle Filler	4/28/2021 05:40	5/7/2021 18:57	70171458019	Lead	<1.0	15	ug/L	
PK-01-BF-P-31	38 Bathroom	Bathroom Faucet	4/28/2021 05:42	5/7/2021 18:58	70171458020	Lead	<1.0	15	ug/L	
PK-01-BF-P-33	38	Classroom Faucet	4/28/2021 05:42	5/7/2021 19:03	70171458021	Lead	<1.0	15	ug/L	
PK-01-CF-P-34	37	Classroom Faucet	4/28/2021 05:43	5/7/2021 19:05	70171458022	Lead	<1.0	15	ug/L	
PK-01-BF-P-36	37 Bathroom	Bathroom Faucet	4/28/2021 05:43	5/7/2021 19:06	70171458023	Lead	<1.0	15	ug/L	
PK-01-BF-P-37	35/37 Corridor Right Restroom	Bathroom Faucet	4/28/2021 05:44	5/7/2021 19:08	70171458024	Lead	<1.0	15	ug/L	
PK-01-BF-P-38	35/37 Corridor Left Restroom	Bathroom Faucet	4/28/2021 05:44	5/7/2021 19:08	70171458025	Lead	<1.0	15	ug/L	
PK-01-CF-P-39	35 Bathroom	Bathroom Faucet	4/28/2021 05:45	5/7/2021 19:09	70171458026	Lead	<1.0	15	ug/L	
PK-01-BF-P-41	35	Classroom Faucet	4/28/2021 05:45	5/7/2021 19:12	70171458027	Lead	<1.0	15	ug/L	
PK-01-BF-P-44	34	Classroom Faucet	4/28/2021 05:45	5/7/2021 19:13	70171458028	Lead	<1.0	15	ug/L	
PK-01-CF-P-45	32 Bathroom	Bathroom Faucet	4/28/2021 05:46	5/7/2021 19:14	70171458029	Lead	<1.0	15	ug/L	
PK-01-BF-P-47	32	Classroom Faucet	4/28/2021 05:46	5/7/2021 19:15	70171458030	Lead	3.3	15	ug/L	
PK-01-CF-P-48	31 Bathroom	Bathroom Faucet	4/28/2021 05:47	5/7/2021 19:16	70171458031	Lead	<1.0	15	ug/L	
PK-01-CF-P-50	31	Classroom Faucet	4/28/2021 05:47	5/7/2021 19:19	70171458032	Lead	1.6	15	ug/L	
PK-01-BF-P-51	30 Bathroom	Bathroom Faucet	4/28/2021 05:49	5/7/2021 19:20	70171458033	Lead	1.4	15	ug/L	
PK-01-CF-P-53	30	Classroom Faucet	4/28/2021 05:49	5/7/2021 19:21	70171458034	Lead	2.9	15	ug/L	
PK-01-BF-P-54	29 Bathroom	Bathroom Faucet	4/28/2021 05:49	5/7/2021 19:24	70171458035	Lead	<1.0	15	ug/L	
PK-01-CF-P-56	29	Classroom Faucet	4/28/2021 05:49	5/7/2021 19:25	70171458036	Lead	<1.0	15	ug/L	
PK-01-BF-P-57	28 Bathroom	Bathroom Faucet	4/28/2021 05:50	5/7/2021 19:26	70171458037	Lead	<1.0	15	ug/L	
PK-01-CF-P-59	28	Classroom Faucet	4/28/2021 05:50	5/7/2021 19:27	70171458038	Lead	<1.0	15	ug/L	
PK-01-BF-P-60	27 Bathroom	Bathroom Faucet	4/28/2021 05:52	5/7/2021 19:28	70171458039	Lead	<1.0	15	ug/L	
PK-01-CF-P-62	27	Classroom Faucet	4/28/2021 05:52	5/7/2021 19:29	70171458040	Lead	<1.0	15	ug/L	
PK-01-BF-P-63	26 Bathroom	Bathroom Faucet	4/28/2021 05:53	5/7/2021 19:32	70171458041	Lead	<1.0	15	ug/L	
PK-01-CF-P-65	26	Classroom Faucet	4/28/2021 05:53	5/7/2021 19:36	70171458042	Lead	1.5	15	ug/L	
PK-01-BF-P-66	25 Bathroom	Bathroom Faucet	4/28/2021 05:54	5/7/2021 19:37	70171458043	Lead	<1.0	15	ug/L	

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units	Remediation Actions
PK-01-CF-P-68	25	Classroom Faucet	4/28/2021 05:54	5/7/2021 19:38	70171458044	Lead	<1.0	15	ug/L	
PK-01-BF-P-69	23 Bathroom	Bathroom Faucet	4/28/2021 05:55	5/7/2021 19:39	70171458045	Lead	<1.0	15	ug/L	
PK-01-CF-P-71	23	Classroom Faucet	4/28/2021 05:55	5/7/2021 19:40	70171458046	Lead	4.4	15	ug/L	
PK-01-BF-P-72	22 Bathroom	Bathroom Faucet	4/28/2021 05:56	5/7/2021 19:41	70171458047	Lead	<1.0	15	ug/L	
PK-01-BF-P-74	22	Bathroom Faucet	4/28/2021 05:56	5/7/2021 19:42	70171458048	Lead	<1.0	15	ug/L	
PK-01-BF-P-75	20 Bathroom	Bathroom Faucet	4/28/2021 05:56	5/7/2021 19:43	70171458049	Lead	3.1	15	ug/L	
PK-01-CF-P-77	20	Classroom Faucet	4/28/2021 05:56	5/7/2021 19:44	70171458050	Lead	5.9	15	ug/L	
PK-01-DW-P-79	Pod - Bottle Filler	Bottle Filler	4/28/2021 05:59	5/7/2021 19:47	70171458051	Lead	<1.0	15	ug/L	
PK-01-BF-P-80	26/27 Corridor Faculty Restroom - L	Bathroom Faucet	4/28/2021 05:59	5/7/2021 19:50	70171458052	Lead	<1.0	15	ug/L	
PK-01-BF-P-81	26/27 Corridor Faculty Restroom - R	Bathroom Faucet	4/28/2021 05:59	5/7/2021 19:51	70171458053	Lead	<1.0	15	ug/L	
PK-01-BF-P-82	26/27 Corridor Boy's Restroom - L	Bathroom Faucet	4/28/2021 05:59	5/7/2021 19:52	70171458054	Lead	<1.0	15	ug/L	
PK-01-BF-P-83	26/27 Corridor Boy's Restroom - R	Bathroom Faucet	4/28/2021 05:59	5/7/2021 19:53	70171458055	Lead	<1.0	15	ug/L	
PK-01-SF-P-84	Nurse	Sink Faucet	4/28/2021 06:01	5/7/2021 19:54	70171458056	Lead	2.9	15	ug/L	
PK-01-BF-P-85	Nurse Bathroom	Bathroom Faucet	4/28/2021 06:01	5/7/2021 19:55	70171458057	Lead	7.1	15	ug/L	
PK-01-CF-P-86	2	Classroom Faucet	4/28/2021 06:02	5/7/2021 19:56	70171458058	Lead	2.2	15	ug/L	
PK-01-SF-P-87	Library	Sink Faucet	4/28/2021 06:02	5/7/2021 19:59	70171458059	Lead	3.3	15	ug/L	
PK-01-CF-P-88	1	Classroom Faucet	4/28/2021 06:03	5/7/2021 20:00	70171458060	Lead	2.9	15	ug/L	
PK-01-BF-P-89	Main Office	Bathroom Faucet	4/28/2021 06:03	5/7/2021 20:03	70171458061	Lead	2.8	15	ug/L	
PK-01-SF-P-90	4	Classroom Faucet	4/28/2021 06:03	5/7/2021 20:06	70171458062	Lead	4.5	15	ug/L	

NYSDOH Action Level for Lead of 15 ppb