

Sample Identification #	Location	Outlet Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
WSL-01-CF-P-01	1	Classroom Sink Faucet	4/29/2021 05:28	5/12/2021 16:11	70171445001	Lead	<1.0	15	ug/L
WSL-01-BF-P-03	1/2 Corridor Restroom	Bathroom Faucet	4/29/2021 05:29	5/12/2021 16:14	70171445002	Lead	<1.0	15	ug/L
WSL-01-CF-P-04	2	Classroom Sink Faucet	4/29/2021 05:29	5/12/2021 16:15	70171445003	Lead	<1.0	15	ug/L
WSL-01-CF-P-06	3	Classroom Sink Faucet	4/29/2021 05:29	5/12/2021 16:17	70171445004	Lead	<1.0	15	ug/L
WSL-01-BF-P-08	3/4 Corridor Restroom	Bathroom Faucet	4/29/2021 05:29	5/12/2021 16:18	70171445005	Lead	<1.0	15	ug/L
WSL-01-CF-P-09	4	Classroom Sink Faucet	4/29/2021 05:30	5/12/2021 16:19	70171445006	Lead	<1.0	15	ug/L
WSL-01-DW-P-12	Corridor Bottle Filler By 5	Bottle Filler	4/29/2021 05:30	5/12/2021 16:21	70171445007	Lead	<1.0	15	ug/L
WSL-01-BF-P-13	4/5 Corridor Restroom	Bathroom Faucet	4/29/2021 05:30	5/12/2021 16:22	70171445008	Lead	<1.0	15	ug/L
WSL-01-CF-P-14	5	Classroom Sink Faucet	4/29/2021 05:32	5/12/2021 16:23	70171445009	Lead	<1.0	15	ug/L
WSL-01-BF-P-16	5/6 Corridor Restroom	Bathroom Faucet	4/29/2021 05:31	5/12/2021 16:24	70171445010	Lead	<1.0	15	ug/L
WSL-01-CF-P-17	6	Classroom Sink Faucet	4/29/2021 05:32	5/12/2021 16:25	70171445011	Lead	<1.0	15	ug/L
WSL-01-CF-P-19	7	Classroom Sink Faucet	4/29/2021 05:33	5/12/2021 16:29	70171445012	Lead	<1.0	15	ug/L
WSL-01-BF-P-21	7/8 Corridor Restroom	Bathroom Faucet	4/29/2021 05:33	5/12/2021 16:30	70171445013	Lead	<1.0	15	ug/L
WSL-01-CF-P-22	8	Classroom Sink Faucet	4/29/2021 05:34	5/12/2021 16:31	70171445014	Lead	<1.0	15	ug/L
WSL-01-CF-P-24	9	Classroom Sink Faucet	4/29/2021 05:35	5/12/2021 16:33	70171445015	Lead	<1.0	15	ug/L
WSL-01-CF-P-26	10	Classroom Sink Faucet	4/29/2021 05:36	5/12/2021 16:34	70171445016	Lead	<1.0	15	ug/L
WSL-01-CF-P-28	11	Classroom Sink Faucet	4/29/2021 05:36	5/12/2021 16:35	70171445017	Lead	<1.0	15	ug/L
WSL-01-CF-P-30	12	Classroom Sink Faucet	4/29/2021 05:37	5/12/2021 16:37	70171445018	Lead	<1.0	15	ug/L
WSL-01-CF-P-32	13	Classroom Sink Faucet	4/29/2021 05:38	5/12/2021 16:38	70171445019	Lead	<1.0	15	ug/L
WSL-01-BF-P-34	13/15 Corridor Restroom	Bathroom Faucet	4/29/2021 05:39	5/12/2021 16:39	70171445020	Lead	<1.0	15	ug/L
WSL-01-CF-P-35	15	Classroom Sink Faucet	4/29/2021 05:39	5/12/2021 16:41	70171445021	Lead	<1.0	15	ug/L
WSL-01-CF-P-37	14	Classroom Sink Faucet	4/29/2021 05:39	5/12/2021 16:46	70171445022	Lead	<1.0	15	ug/L
WSL-01-BF-P-39	14/16 Corridor Restroom	Bathroom Faucet	4/29/2021 05:39	5/12/2021 16:47	70171445023	Lead	<1.0	15	ug/L
WSL-01-CF-P-40	16	Classroom Sink Faucet	4/29/2021 05:40	5/12/2021 16:48	70171445024	Lead	<1.0	15	ug/L
WSL-01-CF-P-42	17	Classroom Sink Faucet	4/29/2021 05:40	5/12/2021 16:49	70171445025	Lead	<1.0	15	ug/L
WSL-01-BF-P-44	17/19 Corridor Restroom	Bathroom Faucet	4/29/2021 05:40	5/12/2021 16:50	70171445026	Lead	<1.0	15	ug/L
WSL-01-CF-P-45	19	Classroom Sink Faucet	4/29/2021 05:41	5/12/2021 16:51	70171445027	Lead	<1.0	15	ug/L
WSL-01-CF-P-47	18	Classroom Sink Faucet	4/29/2021 05:41	5/12/2021 16:52	70171445028	Lead	<1.0	15	ug/L
WSL-01-BF-P-49	18 Corridor Student Restroom	Bathroom Faucet	4/29/2021 05:42	5/12/2021 16:53	70171445029	Lead	<1.0	15	ug/L
WSL-01-BF-P-50	18 Corridor Faculty Restroom	Bathroom Faucet	4/29/2021 05:42	5/12/2021 16:54	70171445030	Lead	1.2	15	ug/L
WSL-01-CF-P-53	20	Classroom Sink Faucet	4/29/2021 05:43	5/12/2021 16:57	70171445031	Lead	<1.0	15	ug/L
WSL-01-BF-P-55	20/21 Corridor Restroom	Bathroom Faucet	4/29/2021 05:43	5/12/2021 17:00	70171445032	Lead	<1.0	15	ug/L
WSL-01-CF-P-56	21	Classroom Sink Faucet	4/29/2021 05:43	5/12/2021 17:01	70171445033	Lead	<1.0	15	ug/L
WSL-01-CF-P-58	22	Classroom Sink Faucet	4/29/2021 05:45	5/12/2021 17:02	70171445034	Lead	<1.0	15	ug/L
WSL-01-BF-P-60	22	Bathroom Faucet	4/29/2021 05:45	5/12/2021 17:03	70171445035	Lead	<1.0	15	ug/L
WSL-01-CF-P-61	23	Classroom Sink Faucet	4/29/2021 05:46	5/12/2021 17:04	70171445036	Lead	<1.0	15	ug/L
WSL-01-CF-P-64	24	Classroom Sink Faucet	4/29/2021 05:47	5/12/2021 17:06	70171445037	Lead	<1.0	15	ug/L
WSL-01-CF-P-66	25	Classroom Sink Faucet	4/29/2021 05:48	5/12/2021 17:07	70171445038	Lead	<1.0	15	ug/L
WSL-01-CF-P-68	26	Classroom Sink Faucet	4/29/2021 05:49	5/12/2021 17:09	70171445039	Lead	<1.0	15	ug/L
WSL-01-DW-P-71	Receiving Corridor Bottle Filler	Bottle Filler	4/29/2021 05:49	5/12/2021 17:10	70171445040	Lead	<1.0	15	ug/L
WSL-01-KF-P-72	Kitchen - Hand Washing	Kitchen Faucet	4/29/2021 05:49	5/12/2021 17:13	70171445041	Lead	<1.0	15	ug/L
WSL-01-KF-P-73	Kitchen - Food Prep	Kitchen Faucet	4/29/2021 05:50	5/12/2021 17:16	70171445042	Lead	1.9	15	ug/L

WSL-01-KF-P-74	Kitchen - Kettle	Kitchen Faucet	4/29/2021 05:50	5/12/2021 17:17	70171445043	Lead	<1.0	15	ug/L
WSL-01-BF-P-75	Kitchen Restroom	Bathroom Faucet	4/29/2021 05:50	5/12/2021 17:18	70171445044	Lead	<1.0	15	ug/L
WSL-01-BF-P-76	Girl's Restroom by Boiler Room L	Bathroom Faucet	4/29/2021 05:51	5/12/2021 17:21	70171445045	Lead	<1.0	15	ug/L
WSL-01-BF-P-77	Girl's Restroom by Boiler Room R	Bathroom Faucet	4/29/2021 05:51	5/12/2021 17:22	70171445046	Lead	<1.0	15	ug/L
WSL-01-BF-P-79	Boy's Restroom by Faculty R	Bathroom Faucet	4/29/2021 05:53	5/12/2021 17:23	70171445047	Lead	<1.0	15	ug/L
WSL-01-SF-P-80	28 Faculty/Isolation	Sink Faucet	4/29/2021 05:53	5/12/2021 17:24	70171445048	Lead	<1.0	15	ug/L
WSL-01-BF-P-81	28 Faculty/Isolation Restroom	Bathroom Faucet	4/29/2021 05:53	5/12/2021 17:25	70171445049	Lead	<1.0	15	ug/L
WSL-01-SF-P-82	34 Nurse Main Area	Sink Faucet	4/29/2021 05:54	5/12/2021 17:26	70171445050	Lead	<1.0	15	ug/L
WSL-01-SF-P-83	34 Nurse Exam Room	Sink Faucet	4/29/2021 05:54	5/12/2021 17:27	70171445051	Lead	1.4	15	ug/L
WSL-01-BF-P-84	34 Nurse Bathroom	Bathroom Faucet	4/29/2021 05:54	5/12/2021 17:30	70171445052	Lead	<1.0	15	ug/L
WSL-01-BF-P-85	Left Faculty Restroom	Bathroom Faucet	4/29/2021 05:56	5/12/2021 17:33	70171445053	Lead	<1.0	15	ug/L
WSL-01-BF-P-86	Right Faculty Restroom	Bathroom Faucet	4/29/2021 05:56	5/12/2021 17:34	70171445054	Lead	<1.0	15	ug/L
WSL-01-CF-P-87	33 - Music	Classroom Sink Faucet	4/29/2021 05:57	5/12/2021 17:35	70171445055	Lead	<1.0	15	ug/L
WSL-01-BF-P-88	Girl's Restroom	Bathroom Faucet	4/29/2021 05:58	5/12/2021 17:36	70171445056	Lead	<1.0	15	ug/L
WSL-01-DW-P-90	Corridor Bottle Filler	Bottle Filler	4/29/2021 05:57	5/12/2021 17:37	70171445057	Lead	<1.0	15	ug/L
WSL-01-BF-P-91	Boy's Restroom by 31 - L	Bathroom Faucet	4/29/2021 05:58	5/12/2021 17:38	70171445058	Lead	<1.0	15	ug/L
WSL-01-BF-P-92	Boy's Restroom by 31 - R	Bathroom Faucet	4/29/2021 05:58	5/12/2021 17:39	70171445059	Lead	<1.0	15	ug/L
WSL-01-SF-P-93	Library Office	Sink Faucet	4/29/2021 05:59	5/12/2021 17:41	70171445060	Lead	<1.0	15	ug/L

NYSDOH Action Level for Lead of 15 ppb