

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On : 7/24/2024 Page 2 of 2  
Sample ID: BF07577  
Date Received: 07/03/2024  
Time Received: 09:07  
Date Finalized: 7/24/2024  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Schools  
Sample Loc: 333 NY 351  
Sample Pt: After GAC-Kitchen Sink CWT

ALG - 2nd Qtr  
PFAS Summer 2024

Collect Date: 07/03/2024  
Collect Time: 07:53  
Collected by: BILL SANSONE  
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well  
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**Qualifiers Key:**

- |   |  |                             |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit               | R Duplication outside acceptance limits                | H Hold time exceeded        |
| T Temperature outside specifications                | A Sample contained air bubble or headspace             | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits                | Z Analysis is not state-certified                      | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab   |
| J Analyte detected below quantitation limit         | I(+/-) IS/Surrogate outside acceptance limits          |                             |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

PFAS: SUB\* PFAS analyses were completed by NYS DOH Lab. #12058. Samples were prepared on 07/11/24.  
Surrogates: All surrogate recoveries within acceptable limits.

All test results are within acceptable limits where applicable. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

**Averill Park Central School**

Attn: Aaron Heffner  
 146 Gettle Road St. 1  
 Averill Park ,NY 12018

Printed On : 7/24/2024

Page 1 of 2

Sample ID: BF07577

Date Received: 07/03/2024

Time Received: 09:07

Date Finalized: 7/24/2024

PO Number:

Your Ref:

Customer: Averill Park Central School  
 Owner: Averill Park Schools  
 Sample Loc: 333 NY 351  
 Sample Pt: After GAC-Kitchen Sink CWT

Collect Date: 07/03/2024  
 Collect Time: 07:53  
 Collected by: BILL SANSONE  
 Receipt Temp: 15 C on ice chilling

ALG 2ND QRT  
 PFAS Summer 2024

Water Source: Drilled Well  
 Chlorinated: Yes Field Residual Chlorine:

Potable: Yes  
 Grab/Comp: Grab

L a b o r a t o r y R e p o r t

| Test                                      | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|--------|-----|------------|-------|-------------|---------|---------------|
| 4,8-dioxa-3H-perfluorononanoic acid (ADO) | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| 4:2 Fluorotelomersulfonic acid (4:2FTSA)  | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| 6:2 Fluorotelomersulfonic acid (6:2FTSA)  | <1.76  |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| 8:2 Fluorotelomersulfonic acid (8:2FTSA)  | <1.76  |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Hexafluoropropylene oxide dimer acid (HF) | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDH) | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoro(2-ethoxyethane)sulfonic acid (  | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoro-4-oxapentanoic acid (PFMPA)     | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoro-5-oxahexanoic acid (PFMBA)      | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorodecanoic acid (PFDA)             | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorododecanoic acid (PFDoA)          | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoroheptanesulfonic acid (PFHpS)     | <1.76  |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoroheptanoic acid (PFHpA)           | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorohexanesulfonic acid (PFHxS)      | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorononanoic acid (PFNA)             | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorooctanesulfonic acid (PFOS)       | <0.880 | 10  |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorooctanoic acid (PFOA)             | <0.880 | 10  |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoropentanesulfonic acid (PFPeS)     | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoroundecanoic acid (PFUnA)          | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorobutanoic acid (PFBA)             | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorobutanesulfonic acid (PFBS)       | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluoropentanoic acid (PFPeA)           | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| Perfluorohexanoic acid (PFHxA)            | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| 11Cl-PF3OUds (F53B Minor)                 | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |
| 9Cl-PF3ONS (F53B Major)                   | <0.880 |     |            | ng/L  | EPA 533     | SUB*    | 7/15/2024     |