

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 7/24/2024 Page 2 of 2
Sample ID: **BF07578**
Date Received: 07/03/2024
Time Received: 09:07
Date Finalized: 7/24/2024
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Schools
Sample Loc: 333 NY 351
Sample Pt: Mid GAC

Collect Date: 07/03/2024
Collect Time: 07:50
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

*ALG 2RD QRT
PFAS SUMMER
2024*

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |
- (+ Result may be biased high / - Result may be biased low)

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #12058. Samples were prepared on 07/11/24.
Surrogates: All surrogate recoveries within acceptable limits.
PFAS FIELD BLANK:
All analytes - None Detected
Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.
(518) 949-2020

Reviewed by Brian Collins
These results relate to samples as received.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 7/24/2024 Page 1 of 2

Sample ID: **BF07578**
Date Received: 07/03/2024
Time Received: 09:07
Date Finalized: 7/24/2024
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Schools
Sample Loc: 333 NY 351
Sample Pt: Mid GAC

ALL 2ND QRT
PFAS SUMMER
2024

Collect Date: 07/03/2024
Collect Time: 07:50
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

| Test | Result | MCL | Qualifiers | Units | Method Used | Analyst | Analysis Date |
|---|--------|-----|------------|-------|-------------|---------|---------------|
| 4,8-dioxa-3H-perfluorononanoic acid (ADO) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| 4:2 Fluorotelomersulfonic acid (4:2FTSA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| 6:2 Fluorotelomersulfonic acid (6:2FTSA) | <1.91 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| 8:2 Fluorotelomersulfonic acid (8:2FTSA) | <1.91 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Hexafluoropropylene oxide dimer acid (HF) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Nonafluoro-3,6-dioxaheptanoic acid (NFDH) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoro(2-ethoxyethane)sulfonic acid (| <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoro-4-oxapentanoic acid (PFMPA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoro-5-oxahexanoic acid (PFMBA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorodecanoic acid (PFDA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorododecanoic acid (PFDoA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoroheptanesulfonic acid (PFHpS) | <1.91 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoroheptanoic acid (PFHpA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorohexanesulfonic acid (PFHxS) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorononanoic acid (PFNA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorooctanesulfonic acid (PFOS) | <0.954 | 10 | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorooctanoic acid (PFOA) | <0.954 | 10 | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoropentanesulfonic acid (PFPeS) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoroundecanoic acid (PFUnA) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorobutanoic acid (PFBA) | 18.6 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorobutanesulfonic acid (PFBS) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluoropentanoic acid (PFPeA) | 13.6 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| Perfluorohexanoic acid (PFHxA) | 5.09 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| 11Cl-PF3OUds (F53B Minor) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |
| 9Cl-PF3ONS (F53B Major) | <0.954 | | | ng/L | EPA 533 | SUB* | 7/15/2024 |