

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 9/25/2025 Page 1 of 2

Sample ID: BG10629
Date Received: 08/21/2025
Time Received: 11:15
Date Finalized: 9/25/2025
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Well 2 RAW

Collect Date: 08/21/2025
Collect Time: 08:55
Collected by: BRIAN COLLINS
Receipt Temp: 4.1 C On Ice Chilling

3RD QUARTER
PFOA
ALGON. RAW WATER #2

Water Source: Drilled Well
Chlorinated: No *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Hexafluoropropylene oxide dimer acid (HF)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Nonafluoro-3,6-dioxahexanoic acid (NFDH)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoro(2-ethoxyethane)sulfonic acid (<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluorodecanoic acid (PFDA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluorododecanoic acid (PFDoA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoroheptanesulfonic acid (PFHpS)	<1.87		C-	ng/L	EPA 533	SUB*	9/8/2025
Perfluoroheptanoic acid (PFHpA)	4.21			ng/L	EPA 533	SUB*	9/8/2025
Perfluorohexanesulfonic acid (PFHxS)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluorononanoic acid (PFNA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluorooctanesulfonic acid (PFOS)	10.0	10		ng/L	EPA 533	SUB*	9/8/2025
Perfluorooctanoic acid (PFOA)	14.4	10	X	ng/L	EPA 533	SUB*	9/8/2025
Perfluoropentanesulfonic acid (PFPeS)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoroundecanoic acid (PFUnA)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluorobutanoic acid (PFBA)	13.6			ng/L	EPA 533	SUB*	9/8/2025
Perfluorobutanesulfonic acid (PFBS)	<1.87			ng/L	EPA 533	SUB*	9/8/2025
Perfluoropentanoic acid (PFPeA)	45.4			ng/L	EPA 533	SUB*	9/8/2025
Perfluorohexanoic acid (PFHxA)	51.7			ng/L	EPA 533	SUB*	9/8/2025
11Cl-PF3OUds (F53B Minor)	<1.87		S-	ng/L	EPA 533	SUB*	9/8/2025
9Cl-PF3ONS (F53B Major)	<1.87		C-	ng/L	EPA 533	SUB*	9/8/2025