

Averill Park Central School

Printed On : 4/10/2025

Page 1 of 2

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Sample ID: BG02693
Date Received: 03/26/2025
Time Received: 08:56
Date Finalized: 4/10/2025
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Schools
Sample Loc: Averill Park High School
Sample Pt: Well 2 Raw

Collect Date: 03/26/2025
Collect Time: 06:25
Collected by: BILL SANSONE
Receipt Temp: 8.6 C on ice chilling

Water Source:
Chlorinated: No Field Residual Chlorine:

Portable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Hexafluoropropylene oxide dimer acid (HF)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoro(2-ethoxyethane)sulfonic acid (<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorodecanoic acid (PFDA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorododecanoic acid (PFDoA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoroheptanesulfonic acid (PFHpS)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoroheptanoic acid (PFHpA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorohexanesulfonic acid (PFHxS)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorononanoic acid (PFNA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorooctanesulfonic acid (PFOS)	<1.91	10		ng/L	EPA 533	SUB*	4/1/2025
Perfluorooctanoic acid (PFOA)	<1.91	10		ng/L	EPA 533	SUB*	4/1/2025
Perfluoropetanesulfonic acid (PFPeS)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoroundecanoic acid (PFUnA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorobutanoic acid (PFBA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorobutanesulfonic acid (PFBS)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluoropentanoic acid (PFPeA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
Perfluorohexanoic acid (PFHxA)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
11CI-PF3OUds (F53B Minor)	<1.91			ng/L	EPA 533	SUB*	4/1/2025
9CI-PF3ONS (F53B Major)	<1.91			ng/L	EPA 533	SUB*	4/1/2025