

Averill Park Central School

Attn: Aaron Heffner
 146 Gettle Road St. 1
 Averill Park ,NY 12018

Printed On : 2/20/2025 Page 1 of 2

Sample ID: **BG00899**
 Date Received: 02/05/2025
 Time Received: 08:19
 Date Finalized: 2/20/2025
 PO Number:
 Your Ref:

Customer: Averill Park Central School
 Owner: Averill Park Central School
 Sample Loc: 333 NY 351
 Sample Pt: Between GAC 1 - 2

Collect Date: 02/05/2025
 Collect Time: 07:15
 Collected by: BILL SANSONE
 Receipt Temp: 17 C See Note 1

Water Source: Drilled Well
 Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
 Grab/Comp: Grab

*1st QUARTER
 AUG-2025
 PFOA*

Laboratory Report

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Hexafluoropropylene oxide dimer acid (HF)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.91		C-	ng/L	EPA 533	SUB*	2/12/2025
Perfluoro(2-ethoxyethane)sulfonic acid (<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorodecanoic acid (PFDA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorododecanoic acid (PFDoA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoroheptanesulfonic acid (PFHpS)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoroheptanoic acid (PFHpA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorohexanesulfonic acid (PFHxS)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorononanoic acid (PFNA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorooctanesulfonic acid (PFOS)	<1.91	10		ng/L	EPA 533	SUB*	2/12/2025
Perfluorooctanoic acid (PFOA)	2.58	10		ng/L	EPA 533	SUB*	2/12/2025
Perfluoropentanesulfonic acid (PFPeS)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoroundecanoic acid (PFUnA)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluorobutanoic acid (PFBA)	15.3			ng/L	EPA 533	SUB*	2/12/2025
Perfluorobutanesulfonic acid (PFBS)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
Perfluoropentanoic acid (PFPeA)	21.3			ng/L	EPA 533	SUB*	2/12/2025
Perfluorohexanoic acid (PFHxA)	12.5			ng/L	EPA 533	SUB*	2/12/2025
11CI-PF3OUds (F53B Minor)	<1.91			ng/L	EPA 533	SUB*	2/12/2025
9CI-PF3ONS (F53B Major)	<1.91			ng/L	EPA 533	SUB*	2/12/2025