

# Capital Region Environmental Laboratory

137 Columbia Turnpike, Rensselaer, NY 12144  
(518) 949-2020

Averill Park Central School

Your Ref:

Attn: Aaron Heffner

146 Gettle Road St. 1

Averill Park, NY 12018

Sample ID	Sample Point	Collection Date	Field Chlorine	Result	MCL	Qualifiers	Method	Units	Analysis Date
BG12423	PK-01-DW-P-03	09/26/25 04:32	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12424	PK-01-DW-P-04	09/26/25 04:33	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12425	PK-01-SF-P-07	09/26/25 04:44	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12426	PK-01-SF-P-08	09/26/25 04:45	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12427	PK-01-SF-P-09	09/26/25 04:46	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12428	PK-01-SF-P-10	09/26/25 04:40	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12429	PK-01-CF-P-14	09/26/25 04:49	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12430	PK-01-CF-P-17	09/26/25 04:50	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12431	PK-01-CF-P-20	09/26/25 04:53	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12432	PK-01-CF-P-23	09/26/25 04:54	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12433	PK-01-DW-P-29	09/26/25 05:06	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12434	PK-01-DW-P-30	09/26/25 05:06	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12435	PK-01-CF-P-33	09/26/25 05:08	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12436	PK-01-CF-P-34	09/26/25 05:10	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12437	PK-01-CF-P-41	09/26/25 05:12	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12438	PK-01-CF-P-44	09/26/25 05:14	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12439	PK-01-CF-P-47	09/26/25 05:15	Lead (schools)	6.6	15		SM 22 3113E	ug/L	10/06/25
BG12440	PK-01-CF-P-50	09/26/25 05:16	Lead (schools)	2.0	15		SM 22 3113E	ug/L	10/06/25
BG12441	PK-01-CF-P-53	09/26/25 05:20	Lead (schools)	12.4	15		SM 22 3113E	ug/L	10/06/25
BG12442	PK-01-CF-P-56	09/26/25 05:21	Lead (schools)	2.2	15		SM 22 3113E	ug/L	10/06/25
BG12443	PK-01-CF-P-59	09/26/25 05:23	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12444	PK-01-CF-P-62	09/26/25 05:25	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12445	PK-01-CF-P-65	09/26/25 05:27	Lead (schools)	4.6	15		SM 22 3113E	ug/L	10/06/25
BG12446	PK-01-CF-P-68	09/26/25 05:28	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12447	PK-01-CF-P-71	09/26/25 05:30	Lead (schools)	2.5	15		SM 22 3113E	ug/L	10/06/25
BG12448	PK-01-CF-P-74	09/26/25 05:31	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12449	PK-01-CF-P-77	09/26/25 05:32	Lead (schools)	15.2	15	X	SM 22 3113E	ug/L	10/06/25
BG12450	PK-01-CF-P-78	09/26/25 05:36	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12454	PK-01-CF-P-79	09/26/25 05:35	Lead (schools)	<1.0	15		SM 22 3113E	ug/L	10/06/25
BG12455	PK-01-CF-P-84	09/26/25 05:43	Lead (schools)	2.3	15		SM 22 3113E	ug/L	10/06/25
BG12456	PK-01-CF-P-86	09/26/25 05:41	Lead (schools)	2.1	15		SM 22 3113E	ug/L	10/06/25
BG12457	PK-01-SF-P-87	09/26/25 05:47	Lead (schools)	2.1	15		SM 22 3113E	ug/L	10/06/25

# Capital Region Environmental Laboratory

137 Columbia Turnpike

Rensselaer, NY 12144

Phone: (518) 949-2020

## Chain of Custody Record

Invoice:		Averill Park		146 Gettle Road St. 1		Averill Park, NY 12018	
Samplers:		Aron/Bill		Address:		Poestenkill Elementary 1 Veterans St., Poestenkill	
Sample ID	Location	Collection Date	Time	Grab/Comp	Number of Containers		
BG12456	PK-01-CF-P-86 Classroom Faucet Room #6	9/26/2025	5:41	Grab	1		
BG12457	PK-01-SF-P-87 Library Sink Faucet	9/26/2025	5:47	Grab	1		
BG12458	Room #19 Faculty Room Sink	9/26/2025	5:37	Grab	1		
BG12459	Boys Gang Bath Fountain by Restroom	9/26/2025	4:36	Grab	1		
BG12460	Room #7 Sink	9/26/2025	5:40	Grab	1		
BG12461	Nurses Office Fountain	9/26/2025	5:45	Grab	1		
BG12462	Room #7 Fountain	9/26/2025	5:46	Grab	1		
Containers prepared by:		Received by:					
CREL							
Relinquished by:		Received by:					
Method of shipment:		Temperature:					