

# Capital Region Environmental Laboratory

137 Columbia Turnpike, Rensselaer, NY 12144  
(518) 949-2020

Averill Park Central School

Attn: Aaron Hefner

146 Gettle Road St. 1

Averill Park, NY 12018

Your Ref:

West Sand Lake ES

| Sample ID | Sample Point                | Collection Date | Field Chlorine | Result | MCL   | Qualifiers | Method       | Units | Analysis Date |
|-----------|-----------------------------|-----------------|----------------|--------|-------|------------|--------------|-------|---------------|
| BG10654   | Bottle Fill outside Kitchen | 08/21/25 09:32  |                | 0.11   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10654   | Bottle Fill outside Kitchen | 08/21/25 09:32  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10655   | Faculty Room Sink CWT       | 08/21/25 09:35  |                | 0.45   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10655   | Faculty Room Sink CWT       | 08/21/25 09:35  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10656   | Nurses Office Sink CWT      | 08/21/25 09:46  |                | 0.31   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10656   | Nurses Office Sink CWT      | 08/21/25 09:46  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10657   | Bottle Fill Speciality Hall | 08/21/25 09:49  |                | 0.07   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10657   | Bottle Fill Speciality Hall | 08/21/25 09:49  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10658   | Room 32 Art Room            | 08/21/25 09:51  |                | 0.88   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10658   | Room 32 Art Room            | 08/21/25 09:51  |                | 0.003  | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10659   | Room 1 Sink CWT             | 08/21/25 09:53  |                | 0.48   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10659   | Room 1 Sink CWT             | 08/21/25 09:53  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10660   | Room 5 Sink CWT             | 08/21/25 09:55  |                | 3.35   | 1.3   | X          | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10660   | Room 5 Sink CWT             | 08/21/25 09:55  |                | 0.003  | 0.015 |            | SM 22 3113E  | mg/L  | 08/28/25      |
| BG10661   | Bottle Fill Outside Gym     | 08/21/25 09:56  |                | <0.01  | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10661   | Bottle Fill Outside Gym     | 08/21/25 09:56  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10662   | Room 9 Sink CWT             | 08/21/25 09:57  |                | 0.35   | 1.3   |            | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10662   | Room 9 Sink CWT             | 08/21/25 09:57  |                | <0.001 | 0.015 |            | SM 22 3113E  | mg/L  | 08/22/25      |
| BG10663   | Room 17 Sink CWT            | 08/21/25 09:59  |                | 4.97   | 1.3   | X          | 'A200.7 Rev' | mg/L  | 09/05/25      |
| BG10663   | Room 17 Sink CWT            | 08/21/25 09:59  |                | 0.001  | 0.015 |            | SM 22 3113E  | mg/L  | 08/28/25      |

## Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Test procedures for analyses meet NELAC requirements unless noted.

# Capital Region Environmental Laboratory

137 Columbia Turnpike, Rensselaer, NY 12144  
(518) 949-2020

Averill Park Central School  
Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Your Ref: West Sand Lake ES

Sample ID Sample Point Collection Date Field Chlorine Result MCL Qualifiers Method Units Analysis Date



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.