

Capital Region Environmental Laboratory

Averill Park Central School

Attn: Aaron Heffner

146 Gettle Road St. 1

Averill Park, NY 12018

Your Ref: Algonquin MS

Sample ID	Sample Point	Collection Date	Test	Result	Units	MCL	Qualifiers	Method	Analysis Date
BG14843	AMS-01-SF-P-02	11/17/25 04:55	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14844	AMS-01-DW-P-03	11/17/25 04:54	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14845	AMS-01-SF-P-08	11/17/25 05:01	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14846	AMS-01-SF-P-10	11/17/25 04:17	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
Exam - Room Nurse	AMS-01-SF-P-11	11/17/25 04:18	Lead (schools)	9.7	ug/L	15		SM 22 3113B	11/25/25
BG14848	AMS-01-IM-P-12	11/17/25 04:20	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14849	AMS-01-DW-P-14	11/17/25 04:12	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14850	AMS-01-CF-P-16	11/17/25 04:14	Lead (schools)	2.1	ug/L	15		SM 22 3113B	11/25/25
BG14851	AMS-01-CF-P-17	11/17/25 04:15	Lead (schools)	4.4	ug/L	15		SM 22 3113B	11/25/25
BG14852	AMS-01-SF-P-25	11/17/25 04:06	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
BG14853	AMS-01-SF-P-28	11/17/25 04:04	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
KITCHEN KETTLE	AMS-01-KF-P-29	11/17/25 04:00	Lead (schools)	9.2	ug/L	15		SM 22 3113B	11/25/25
KITCHEN	AMS-01-KF-P-30	11/17/25 04:05	Lead (schools)	297	ug/L	15	X	SM 22 3113B	12/01/25
STINK	AMS-01-DW-P-31	11/17/25 04:09	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
PY	AMS-01-DW-P-32	11/17/25 04:09	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
DOUBLE	AMS-01-DW-P-33	11/17/25 12:20	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
DOOR	AMS-01-DW-P-34	11/17/25 04:32	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	11/25/25
DOOR	AMS-01-DW-P-35	11/17/25 04:36	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-SF-P-36	11/17/25 04:37	Lead (schools)	1.4	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-DW-P-37	11/17/25 04:42	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-DW-P-38	11/17/25 04:42	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-SF-P-39	11/17/25 04:44	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-IM-P-40	11/17/25 04:46	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-CF-P-43	11/17/25 04:40	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-CF-P-45	11/17/25 04:59	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-CF-P-46	11/17/25 04:57	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-CF-P-47	11/17/25 04:51	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
	AMS-01-CF-P-48	11/17/25 04:51	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
THE GARAGE	AMS-01-CF-P-48	11/17/25 03:59	Lead (schools)	7.9	ug/L	15		SM 22 3113B	12/01/25
BOILER	AMS-01-KF-P-50	11/17/25 03:59	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
TEACHERS	TEACHERS	11/17/25 04:27	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
TEACHERS	TEACHERS	11/17/25 04:30	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
TEACHERS	TEACHERS	11/17/25 04:34	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
6TH GRADE	6TH GRADE	11/17/25 04:22	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/01/25
BOTTLE FILLER	BOTTLE FILLER	11/17/25 12:20	Lead (schools)	<1.0	ug/L	15		SM 22 3113B	12/03/25

# Capital Region Environmental Laboratory

137 Columbia Turnpike, Rensselaer, NY 12144  
(518) 949-2020

Averill Park Central School  
Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Your Ref: Algonquin MS

Sample ID Sample Point Collection Date Test Result Units MCL Qualifiers Method Analysis Date

### Qualifiers Key:

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfite, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Test procedures for analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person

If you have questions, please call.

(518) 949-2020

**New York State DOH E.L.A.P. # 10350**

**Reviewed by Brian Collins**  
These results relate to samples as received.

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14843**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-02  
Sample Pt: Main Office Sink Faucet

Collect Date: 11/17/2025  
Collect Time: 04:55  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.



**Averill Park Central School**  
Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14845**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-08  
Sample Pt: Library Office Faucet

Collect Date: 11/17/2025  
Collect Time: 05:01  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY93

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14846**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-10  
Sample Pt: Nurse Office Main Faucet

Collect Date: 11/17/2025  
Collect Time: 04:17  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14847**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-11  
Sample Pt: Nurse Office ExamFaucet

Collect Date: 11/17/2025  
Collect Time: 04:18  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**Laboratory Report**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	9.7	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

New York State DOH E.L.A.P. # 10350

Reviewed by Brian Collins  
These results relate to samples as received.

MassDEP Cert. # M-NY93

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 12/4/2025  
Sample ID: **BG14848**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-IM-P-12  
Sample Pt: Nurse Office Ice Machine

Collect Date: 11/17/2025  
Collect Time: 04:20  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**Laboratory Report**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported


**Legend:** < Less Than, > Greater Than

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

New York State DOH E.L.A.P. # 10350

**Reviewed by Brian Collins**  
These results relate to samples as received.

MassDEP Cert. # M-NY93

The documents accompanying this teletype transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this teletype in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14849**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-14  
Sample Pt: Outside PFA2 Fountain

Collect Date: 11/17/2025  
Collect Time: 04:12  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit R Duplication outside acceptance limits H Hold time exceeded
  - T Temperature outside specifications A Sample contained air bubble or headspace B Analyte detected in blank
  - C(+/-) CCV outside acceptance limits Z Analysis is not state-certified G Incorrect bottle received
  - S(+/-) Lab control sample outside acceptance limits M(+/-) Matrix spike recovery outside acceptance limits P Sample preserved at lab
  - J Analyte detected below quantitation limit I(+/-) IS/Surrogate outside acceptance limits
- (+ Result may be biased high / - Result may be biased low)

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 12/4/2025 Page 1 of 1  
**Sample ID:** **BG14850**  
*Date Received:* 11/17/2025  
*Time Received:* 13:25  
*Date Finalized:* 12/4/2025  
*PO Number:*  
*Your Ref:* Algonquin MS

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* AMS-01-CF-P-16  
*Sample Pt:* PFA2 North Side R Faucet

*Collect Date:* 11/17/2025  
*Collect Time:* 04:14  
*Collected by:* AARON HEFFNER  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.1	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 12/4/2025 Page 1 of 1  
**Sample ID:** **BG14851**  
*Date Received:* 11/17/2025  
*Time Received:* 13:25  
*Date Finalized:* 12/4/2025  
*PO Number:*  
*Your Ref:* Algonquin MS

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* AMS-01-CF-P-17  
*Sample Pt:* PFA2 Center L Faucet

*Collect Date:* 11/17/2025  
*Collect Time:* 04:15  
*Collected by:* AARON HEFFNER  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	4.4	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 12/4/2025 Page 1 of 1

**Sample ID: BG14852**  
*Date Received:* 11/17/2025  
*Time Received:* 13:25  
*Date Finalized:* 12/4/2025  
*PO Number:*  
*Your Ref:* Algonquin MS

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* AMS-01-SF-P-25  
*Sample Pt:* 315 Sink Faucet

*Collect Date:* 11/17/2025  
*Collect Time:* 04:06  
*Collected by:* AARON HEFFNER  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025  
Sample ID: **BG14853**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-28  
Sample Pt: Kitchen Food Prep Center Faucet

Collect Date: 11/17/2025  
Collect Time: 04:04  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

New York State DOH E.L.A.P. # 10350

**Reviewed by Brian Collins**

These results relate to samples as received.

MassDEP Cert. # M-NY93

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14854**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-KF-P-29  
Sample Pt: Kitchen Kettle Faucet

Collect Date: 11/17/2025  
Collect Time: 04:00  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	9.2	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018**

**Printed On** 12/4/2025 Page 1 of 1

**Sample ID: BG14855**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-KF-P-30  
Sample Pt: Kitchen Dock Entrance Faucet

Collect Date: 11/17/2025  
Collect Time: 04:05  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	297	15	X	ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14856**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-31  
Sample Pt: Cafeteria Water Fountain

Collect Date: 11/17/2025  
Collect Time: 04:09  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14857**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-32  
Sample Pt: Cafeteria Bottle Filler

Collect Date: 11/17/2025  
Collect Time: 04:09  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14858**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-33  
Sample Pt: Outside 610 Fountain

Collect Date: 11/17/2025  
Collect Time: 12:20  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14859**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-34  
Sample Pt: Corridor by Restrooms Fountain

Collect Date: 11/17/2025  
Collect Time: 04:32  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	11/25/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14860**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-35  
Sample Pt: Outside 800 Fountain

Collect Date: 11/17/2025  
Collect Time: 04:36  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14861**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-36  
Sample Pt: 401 Sink Faucet

Collect Date: 11/17/2025  
Collect Time: 04:37  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.4	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 12/4/2025 Page 1 of 1

**Sample ID: BG14862**  
*Date Received:* 11/17/2025  
*Time Received:* 13:25  
*Date Finalized:* 12/4/2025  
*PO Number:*  
*Your Ref:* Algonquin MS

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* AMS-01-DW-P-37  
*Sample Pt:* New Gym Corridor Fountain

*Collect Date:* 11/17/2025  
*Collect Time:* 04:42  
*Collected by:* AARON HEFFNER  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14863**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-DW-P-38  
Sample Pt: New Gym Corridor Bottle Filler

Collect Date: 11/17/2025  
Collect Time: 04:42  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14864**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-SF-P-39  
Sample Pt: Concession by New Gym Faucet

Collect Date: 11/17/2025  
Collect Time: 04:44  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14865**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-IM-P-40  
Sample Pt: Concession by New Gym Ice Machine

Collect Date: 11/17/2025  
Collect Time: 04:46  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14866**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-CF-P-43  
Sample Pt: 4095/TCA Office Faucet

Collect Date: 11/17/2025  
Collect Time: 04:40  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14867**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-CF-P-45  
Sample Pt: M4 Music/Orchestra Faucet

Collect Date: 11/17/2025  
Collect Time: 04:59  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1  
Sample ID: **BG14868**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-CF-P-46  
Sample Pt: M3 Music/Orchestra Faucet

Collect Date: 11/17/2025  
Collect Time: 04:57  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
 146 Gettle Road St. 1  
 Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14869**  
 Date Received: 11/17/2025  
 Time Received: 13:25  
 Date Finalized: 12/4/2025  
 PO Number:  
 Your Ref: Algonquin MS

Customer: Averill Park Central School  
 Owner: Averill Park Central School  
 Sample Loc: AMS-01-CF-P-47  
 Sample Pt: Central Corridor 700s Fountain

Collect Date: 11/17/2025  
 Collect Time: 04:51  
 Collected by: AARON HEFFNER  
 Receipt Temp: 18 C See Note 1

Water Source:  
 Chlorinated: No Field Residual Chlorine:

Potable: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14870**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-CF-P-48  
Sample Pt: Central Corridor 700s Bottle Filler

Collect Date: 11/17/2025  
Collect Time: 04:51  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14871**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-CF-P-48  
Sample Pt: Kitchen Left Window Wall

Collect Date: 11/17/2025  
Collect Time: 03:59  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	7.9	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14872**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: AMS-01-KF-P-50  
Sample Pt: Kitchen Right Window Wall

Collect Date: 11/17/2025  
Collect Time: 03:59  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**Laboratory Report**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14873**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: TEACHERS  
Sample Pt: Prep Room Between 614+615

Collect Date: 11/17/2025  
Collect Time: 04:27  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14874**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: TEACHERS  
Sample Pt: Prep Room Between 712+713

Collect Date: 11/17/2025  
Collect Time: 04:30  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Capital Region Environmental Laboratory**

137 Columbia Turnpike, Rensselaer, NY 12144  
(518) 949-2020

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14875**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: TEACHERS  
Sample Pt: Prep Room Between 812+813

Collect Date: 11/17/2025  
Collect Time: 04:34  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**Laboratory Report**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
146 Gettle Road St. 1  
Averill Park, NY 12018

**Printed On** 12/4/2025 Page 1 of 1

**Sample ID:** BG14876  
*Date Received:* 11/17/2025  
*Time Received:* 13:25  
*Date Finalized:* 12/4/2025  
*PO Number:*  
*Your Ref:* Algonquin MS

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* 6TH GRADE  
*Sample Pt:* Fountain Outside Nurse Office

*Collect Date:* 11/17/2025  
*Collect Time:* 04:22  
*Collected by:* AARON HEFFNER  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/1/2025

**Qualifiers Key:**

- |   |  |                             |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit               | R Duplication outside acceptance limits                | H Hold time exceeded        |
| T Temperature outside specifications                | A Sample contained air bubble or headspace             | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits                | Z Analysis is not state-certified                      | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab   |
| J Analyte detected below quantitation limit         | I(+/-) IS/Surrogate outside acceptance limits          |                             |
- (+ Result may be biased high / - Result may be biased low)

**Legend:** < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 12/4/2025 Page 1 of 1

Sample ID: **BG14877**  
Date Received: 11/17/2025  
Time Received: 13:25  
Date Finalized: 12/4/2025  
PO Number:  
Your Ref: Algonquin MS

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: BOTTLE FILLER  
Sample Pt: Outside room 610

Collect Date: 11/17/2025  
Collect Time: 12:20  
Collected by: AARON HEFFNER  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	12/3/2025

**Qualifiers Key:**

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

(+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.