

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03082**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: **Miller Hill Elementary School**  
Sample Pt: **MH-01-SF-P-01**

Collect Date: **04/02/2025**  
Collect Time: **04:58**  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: **No** Field Residual Chlorine:

Potable: **Yes**  
Grab/Comp: **Grab**

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<b>&lt;1.0</b>	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03083**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-SF-P-03

Collect Date: 04/02/2025  
Collect Time: 05:12  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.6	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03084**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-04

Collect Date: 04/02/2025  
Collect Time: 05:03  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03085**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-06

Collect Date: 04/02/2025  
Collect Time: 05:06  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03086**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-08

Collect Date: 04/02/2025  
Collect Time: 05:07  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03087**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-10

*Room 106 MH*

Collect Date: 04/02/2025  
Collect Time: 05:09  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	4.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03088**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: **Miller Hill Elementary School**  
Sample Pt: **MH-01-BF-P-14**

Collect Date: **04/02/2025**  
Collect Time: 05:16  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03089**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-SF-P-16

Collect Date: 04/02/2025  
Collect Time: 05:21  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.7	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03090**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: **Miller Hill Elementary School**  
Sample Pt: **MH-01-SF-P-22**

Collect Date: **04/02/2025**  
Collect Time: 05:23  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03092**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-SF-P-27

Collect Date: 04/02/2025  
Collect Time: 05:32  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.3	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03093**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-SF-P-28

Collect Date: 04/02/2025  
Collect Time: 05:33  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.6	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03094**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-SF-P-29

Collect Date: 04/02/2025  
Collect Time: 05:34  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.8	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1  
**Sample ID:** **BG03095**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* MH-01-DW-P-30

*Collect Date:* 04/02/2025  
*Collect Time:* 05:35  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03096**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* MH-01-DW-P-31

*Collect Date:* 04/02/2025  
*Collect Time:* 05:36  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03097**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-32

Collect Date: 04/02/2025  
Collect Time: 05:37  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this teletype transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this teletype in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03099**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-37

Collect Date: 04/02/2025  
Collect Time: 05:39  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03100**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-39

Collect Date: 04/02/2025  
Collect Time: 05:42  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03101**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* MH-01-CF-P-41

*Collect Date:* 04/02/2025  
*Collect Time:* 05:42  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- |   |  |                             |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit               | R Duplication outside acceptance limits                | H Hold time exceeded        |
| T Temperature outside specifications                | A Sample contained air bubble or headspace             | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits                | Z Analysis is not state-certified                      | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab   |
| J Analyte detected below quantitation limit         | I(+/-) IS/Surrogate outside acceptance limits          |                             |
- (+ Result may be biased high / - Result may be biased low)


**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1  
**Sample ID:** **BG03102**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* MH-01-CF-P-44

*Collect Date:* 04/02/2025  
*Collect Time:* 05:44  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (Schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than      mg/L=PPM, ug/L=PPB      If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03103**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-46

Collect Date: 04/02/2025  
Collect Time: 05:45  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03104**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-48

Collect Date: 04/02/2025  
Collect Time: 05:46  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03105**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-CF-P-51

Collect Date: 04/02/2025  
Collect Time: 05:47  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03106**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-DW-P-53

Collect Date: 04/02/2025  
Collect Time: 05:52  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1  
**Sample ID:** **BG03107**  
**Date Received:** 04/02/2025  
**Time Received:** 08:25  
**Date Finalized:** 4/8/2025  
**PO Number:**  
**Your Ref:**

**Customer:** Averill Park Central School  
**Owner:** Averill Park Central School  
**Sample Loc:** Miller Hill Elementary School  
**Sample Pt:** MH-01-DW-P-54

**Collect Date:** 04/02/2025  
**Collect Time:** 05:52  
**Collected by:**  
**Receipt Temp:** 18 C See Note 1

**Water Source:**  
**Chlorinated:** No **Field Residual Chlorine:**

**Potable:** Yes  
**Grab/Comp:** Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03108**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-01-DW-P-55

Collect Date: 04/02/2025  
Collect Time: 05:54  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03109**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-DW-P-56

Collect Date: 04/02/2025  
Collect Time: 05:55  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03110**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-57

Collect Date: 04/02/2025  
Collect Time: 05:56  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03111**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-60

Collect Date: 04/02/2025  
Collect Time: 05:57  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03112**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-SF-P-62

Collect Date: 04/02/2025  
Collect Time: 05:58  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03113**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-65

Collect Date: 04/02/2025  
Collect Time: 05:59  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03114**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-69

Collect Date: 04/02/2025  
Collect Time: 06:01  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03115**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-71

Collect Date: 04/02/2025  
Collect Time: 06:04  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1  
**Sample ID:** **BG03116**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* MH-02-CF-P-74

*Collect Date:* 04/02/2025  
*Collect Time:* 06:05  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03117**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-76

Collect Date: 04/02/2025  
Collect Time: 06:06  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03118**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-79

Collect Date: 04/02/2025  
Collect Time: 06:07  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03119**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-DW-P-81

Collect Date: 04/02/2025  
Collect Time: 06:07  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03120**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-DW-P-82

Collect Date: 04/02/2025  
Collect Time: 06:08  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03121**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-SF-P-83

Collect Date: 04/02/2025  
Collect Time: 06:12  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1

Sample ID: **BG03122**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-85

Collect Date: 04/02/2025  
Collect Time: 06:15  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1

**Sample ID: BG03123**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-94

Collect Date: 04/02/2025  
Collect Time: 06:16  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	2.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03124**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-96

Collect Date: 04/02/2025  
Collect Time: 06:18  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.7	15		ug/L	SM 22 3113B	MN	4/4/2025

Qualifiers Key:

X Exceeds maximum contamination limit	R Duplication outside acceptance limits	H Hold time exceeded
T Temperature outside specifications	A Sample contained air bubble or headspace	B Analyte detected in blank
C(+/-) CCV outside acceptance limits	Z Analysis is not state-certified	G Incorrect bottle received
S(+/-) Lab control sample outside acceptance limits	M(+/-)Matrix spike recovery outside acceptance limits	P Sample preserved at lab
J Analyte detected below quantitation limit	I(+/-) IS/Surrogate outside acceptance limits	
(+ Result may be biased high / - Result may be biased low)		


Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park, NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03125**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: Miller Hill Elementary School  
Sample Pt: MH-02-CF-P-98

Collect Date: 04/02/2025  
Collect Time: 06:19  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y   R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	1.5	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB

If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On 4/8/2025 Page 1 of 1  
Sample ID: **BG03126**  
Date Received: 04/02/2025  
Time Received: 08:25  
Date Finalized: 4/8/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: **Miller Hill Elementary School**  
Sample Pt: **MH-02-CF-P-101**

Collect Date: **04/02/2025**  
Collect Time: 06:20  
Collected by:  
Receipt Temp: 18 C See Note 1

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<b>1.8</b>	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than

mg/L=PPM, ug/L=PPB


If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**  
**Attn: Aaron Heffner**  
**146 Gettle Road St. 1**  
**Averill Park ,NY 12018**

**Printed On** 4/8/2025 Page 1 of 1  
**Sample ID:** **BG03128**  
*Date Received:* 04/02/2025  
*Time Received:* 08:25  
*Date Finalized:* 4/8/2025  
*PO Number:*  
*Your Ref:*

*Customer:* Averill Park Central School  
*Owner:* Averill Park Central School  
*Sample Loc:* Miller Hill Elementary School  
*Sample Pt:* Room 110 Art Front Sink

*Collect Date:* 04/02/2025  
*Collect Time:* 05:27  
*Collected by:*  
*Receipt Temp:* 18 C See Note 1

*Water Source:*  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead (schools)	<1.0	15		ug/L	SM 22 3113B	MN	4/4/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-) Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab


**Legend:** < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

Test procedures for all analyses meet NELAC requirements unless noted.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

**MassDEP Cert. # M-NY934**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
146 Gettle Road St. 1  
Averill Park ,NY 12018

Printed On : 4/21/2025 Page 1 of 1  
Sample ID: **BG03461**  
Date Received: 04/12/2025  
Time Received: 12:30  
Date Finalized: 4/21/2025  
PO Number:  
Your Ref:

Customer: Averill Park Central School  
Owner: Averill Park Central School  
Sample Loc: **Miller Hill Elementary School**  
Sample Pt: **Cafe Fountain**

Collect Date: **04/11/2025**  
Collect Time: 06:07  
Collected by: AARON HEFFNER  
Receipt Temp: 9.3 C On Ice Chilling

Water Source:  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM 22 3113B	MN	4/18/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.  
(518) 949-2020

**Reviewed by Brian Collins**  
These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.

**Averill Park Central School**

Attn: Aaron Heffner  
 146 Gettle Road St. 1  
 Averill Park ,NY 12018

Printed On : 4/21/2025 Page 1 of 1

Sample ID: **BG03460**  
 Date Received: 04/12/2025  
 Time Received: 12:30  
 Date Finalized: 4/21/2025  
 PO Number:  
 Your Ref:

Customer: Averill Park Central School  
 Owner: Averill Park Central School  
 Sample Loc: Miller Hill Elementary School  
 Sample Pt: Cafe Bottle Filler

Collect Date: 04/11/2025  
 Collect Time: 06:06  
 Collected by: AARON HEFFNER  
 Receipt Temp: 9.3 C On Ice Chilling

Water Source:  
 Chlorinated: No Field Residual Chlorine:

Potable: Yes  
 Grab/Comp: Grab

**L a b o r a t o r y R e p o r t**

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Lead	0.002	0.015		mg/L	SM 22 3113B	MN	4/18/2025

**Qualifiers Key:**

- X Exceeds maximum contamination limit
- T Temperature outside specifications
- C(+/-) CCV outside acceptance limits
- S(+/-) Lab control sample outside acceptance limits
- J Analyte detected below quantitation limit
- (+ Result may be biased high / - Result may be biased low)
- R Duplication outside acceptance limits
- A Sample contained air bubble or headspace
- Z Analysis is not state-certified
- M(+/-)Matrix spike recovery outside acceptance limits
- I(+/-) IS/Surrogate outside acceptance limits
- H Hold time exceeded
- B Analyte detected in blank
- G Incorrect bottle received
- P Sample preserved at lab

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

**Comments:**

All test results are within acceptable limits. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins  
 Lead Technical Director Environmental Laboratory  
 and contact person  
 If you have questions, please call.  
 (518) 949-2020

**Reviewed by Brian Collins**  
 These results relate to samples as received.

New York State DOH E.L.A.P. # 10350

MassDEP Cert. # M-NY934

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.