

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/9/2026 Page 1 of 2

Sample ID: BH04821
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Averill Park High School
Sample Pt: Well 1

Collect Date: 05/28/2026
Collect Time: 08:50
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.7			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026 Page 2 of 2

Sample ID: BH04821
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Averill Park High School
Sample Pt: Well 1

Collect Date: 05/28/2026
Collect Time: 08:50
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported


MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
 Surrogates: All surrogate recoveries within acceptable limits.

All test results are within acceptable limits where applicable. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/9/2026

Page 1 of 2

Sample ID: BH04822

Date Received: 05/28/2026

Time Received: 10:22

Date Finalized: 6/9/2026

PO Number:

Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Averill Park High School
Sample Pt: Well 2

Collect Date: 05/28/2026
Collect Time: 09:00
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	<1.8	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.8	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.8			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026 Page 2 of 2

Sample ID: BH04822
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Averill Park High School
Sample Pt: Well 2

Collect Date: 05/28/2026
Collect Time: 09:00
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
 Surrogates: All surrogate recoveries within acceptable limits.

All test results are within acceptable limits where applicable. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026

Page 1 of 2

Sample ID: BH04823

Date Received: 05/28/2026

Time Received: 10:22

Date Finalized: 6/9/2026

PO Number:

Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Miller Hill
Sample Pt: Well 1

Collect Date: 05/28/2026

Collect Time: 08:00

Collected by: BILL SANSONE

Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well

Potable: Yes

Chlorinated: Yes Field Residual Chlorine:

Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	3.4	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	3.5	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	2.1			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/9/2026 Page 2 of 2
Sample ID: BH04823
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Miller Hill
Sample Pt: Well 1

Collect Date: 05/28/2026
Collect Time: 08:00
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.

Surrogates: All surrogate recoveries within acceptable limits.

PFAS FIELD BLANK:

All analytes - None Detected

Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/9/2026

Page 1 of 2

Sample ID: BH04824

Date Received: 05/28/2026

Time Received: 10:22

Date Finalized: 6/9/2026

PO Number:

Your Ref:

Customer: Averill Park Central School

Owner: Averill Park Central School

Sample Loc: Miller Hill

Sample Pt: Well 2

Collect Date: 05/28/2026

Collect Time: 08:01

Collected by: BILL SANSONE

Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well

Chlorinated: Yes Field Residual Chlorine:

Potable: Yes

Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9		I+	ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	3.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	3.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	2.6			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

Attn: Aaron Heffner
 146 Gettle Road St. 1
 Averill Park ,NY 12018

Printed On : 6/9/2026 Page 2 of 2
 Sample ID: BH04824
 Date Received: 05/28/2026
 Time Received: 10:22
 Date Finalized: 6/9/2026
 PO Number:
 Your Ref:

Customer: Averill Park Central School
 Owner: Averill Park Central School
 Sample Loc: Miller Hill
 Sample Pt: Well 2

Collect Date: 05/28/2026
 Collect Time: 08:01
 Collected by: BILL SANSONE
 Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
 Chlorinated: Yes Field Residual Chlorine:

Potable: Yes
 Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
 Surrogates: Surogate recovery for surrogate 13C2-4-2 FTSA was above acceptable limits. All other surrogate recoveries within acceptable limits.
 PFAS FIELD BLANK:
 All analytes - None Detected
 Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026

Page 1 of 2

Sample ID: BH04826

Date Received: 05/28/2026

Time Received: 10:22

Date Finalized: 6/9/2026

PO Number:

Your Ref:

Customer: Averill Park Central School

Collect Date: 05/28/2026

Owner: Averill Park Central School

Collect Time: 09:30

Sample Loc: West Sand Lake Elem.

Collected by: BILL SANSONE

Sample Pt: Well 1

Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well

Potable: Yes

Chlorinated: Yes Field Residual Chlorine:

Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	<1.9	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.9	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.9			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.9			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026 Page 2 of 2

Sample ID: BH04826
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: West Sand Lake Elem.
Sample Pt: Well 1

Collect Date: 05/28/2026
Collect Time: 09:30
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | |
|---|--|-----------------------------|
| X Exceeds maximum contamination limit | R Duplication outside acceptance limits | H Hold time exceeded |
| T Temperature outside specifications | A Sample contained air bubble or headspace | B Analyte detected in blank |
| C(+/-) CCV outside acceptance limits | Z Analysis is not state-certified | G Incorrect bottle received |
| S(+/-) Lab control sample outside acceptance limits | M(+/-) Matrix spike recovery outside acceptance limits | P Sample preserved at lab |
| J Analyte detected below quantitation limit | I(+/-) IS/Surrogate outside acceptance limits | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported


MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
 Surrogates: All surrogate recoveries within acceptable limits.

All test results are within acceptable limits where applicable. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/9/2026

Page 1 of 2

Sample ID: BH04827
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: West Sand Lake Elem.
Sample Pt: Well 2

Collect Date: 05/28/2026
Collect Time: 09:45
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.7			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/9/2026 Page 2 of 2

Sample ID: BH04827
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/9/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: West Sand Lake Elem.
Sample Pt: Well 2

Collect Date: 05/28/2026
Collect Time: 09:45
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

- | | | | | | |
|--------|--|--------|---|---|---------------------------|
| X | Exceeds maximum contamination limit | R | Duplication outside acceptance limits | H | Hold time exceeded |
| T | Temperature outside specifications | A | Sample contained air bubble or headspace | B | Analyte detected in blank |
| C(+/-) | CCV outside acceptance limits | Z | Analysis is not state-certified | G | Incorrect bottle received |
| S(+/-) | Lab control sample outside acceptance limits | M(+/-) | Matrix spike recovery outside acceptance limits | P | Sample preserved at lab |
| J | Analyte detected below quantitation limit | I(+/-) | IS/Surrogate outside acceptance limits | | |

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
Surrogates: All surrogate recoveries within acceptable limits.

All test results are within acceptable limits where applicable. Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.

Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.

Reviewed by Brian Collins
These results relate to samples as received.

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/10/2026 Page 1 of 2

Sample ID: BH04828
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/10/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Between GAC 2&3

Collect Date: 05/28/2026
Collect Time: 07:15
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	2.9	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.8	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	30.6			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	7.1			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	2.0			ng/L	EPA 533	SUB*	6/2/2026
11Cl-PF3OUds (F53B Minor)	<1.8			ng/L	EPA 533	SUB*	6/2/2026
9Cl-PF3ONS (F53B Major)	<1.8			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/10/2026

Page 2 of 2

Sample ID: BH04828
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/10/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Between GAC 2&3

Collect Date: 05/28/2026
Collect Time: 07:15
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.


Surrogates: All surrogate recoveries within acceptable limits.

PFAS FIELD BLANK:

All analytes - None Detected

Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
Lead Technical Director Environmental Laboratory
and contact person
If you have questions, please call.

Reviewed by Brian Collins
These results relate to samples as received.

Averill Park Central School

Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018

Printed On : 6/10/2026

Page 1 of 2

Sample ID: BH04830
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/10/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Kitchen Sink CWT

Collect Date: 05/28/2026
Collect Time: 07:05
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
4,8-dioxa-3H-perfluorononanoic acid (ADO)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
4:2 Fluorotelomersulfonic acid (4:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
6:2 Fluorotelomersulfonic acid (6:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
8:2 Fluorotelomersulfonic acid (8:2FTSA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Hexafluoropropylene oxide dimer acid (HF)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Nonafluoro-3,6-dioxaheptanoic acid (NFDH)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro(2-ethoxyethane)sulfonic acid (<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-4-oxapentanoic acid (PFMPA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoro-5-oxahexanoic acid (PFMBA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorodecanoic acid (PFDA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorododecanoic acid (PFDoA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanesulfonic acid (PFHpS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroheptanoic acid (PFHpA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanesulfonic acid (PFHxS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorononanoic acid (PFNA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanesulfonic acid (PFOS)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluorooctanoic acid (PFOA)	<1.7	10		ng/L	EPA 533	SUB*	6/2/2026
Perfluoropetanesulfonic acid (PFPeS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoroundecanoic acid (PFUnA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanoic acid (PFBA)	6.6			ng/L	EPA 533	SUB*	6/2/2026
Perfluorobutanesulfonic acid (PFBS)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluoropentanoic acid (PFPeA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
Perfluorohexanoic acid (PFHxA)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
11CI-PF3OUds (F53B Minor)	<1.7			ng/L	EPA 533	SUB*	6/2/2026
9CI-PF3ONS (F53B Major)	<1.7			ng/L	EPA 533	SUB*	6/2/2026

Averill Park Central School

**Attn: Aaron Heffner
146 Gettle Road St. 1
Averill Park ,NY 12018**

Printed On : 6/10/2026 Page 2 of 2

Sample ID: BH04830
Date Received: 05/28/2026
Time Received: 10:22
Date Finalized: 6/10/2026
PO Number:
Your Ref:

Customer: Averill Park Central School
Owner: Averill Park Central School
Sample Loc: Algonquin Middle School
Sample Pt: Kitchen Sink CWT

Collect Date: 05/28/2026
Collect Time: 07:05
Collected by: BILL SANSONE
Receipt Temp: 15 C on ice chilling

Water Source: Drilled Well
Chlorinated: Yes *Field Residual Chlorine:*

Potable: Yes
Grab/Comp: Grab

Qualifiers Key:

X	Exceeds maximum contamination limit	R	Duplication outside acceptance limits	H	Hold time exceeded
T	Temperature outside specifications	A	Sample contained air bubble or headspace	B	Analyte detected in blank
C(+/-)	CCV outside acceptance limits	Z	Analysis is not state-certified	G	Incorrect bottle received
S(+/-)	Lab control sample outside acceptance limits	M(+/-)	Matrix spike recovery outside acceptance limits	P	Sample preserved at lab
J	Analyte detected below quantitation limit	I(+/-)	IS/Surrogate outside acceptance limits		

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported


MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

PFAS: SUB* PFAS analyses were completed by NYS DOH Lab. #10709. Samples were prepared on 06/01/26.
 Surrogates: All surrogate recoveries within acceptable limits.
 PFAS FIELD BLANK:
 All analytes - None Detected
 Surrogates: All surrogate recoveries within acceptable limits.

Test procedures for all analyses meet NELAC requirements unless noted. If you have any questions, please call the laboratory.



Brian Collins
 Lead Technical Director Environmental Laboratory
 and contact person
 If you have questions, please call.

Reviewed by Brian Collins
 These results relate to samples as received.